



NOTES: (THIS SHEET ONLY)

1. GENERAL: ALL EMERGENCY EGRESS LIGHT FIXTURES, ELCO NORMAL POWER SENSING CIRCUIT, AND EXIT SIGNS SHALL BE UNSWITCHED.
2. GENERAL: LOCATION OF RECESSED CEILING LUMINAIRES SHALL BE AS INDICATED ON ARCHITECTURAL REFLECTED CEILING PLAN(S). THIS CONTRACTOR SHALL VERIFY ALL FIXTURE QUANTITIES. SHOULD QUANTITY DISCREPANCIES OCCUR, CONTRACTOR SHALL PROVIDE FOR THE GREATER VALUE.
3. GENERAL: PROVIDE 0-10V DIMMING CABLES FROM ROOM LIGHT CONTROLLER TO EACH FIXTURE SHOWN IN A SPACE WITH LOW VOLTAGE DIGITAL DIMMER. THE CABLES SHALL BE SUPPORTED BY J-HOOK SYSTEM.
4. INSTALL LIGHTING CONTROL SYSTEM OVERPANELS AT THE LOCATION LABEL BUTTON WITH CONTROLLED AREA.
5. PROVIDE UL924 EMERGENCY LIGHTING CONTROL UNIT (ELCU) FOR THIS FIXTURE. DEVICE SHALL BE COMPLIANT WITH 10V DIMMING SYSTEM AND SHALL DRIVE FIXTURES TO 100% ON POWER LOSS REGARDLESS OF OTHER CONTROL SETTINGS. RECESSED 0-10V DIMMING CIRCUIT BE ROUTED VIA THIS UNIT. EGRESS LIGHTING SHALL BE DIMMED WITH LINE FIXTURES WITHIN SPACE. THE UNSWITCHED LEG OF EMERGENCY LIGHTING CIRCUIT IN ADDITION EMERGENCY LIGHTING CIRCUIT SHALL BE ROUTED VIA THIS UNIT. INSTALL IN 1-BOX ADJACENT TO FIXTURE.

ISSUANCES

DATE	Description

KEY PLAN

AH&P
CONSULTING ENGINEERS
ANDREWS, HAMMOCK & POWELL, INC.
255 Dexter Lane
Suite 100
Macon, Georgia 31210
Macon, GA 31210
Fax 478 405-8210
WWW.AHPENG.COM



Manley Spangler Smith Architects
A Professional Corporation

625 East Taylor St
P.O. Box 880
Griffin, Georgia 30224
Office 770 227 5473
Fax 770 228 3442

PROJECT:
HENRY COUNTY
SCHOOLS -
DISTRIBUTION CENTER

CLIENT:
HENRY COUNTY BOARD
OF EDUCATION

SHEET TITLE:
LIGHTING FLOOR PLAN

PROJECT NUMBER: 201827
DATE: 08.13.20
SCALE: AS SHOWN
DRAWN BY: SMN
CHECKED BY: NHO

SHEET NO.: E1.21

LIGHTING FLOOR PLAN

SCALE: 3/32" = 1'-0"

Order Plans @

WWW.LDLINE.COM