




- NOTES: (THIS SHEET ONLY)**
1. ALL DATA OUTLETS ATTACHED TO THIS PLAN SOUTH WALL SHALL BE ABOVE COUNTER. COORDINATE WITH ARCHITECTURAL PLANS FOR EXACT MOUNTING HEIGHT.
 2. GENERAL: CONNECT ALL DATA OUTLETS AND ENDPOINTS TO MDU IN ACCORDANCE WITH SPECIFICATIONS. ROUTE CABLES ABOVE ACCESSIBLE CEILINGS. PROVIDE J-HOOKS ABOVE WORK FOR CEILING CABLE ROUTING.
 3. GENERAL: FIRE ALARM SYSTEM DEVICES SHOWN ON DRAWINGS WITH NO CABLEING FOR CLARITY. FIRE ALARM SYSTEM CABLEING SHALL BE ROUTED IN DEDICATED CONDUIT SYSTEMS PER SPECIFICATIONS.
 4. INTERFACE HVAC FANS TO FIRE ALARM SYSTEM. HVAC FANS SHALL DE-ENERGIZE IN FIRE ALARM MODE.
 5. MAKE CONNECTIONS TO FLOW CONTROL AND TAMPER SWITCH.
 6. MAKE CONNECTIONS TO JOCKEY PUMP CONTROLLER.
 7. MAKE CONNECTIONS TO SPRINKLER RISER TAMPER SWITCHES.
 8. MAKE CONNECTIONS TO FIRE PUMP CONTROLLER.
 9. MAKE CONNECTIONS TO FIRE PUMP AND TAMPER SWITCHES.

Order Plans @

LOW VOLTAGE FLOOR PLAN
SCALE: 3/32" = 1'-0"

ISSUANCES	
DATE	Description
KEY PLAN	
 <p>ANDREWS, HARMON & POWELL, INC. 255 Charter Lane Suite 100 Macon, Georgia 31210 Macon, GA 31210 Fax 478 405-8210 WWW.AHPENGINEERS.COM</p>	
	
	
<p>Manley Spangler Smith Architects A Professional Corporation</p> <p>625 East Taylor St P.O. Box 880 Griffin, Georgia 30224 Office 770.227.5473 Fax 770.228.3442</p>	
<p>PROJECT: HENRY COUNTY SCHOOLS - DISTRIBUTION CENTER</p> <p>CLIENT: HENRY COUNTY BOARD OF EDUCATION</p> <p>SHEET TITLE: LOW VOLTAGE FLOOR PLAN</p>	
PROJECT NUMBER:	201827
DATE:	08.13.20
SCALE:	AS SHOWN
DRAWN BY:	SMN
CHECKED BY:	NHO
SHEET NO.:	E3.21