

Branch Panel: IC-1. Location: Supply From: Mounting: Recessed Enclosure: NEMA 1. Volts: 120/240 Single Phases: 1 Wires: 3. A.I.C. Rating: 10K Mains Type: MCB Mains Rating: 150 A MCB Rating: 150 A. Notes: ALL BREAKERS AFI TYPE. Table with columns: CKT, Circuit Description, Trip, Poles, A, B, Poles, Trip, Circuit Description, CKT.


Branch Panel: IC-2. Location: Supply From: Mounting: Recessed Enclosure: NEMA 1. Volts: 120/240 Single Phases: 1 Wires: 3. A.I.C. Rating: 10K Mains Type: MCB Mains Rating: 150 A MCB Rating: 150 A. Notes: ALL BREAKERS AFI TYPE. Table with columns: CKT, Circuit Description, Trip, Poles, A, B, Poles, Trip, Circuit Description, CKT.

Branch Panel: IC-3. Location: Supply From: Mounting: Recessed Enclosure: NEMA 1. Volts: 120/240 Single Phases: 1 Wires: 3. A.I.C. Rating: 10K Mains Type: MCB Mains Rating: 150 A MCB Rating: 150 A. Notes: ALL BREAKERS AFI TYPE. Table with columns: CKT, Circuit Description, Trip, Poles, A, B, Poles, Trip, Circuit Description, CKT.

Branch Panel: IC-4. Location: Supply From: Mounting: Recessed Enclosure: NEMA 1. Volts: 120/240 Single Phases: 1 Wires: 3. A.I.C. Rating: 10K Mains Type: MCB Mains Rating: 150 A MCB Rating: 150 A. Notes: ALL BREAKERS AFI TYPE. Table with columns: CKT, Circuit Description, Trip, Poles, A, B, Poles, Trip, Circuit Description, CKT.

DRAWING NOTES

- A. PLEASE REFER TO SHEET E006 FOR PROJECT NOTES, LEGEND, AND ABBREVIATIONS.
B. PANEL SCHEDULES ARE REPRESENTATIVE OF THE TYPE OF UNIT. INDIVIDUAL UNITS MAY VARY SLIGHTLY.
C. PANEL DOORS SHALL BE FACTORY FINISH WHITE WITH FACTORY FINISH WHITE SCREWS AND WHITE PLASTIC LATCH.
D. PANEL DIRECTORY SHALL BE NEATLY PRINTED OR TYPED ON EACH PANEL DOOR.
E. THE "HOUSE" PANELS COVER UP TO THREE BUILDINGS AND MAY CONTAIN THE CIRCUITS FOR THE FOLLOWING: GFCI RECEPTACLES AT ALL HEAT RUMPS, FRONT PORCH AND BREEZEWAY LIGHTS, POWER FOR SECURITY CAMERAS, POWER FOR AUTO GATE OPENER, POWER FOR MAIN GATE AND ACCESS CONTROL, SPRINKLER ROOM VALVES, SPRINKLER ROOM WALL HEATER, SPRINKLER ROOM LIGHT AND RECEPTACLES, SPRINKLER ROOM ACCESS CONTROL, IRRIGATION CONTROLLER, SIGN/MONUMENT LIGHT, ETC.
F. REFER TO SHEET E006 FOR UNIT PANEL CALCULATIONS.



Architecture Planning Interiors Research
50 South B.B. King Boulevard
Memphis, Tennessee 38103
Telephone 901 521 1440
Fax 901 525 2760
E-mail info@lrk.com

Client:
McCormack Baron Salazar


720 Olive St, Suite 2500
St. Louis, MO 63101

Issues and Revisions

Table with columns: #, Date, Issued / Revised.
1 03/16/2020 50% CONSTRUCTION DOCUMENTS
2 05/18/2020 80% CONSTRUCTION DOCUMENTS
3 07/13/2020 PERMIT

- BUILDING ADDRESSES
TYPE E/E 442, 444, 446, 448 BATHURST LANE
TYPE H/A 324, 290, 230, 330 ISHAMEL PLACE
TYPE H/B 313, 440 VANCE AVE
TYPE I/C 313 S DANNY THOMAS BLVD
TYPE L/B 365, 431 VANCE AVE
TYPE L/A 337 ISHAMEL PLACE
TYPE M/A 420, 351 FOOTE LANE
420 S DANNY THOMAS BLVD
402, 428 FOOTE LANE

©2020 LRK Inc.
Drawings, written material, and design concepts shall not be used or reproduced in whole or part in any form or format without prior written consent of LRK Inc. Do not scale drawings. Use given dimensions only. If not shown, verify correct dimensions with the Architect. Contractor shall check and verify all dimensions and conditions at job.



LRK Project 01.15100.02
Number:

Project Name:
South City CNI
Phase 4
Memphis TN

Drawing Name:
ELECTRICAL PANEL
SCHEDULES - BUILDING
I-C

Drawn By: Author
Checked By: Checker

IC-E300

Order Plans @ WWW.LDILine.com