



1 DUMPSTER ENCLOSURE - FOUNDATION PLAN 3/8" = 1'-0"

SECTION 1
3/4" = 1'-0"

SECTION 2
3/4" = 1'-0"

FOUNDATION NOTES:

- ELEV. ±0'-0" IS REFERENCE ONLY. SEE CIVIL FOR TRUE NGVD ELEVATION.
- C.J. INDICATES CONTROL JOINT SEE S4.1 FOR DETAILS.
- T.E. INDICATES THICKENED EDGE SEE S4.1 FOR DETAILS.
- VERIFY SLOPES AND STEPS WITH ARCHT. PRIOR TO CONSTRUCTION. SEE TYPICAL STEP DETAIL ON S4.1.
- ALL MASONRY WALLS ARE MW-1 U.N.O., SEE SCHEDULE ON THIS SHEET.
- MF-# DENOTES MONOLITHIC CONCRETE FOOTING, SEE SCHEDULE ON THIS SHEET.
- INDICATES WALL CONTROL JOINT, SEE DETAIL ON S4.1.
- FLOOR CONSTRUCTION: 6" THICK CONCRETE SLAB ON GRADE WITH #5 AT 12" O.C. E.W. MID-DEPTH, AND 8" THICK CONCRETE SLAB REINF. W/ #5 AT 12" O.C. E.W. END-DEPTH.
- FOOTING EXCAVATIONS SHALL BE FREE OF WATER BEFORE PLACING CONCRETE.
- CONTRACTOR TO COORDINATE ALL FLOOR DRAINS AND PLUMBING PRIOR TO PLACING CONCRETE FOOTINGS OR SLAB.

STRUCTURAL NOTES

CODES AND STANDARDS

- WIND LOADS AS PER:
 - FLORIDA BUILDING CODE 2017 EDITION, FOR A 139 MPH(ULT)/108 MPH(ASD) EXPOSURE C, +/-0.18 INTERNAL PRESSURE COEFFICIENT, 1.0 IMPORTANCE FACTOR, AND RISK CATEGORY II.
 - THIS BUILDING IS DESIGNED AS AN ENCLOSED BUILDING.
- THE PROJECT WAS DESIGNED IN ACCORDANCE WITH THE:
 - FLORIDA BUILDING CODE 2017 EDITION.
 - BUILDING CODE REQUIREMENTS FOR REINFORCED CONCRETE (ACI 318/ 2014 EDITION).
 - MANUAL OF STANDARD PRACTICE FOR DETAILING REINFORCED CONCRETE STRUCTURES (ACI 315/ LATEST EDITION).
 - MANUAL OF STANDARD PRACTICE FOR WELDING REINFORCING STEEL, INSERTS & CONNECTIONS IN REINFORCED CONCRETE CONSTRUCTION. AWS. D1.4/ 1998 EDITION.
- FLOOR LIVE LOAD: 250 PSF.

FOUNDATION

- ALL SITE PREPARATION AND EXCAVATION WORK IS TO BE PERFORMED IN STRICT ACCORDANCE WITH THE:
 - GEOTECHNICAL REPORT PREPARED BY ATC GROUP SERVICES, LLC DATED DECEMBER 9, 2019(PROJECT No. Z465710002).
- THE BUILDING SITE SHOULD BE EXCAVATED TO THE DEPTH AND EXTENT INDICATED IN THE SOILS REPORT. ALL SUBGRADES SHALL BE APPROVED IN WRITING BY THE SOILS ENGINEER PRIOR TO BACKFILLING.
- BOTTOM OF FOOTINGS TO BEAR ON SOIL CAPABLE OF SAFELY SUPPORTING 2500 PSF.

MASONRY WALL SCHEDULE		
MARK	THICKNESS	REINFORCING
MW-1	8" CMU	#5 AT 40" O.C.

FOOTING SCHEDULE		
MARK	SIZE	REINFORCING
MF36.1B	36" X 36" X 48" CON.	#5 CONT. BOTTOM

MASONRY WALL NOTES:

- WALL SEGMENTS SHALL BE REINFORCED WITH 9 GA. GALVANIZED LATERAL REINFORCING @ 18" O.C. HORIZ. EXTEND REINFORCING 6" INTO POURED ELEMENTS AND AROUND ENCASED STEEL.
- ADJACENT TO ANY EXTERIOR/INTERIOR WALL OPENING, PLACE 1 #5 VERTICAL IN CELL GROUTED SOLID, FULL HEIGHT.
- ALL MASONRY REINFORCED CELLS SHALL BE FILLED WITH 3000 PSI GROUT MIX.

Order Plans @ www.LDILine.com

www.LDILine.com

COPYRIGHT © 2020 INTERPLAN, LLC. RESERVES COPYRIGHT & OTHER RIGHTS RESPECTING THESE DOCUMENTS TO THE ORIGINAL SITE OF PROPOSED WORK. REPRODUCTIONS, CHANGES OR ASSIGNMENTS ARE PROHIBITED.