


1 ROOFTOP POWER PLAN
SCALE: 1/4" = 1'-0"

KEYED NOTE - ROOF:

- 1 STUB-UP CONDUIT TO ROOF CURB AND PROVIDE SEAL TIGHT CONNECTION TO DISCONNECT WITH SUFFICIENT SLACK TO ALLOW REMOVAL OF FAN FOR SERVICING.
- 2 DOWN TO ICE MACHINE.
- 3 SEE ELECTRICAL RISER SHEET E-3 FOR ELECTRICAL REQUIREMENTS TO MECHANICAL EQUIPMENT.
- 4 120V/1Ø WATER PROOF, GFCI RECEPTACLE BY ELECTRICAL CONTRACTOR.
- 5 LOCATION OF JUNCTION BOXES FOR SIGNS TO BE COORDINATED WITH SIGN MANUFACTURER/INSTALLER.
- 6 STUB FUTURE USE RTU CIRCUIT
- 7 STUB FUTURE USE FAN CIRCUIT



ROOF RECEPTACLE MOUNTING
SCALE: NONE

Order Plans @ WWW.LDILine.com

OWNERS:
ESTEL DEVELOPMENT LLC
763 NE 193RD TERRACE
MIAMI, FL 33179

DATE	NO.	DATE	SCALE	REVISION
8/14/20				

GERSHEN ASSOCIATES, P.A.
Architecture / Planning
Construction Consulting
9788 SOUTH DIXIE HIGHWAY/ MANI, FLORIDA 33156
(305) 661-7122
REGISTRATION NO. AA 0002786

SEAL
PAUL B. GUERRERO
STATE OF FLORIDA
REGISTERED ARCHITECT
#11057

PROJECT LOCATION
ESTEL PLAZA
2890-2894 WEST BROWARD BLVD
FT LAUDERDALE, FLORIDA 33312
SHEET TITLE
ROOF POWER PLAN

GUERRERO/GONZALEZ ENGINEERS, INC.
Michael C. Guerrero, P.E.
Mechanical Eng. Lic. #15235
Rafael L. Gonzalez, P.E.
Electrical Eng. Lic. #11057
780 Tamiami Canal Road
Miami, Florida 33144-2553
Tel.(305) 262-3944, Fax (305) 262-8211
CA NO. 0007612

SHEET NO.
E-1.1
JOB NO.
2020-002