

**Panel: P5**  
 Location: Elec. 150      Volts: 120/208 Wye      A.I.C. Rating: Series Rated at 65K.  
 Supply From: P4      Phases: 3      Frame: 225 A  
 Mounting: Surface      Wires: 4      Main: 225 A MLO  
 Enclosure: Type 1      Provide Neutral Bar      Provide Ground Bar

Notes:  
 Provide typewritten panel schedules with plastic cover. Circuit names to be exactly as listed here. Provide engraved nameplate on face of panel.

CODE	CK T	Circuit Description	Trip	PLS	A	B	C	PLS	Trip	Circuit Description	CK T	CODE	
1		WHZ	30	2	1800	1800			2	30	WHZ	2	
3						1800	1800					4	
5		Panoramic X-Ray Machine	20	2	1040	1500			1	20	Gen Battery Charger	6	
7							1040	1200	1	20	Gen Jacket Warmer	8	
9		Panoramic X-Ray Machine	20	1		1200	1500		2	30		10	
11		Rcps - Imaging	20	1				540	0	1	20	Spare	12
13		Spare	20	1	0	0			1	20	Spare	14	
15		Rcps - Exam Rms	20	1				1440	0	1	20	Spare	16
17		Rcps - Exam Rms	20	1				1440	0	1	20	Spare	18
19		Dental Exam 105	20	1	180	360			1	20	Dental Exam 142	20	
21		Dental Exam 105 Xray Unit	20	1			1200	1200	1	20	Dental Exam 142 Xray Unit	22	
23		Dental Exam 105 Chair	20	1				1200	1200	1	20	Dental Exam 142 Chair	24
25		Dental Exam 106	20	1	180	360			1	20	Dental Exam 144	26	
27		Dental Exam 106 Xray Unit	20	1			1200	1200	1	20	Dental Exam 144 Xray Unit	28	
29		Dental Exam 106 Chair	20	1				1200	1200	1	20	Dental Exam 144 Chair	30
31		Dental Exam 107	20	1	360	180			1	20	Dental Exam 146	32	
33		Dental Exam 107 Xray Unit	20	1			1200	1200	1	20	Dental Exam 146 Xray Unit	34	
35		Dental Exam 107 Chair	20	1				1200	1200	1	20	Dental Exam 146 Chair	36
37		Dental Exam 108	20	1	360	180			1	20	Dental Exam 148	38	
39		Dental Exam 108 Xray Unit	20	1			1200	1200	1	20	Dental Exam 148 Xray Unit	40	
41		Dental Exam 108 Chair	20	1				1200	1200	1	20	Dental Exam 148 Chair	42
Total Connected Load (VA):					7882 VA	16760 VA	13820 VA						
Total Connected Load (A):					66 A	147 A	123 A						
Legend:													
PANEL CONNECTED LOAD TOTALS													
Total Connected Load:					38265 VA		106 A						

Notes:

**Panel: H**  
 Location: Elec. 156      Volts: 120/208 Wye      A.I.C. Rating: Series Rated at 65K.  
 Supply From: M      Phases: 3      Frame: 600 A  
 Mounting: Surface      Wires: 4      Main: 600 A MLO  
 Enclosure: Type 1      Provide Neutral Bar      Provide Ground Bar

Notes:  
 Provide typewritten panel schedules with plastic cover. Circuit names to be exactly as listed here. Provide engraved nameplate on face of panel.


CODE	CK T	Circuit Description	Trip	PLS	A	B	C	PLS	Trip	Circuit Description	CK T	CODE	
1		WH1	40	2	3000	1800			2	30	WH2	2	
3						3000	1800					4	
5		WH2	30	2	1800	1800			1	20	WH2	6	
7							1800	1800		2	30	WH2	8
9		EW-1	30	2		1500	583		2	20	DCU-1	10	
11							1500	583		2	20	DCU-1	12
13		AHU-1	70	2	4243	2163			2	50	HP-1	14	
15						4243	2163			2	50	HP-1	16
17		AHU-2	70	2	4243	2163			2	50	HP-2	18	
19							4243	2163		2	50	HP-2	20
21		AHU-4	50	2		3162	1415		2	30	HP-4	22	
23							3162	1415		2	30	HP-4	24
25		AHU-5	50	2	3162	1415			2	30	HP-5	26	
27						3162	1415			2	30	HP-5	28
29		AHU-6	30	2	2080	1000			2	30	HP-6	30	
31							2080	1000		2	30	HP-6	32
33		AHU-7	125	2		7987	2663		2	60	HP-7	34	
35							7987	2663		2	60	HP-7	36
37		AHU-3	125	3	9482	3170			3	50	HP-3	38	
39						9482	3170			3	50	HP-3	40
41							9482	3170				42	
43		Space Only	--	--	0	0			--	--	Space Only	44	
45		Space Only	--	--	0	0			--	--	Space Only	46	
47		Space Only	--	--	0	0			--	--	Space Only	48	
49		Panel "L"	125	3	4229	5790			3	125	Panel "P1"	50	
51						3626	5507					52	
53							3558	8886				54	
Total Connected Load (VA):					50494 VA	54369 VA	54735 VA						
Total Connected Load (A):					421 A	458 A	461 A						
Legend:													
PANEL CONNECTED LOAD TOTALS													
Total Connected Load:					159585 VA		443 A						

Notes:


Order Plans @ www.LDILine.com

**PANEL SCHEDULE CODE LEGEND**

F - PROVIDE RED PAD LOCK DEVICE SIMILAR TO SIEMENS #ECP1D1R.  
 G - PROVIDE GFCI RATED BREAKER.  
 K - PROVIDE LOCKING DEVICE ON BREAKER.  
 L - RUN CIRCUIT THRU LIGHTING CONTACTOR.



**GEORGIA MOUNTAINS HEALTH SERVICES, INC.**  
 HIGHLAND CROSSING SOUTH TRACT G  
 EAST ELLIJAY, GEORGIA



ISSUE DATES  
 INITIAL ISSUE 09-04-2020

JOB NO. 19-068 | DWN JLH | CKD GWE

**E6.2**

PANEL SCHEDULES



310 Dodds Ave.  
 P.O. Box 3689  
 Chattanooga, Tennessee 37404  
 PH: (423)698-6675  
 Consulting Engineers MAA #: 20109