



GENERAL PLAN NOTES

1. ALL POLE BASES ARE TO BE LOCATED 18" MINIMUM OFF BACK FACE OF CURB TO EDGE OF POLE BASE. THOSE LOCATED IN AN ISLAND ARE TO BE CENTERED IN ISLAND.
2. ALL POLE MOUNTED LIGHT FIXTURES ARE TO BE INSTALLED AT 25' ABOVE FINISHED GRADE. PROVIDE DIFFERENT POLE LENGTHS FOR POLES LOCATED IN PAVED AND NON PAVED AREAS.

SITE LIGHTING FIXTURE SCHEDULE

TYPE	DESCRIPTION
SA	SEE SHEET ES2.2 FOR FIXTURE DESCRIPTION.
SB	SEE SHEET ES2.2 FOR FIXTURE DESCRIPTION.


ELECTRICAL KEYED NOTES

1. RUN CIRCUIT THRU LIGHTING CONTROL CONTACTOR TO BE CONTROLLED BY TIMECLOCK & PHOTOCELL ASSEMBLY.

ARTECH
ARCHITECTURE & INTERIORS
 ARTECH DESIGN GROUP, INC.
 2010 COMBAT STREET, IN.
 423.265.1313

GEORGIA MOUNTAINS HEALTH SERVICES, INC.
 HIGHLAND CROSSING SOUTH TRACT G
 EAST ELLIJAY, GEORGIA


Order Plans @



ISSUE DATES

INITIAL	DATE
1.	09-04-2020
2.	
3.	
4.	
5.	
6.	

1 ELECTRICAL SITE LIGHTING PLAN
 SCALE: 1" = 30'-0"



MA & A March Adams & Associates
 Consulting Engineers
 310 Dodds Ave.
 P.O. Box 3689
 Chattanooga, Tennessee 37404
 PH: (423)698-6675
 MAA #: 20109

JOB NO. 19-068 | D'WN JLH | CK'D TLM
ES2.1
 ELEC SITE LIGHTING PLAN