



MARK	LENGTH	WIDTH	HEIGHT	USE	COUNT
P1	1'-8"	1'-8"	1'-8"	STRUCTURAL	2
P2	3'-0"	3'-0"	1'-8"	STRUCTURAL	3
P3	3'-0"	3'-5"	1'-4"	NON-STRUCTURAL	1
P4	2'-3 1/2"	3'-5"	1'-4"	NON-STRUCTURAL	1

MARK	LENGTH	WIDTH	FOUNDATION THICKNESS	TOP REINF.	BOTTOM REINF.
F4	4'-0"	4'-0"	1'-4"	#6 @ 12" OC EW	#6 @ 12" OC EW
F5	8'-0"	8'-0"	1'-4"	#6 @ 12" OC EW	#6 @ 12" OC EW
F5(1)	2'-12"	13'-0"	1'-4"	#6 @ 12" OC EW	#6 @ 12" OC EW
F6	8'-0"	6'-0"	1'-4"	#6 @ 12" OC EW	#6 @ 12" OC EW
F7	7'-0"	7'-0"	2'-0"	#6 @ 12" OC EW	#6 @ 12" OC EW
F7(2)	7'-0"	22'-0"	1'-5"	#6 @ 12" OC EW	#6 @ 12" OC EW
F7(2)	7'-0"	22'-0"	1'-5"	#6 @ 12" OC EW	#6 @ 12" OC EW
F8	8'-0"	8'-0"	2'-0"	#6 @ 12" OC EW	#6 @ 12" OC EW

- GENERAL NOTES:**
- EXTERIOR FOOTINGS HEREIN ARE RELATIVE TO FINISHED FLOOR ELEVATION OF 3'-0" THE TOP OF ALL EXTERIOR FOOTINGS SHALL BE THIS -1'-4" TYP. UOM.
 - SEE ARCHITECTURAL DRAWINGS FOR LOCATIONS AND CONSTRUCTION OF NON-LOAD BEARING MIT, STUD WALLS, FIXTURES, AND OTHER ITEMS NOT PRESENTED HEREIN.
 - CONC. CURING COMPOUNDS AND SEALERS ARE NOT PERMITTED FOR THE BUILDING SLAB.
 - 4" CONC. SLAB W/ 4000 PSI CONC. W/ 8X8X2 @ 12" MIN. OVER 15 MIL MIN. VAPOR BARRIER ON THERMITE TREATED COMPACTED SOIL IN ACCORDANCE W/ GEOTECHNICAL REQUIREMENTS, TYP. UOM. PLACE REINF. 1/3 OF THE DEPTH FROM THE TOP OF SLAB OR 1 1/2" MIN.
 - 8" CONC. SLAB W/ 4000 PSI CONC. W/ 8X8X2 @ 12" MIN. OVER 15 MIL MIN. VAPOR BARRIER ON THERMITE TREATED COMPACTED SOIL IN ACCORDANCE W/ GEOTECHNICAL REQUIREMENTS, TYP. UOM. PLACE REINF. 1/3 OF THE DEPTH FROM THE TOP OF SLAB OR 1 1/2" MIN.
 - SEE ARCHITECTURAL, PLUMBING DRAWINGS FOR DRAIN SLOPES, ELEVATIONS AND SLAB RECESSORS. OPENING RE-ENTRANT CORNER, TYP. PROVIDE (3) #4 X 4'-0" LONG BARS AT MID-HEIGHT OF SLAB.
 - ENCASE ALL BASE PLATES WITH 3000 PSI CONCRETE OR GROUT, MIN. 3" THICK ALL AROUND AND ON TOP OF W 3" CLR TO TOP OF BOLTS.
 - PLACEMENT OF CONC. SLAB ON GRADE TO MEET THE FOLLOWING CRITERIA: LEVEL WITHIN ± 1/4" PER 50'-0" AND PARALLEL TO THE BUILDING WALLS AND PARALLEL / PERPENDICULAR TO EACH OTHER, UNLESS INDICATED OTHERWISE.
 - SEE TYPICAL CONTROL JOINT DETAIL ON DRAWING S6. ALL JOINTS MUST BE STRAIGHT TO WITHIN ± 1/4" PER 50'-0" AND PARALLEL TO THE BUILDING WALLS AND PARALLEL / PERPENDICULAR TO EACH OTHER, UNLESS INDICATED OTHERWISE.
 - 8" CONC. SLAB W/ 4000 PSI CONC. W/ #6 BARS @ 12" OC EW CENTERED IN SLAB OVER 15 MIL MIN. VAPOR BARRIER ON THERMITE TREATED COMPACTED SOIL IN ACCORDANCE W/ GEOTECHNICAL REQUIREMENTS AT TRASH COMPOUND SLAB.
 - 8" CONC. SLAB W/ 4000 PSI CONC. W/ #6 BARS @ 12" OC EW CENTERED IN SLAB OVER 15 MIL MIN. VAPOR BARRIER ON THERMITE TREATED COMPACTED SOIL IN ACCORDANCE W/ GEOTECHNICAL REQUIREMENTS AT TRASH COMPOUND SLAB.

Order Plans @ WWW.LDILine.com

CLIENT NAME
WAWA
280 WEST BALTIMORE PIKE
WAWA, PENNSYLVANIA 19083

PROJECT NAME
WAWA F85L 2019.01 STORE #5351 - CMM
1014 EDGEWOOD AVE.
JACKSONVILLE, FL 32254

No.	Description	Date
1	PRELIMINARY	08/09/2020
2	REVISED	08/10/2020
3	REVISED	08/10/2020
4	REVISED	08/10/2020
5	REVISED	08/10/2020

PROJECT NO.
2175780

DATE
08/09/2020

DRAWN BY
WAWA

CHECKED BY
WAWA