

Order Plans @ www.LDILine.com

GENERAL NOTES

A. PROVIDE ALL CODE REQUIRED AND MANUFACTURER RECOMMENDED CLEARANCES FOR ALL EQUIPMENT.

KEYNOTES

NUMBER	NOTES
1	MAINTAIN 10' - 0" MINIMUM FROM ALL PARAPET WALLS AND EXHAUST FANS.
2	MAINTAIN 10' - 0" MINIMUM SEPARATION FROM ALL AIR INTAKE OPENINGS.
3	COORDINATE ROOF PITCH WITH FAN CURB BEFORE PROCUREMENT.

ROOF PLAN - HVAC 1/8" = 1'-0" 1

VOLT AIR
 6005 Benjamin Road, Suite A
 Tampa, Florida 33634
 Tel: 888.881.9713
 www.voltaire.com
 COA #27156
 Project #0118040
 Engineer of Record:
 DANNY CELIS, P.E. #70842

FLEISCHMANGARCIA
 ARCHITECTURE & PLANNING : INTERIORS
 251 HYDE PARK AVENUE, SUITE 800
 TAMPA, FLORIDA 33606
 PHONE (813) 251-1884
 FAX (813) 251-1884
 www.fleischmangarcia.com

HILLSBOROUGH COUNTY
 NEW TAMPA PERFORMING ARTS
 CENTER
 8550 HUNTERS VILLAGE RD.
 TAMPA FL, 33647

THIS DESIGN AND DRAWING IS THE SOLE PROPERTY OF FLEISCHMANGARCIA. NO PART OF THIS WORK MAY BE REPRODUCED WITHOUT PRIOR WRITTEN PERMISSION FROM FLEISCHMANGARCIA.

CERTIFY TO THE BEST OF MY KNOWLEDGE THAT THESE DRAWINGS COMPLY WITH ALL RELEVANT BUILDING CODES.

PERMIT SET
 05/06/2020

FGA PROJECT NUMBER
 19048

ISSUE DATE
 04-15-2020

NO.	DATE	REVISIONS	NOTES

SHEET NAME

ROOF PLAN - HVAC

SHEET NUMBER
M2.3