



Order Plans @ www.LDILine.com

GENERAL NOTES

KEYNOTES

- | NUMBER | NOTES |
|--------|---|
| 1 | PROVIDE, ROUTE AND SIZE REFRIGERANT PIPING PER MANUFACTURER'S INSTALLATION INSTRUCTIONS FOR CONDENSING UNIT LOCATED OUTSIDE AND RESPECTIVE INDOOR UNIT. PROVIDE LONG RADIUS ELBOWS AND ALL REFRIGERANT PIPING SPECIALTIES PER MANUFACTURER'S REQUIREMENTS/RECOMMENDATIONS. ROUTE 3/4" CONDENSATE PIPING TO STORM WATER PIPING. PROVIDE CHECK VALVE UPSTREAM OF CONNECTION. REFER TO PLUMBING DRAWINGS. ROUTE INSULATED CONDENSATE DRAIN ABOVE CEILING. REFER TO PLUMBING DRAWING. |
| 2 | INSULATE PIPING AND PROVIDE ALUMINUM JACKETING. PROVIDE WALL COVER INLET CAP. MAKE OF UV RESISTANT PVC, WHITE COLOR. |
| 3 | CONNECT THERMOSTAT TO VAV-2.2. SEE SHEET M2.2 FOR VAV BOX LOCATION. |
| 4 | CONNECT THERMOSTAT TO VAV-2.3. SEE SHEET M2.2 FOR VAV BOX LOCATION. |
| 5 | CONNECT THERMOSTAT TO VAV-1.8. SEE SHEET M2.2 FOR VAV BOX LOCATION. |
| 6 | CONNECT THERMOSTAT TO VAV-2.1. SEE SHEET M2.2 FOR VAV BOX LOCATION. |
| 7 | FUTURE 3" CHILLED WATER SUPPLY AND RETURN TAPS AND ISOLATION VALVES. |
| 8 | 3" CHILLED WATER SUPPLY AND RETURN UP TO AND FROM SECOND FLOOR. |

FIRST FLOOR PLAN - PIPING 1
1/8" = 1'-0"

VOLT AIR
 6005 Benjamin Road, Suite A
 Tampa, Florida 33634
 Tel: 888.881.6713
 www.voltaire.com
 Project #1: 18040
 COA: #27156
 Engineer of Record:
 DANNY CELIS, P.E. #70642

FLEISCHMANGARCIA
 ARCHITECTURE & INTERIORS
 251 HUNTERS VILLAGE AVENUE, SUITE 300
 TAMPA, FLORIDA 33647
 PHONE (772) 726-8800
 FAX (772) 726-8800
 www.fleischmangarcia.com

**HILLSBOROUGH COUNTY
 NEW TAMPA PERFORMING ARTS
 CENTER**
 8550 HUNTERS VILLAGE RD.
 TAMPA FL, 33647

THIS DESIGN AND DRAWING IS THE SOLE PROPERTY OF FLEISCHMANGARCIA. NO PART OF THIS WORK MAY BE REPRODUCED WITHOUT PRIOR WRITTEN PERMISSION FROM FLEISCHMANGARCIA.

CERTIFY TO THE BEST OF MY KNOWLEDGE THAT THESE DRAWINGS COMPLY WITH ALL RELEVANT BUILDING CODES

PERMIT SET
 05/06/2020

FGA PROJECT NUMBER
 19048
 ISSUE DATE
 04-15-2020

NO.	DATE	NOTES

SHEET NAME
 FIRST FLOOR PLAN - PIPING

SHEET NUMBER
 M3.1