



Order Plans @ www.LDILine.com

www.LDILine.com




WATER TREATMENT PIPING DETAIL A

- KEYED NOTES:
- 18" ACCESS DOOR (TYP)
 - SUPPLY FAN
 - EXTERNAL JUNCTION BOX
 - 15" ACCESS DOOR (TYP)
 - 10" ACCESS DOOR (TYP)
 - OUTSIDE AIR INTAKE
 - 15" ACCESS DOOR (TYP)
 - 15" ACCESS DOOR (TYP)
 - RETURN AIR INTAKE
 - SUPPLY AIR DISCHARGE
 - OUTSIDE AIR COOLING COIL
 - RETURN AIR COOLING COIL
 - MERV 14 FILTER
 - MERV 14 FILTER
 - MERV 8 FILTER




AHU - 1 DETAIL B

- KEYED NOTES:
- 17" ACCESS DOOR (TYP)
 - SUPPLY FANS
 - EXTERNAL JUNCTION BOX
 - 15" ACCESS DOOR (TYP)
 - 10" ACCESS DOOR (TYP)
 - OUTSIDE AIR INTAKE
 - 10" ACCESS DOOR (TYP)
 - 27" ACCESS DOOR (TYP)
 - RETURN AIR INTAKE PLENUM
 - SUPPLY AIR DISCHARGE
 - OUTSIDE AIR COOLING COIL
 - RETURN AIR COOLING COIL
 - MERV 14 FILTER
 - MERV 14 FILTER
 - MERV 8 FILTER



AHU - 3 DETAIL D

- KEYED NOTES:
- 17" ACCESS DOOR (TYP)
 - SUPPLY FANS
 - EXTERNAL JUNCTION BOX
 - 15" ACCESS DOOR (TYP)
 - 10" ACCESS DOOR (TYP)
 - OUTSIDE AIR INTAKE
 - 10" ACCESS DOOR (TYP)
 - 27" ACCESS DOOR (TYP)
 - RETURN AIR INTAKE PLENUM
 - SUPPLY AIR DISCHARGE
 - OUTSIDE AIR COOLING COIL
 - RETURN AIR COOLING COIL
 - MERV 14 FILTER
 - MERV 14 FILTER
 - MERV 8 FILTER



AHU - 2 DETAIL C

VOLT AIR
 THE FIRM HAS BEEN ELECTRICALLY
 SELF
 6005 Benjamin Road, Suite A
 Tampa, Florida 33634
 Tel: 888.881.9713
 www.voltaire.com
 Project # 118940
 COA # 27158
 Engineer of Record:
 DANNY CELIS, P.E. #70642

FLEISCHMANN
 ARCHITECTS
 251 HUNTERS VILLAGE RD.
 TAMPA, FL 33647
 PHONE (813) 755-3600
 FAX (813) 755-1984
 www.fleischmannarch.com

**HILLSBOROUGH COUNTY
 NEW TAMPA PERFORMING ARTS
 CENTER**
 8550 HUNTERS VILLAGE RD.
 TAMPA FL, 33647

THIS DESIGN AND DRAWING IS THE SOLE
 PROPERTY OF FLEISCHMANN ARCHITECTS. NO
 PART OF THIS WORK MAY BE
 REPRODUCED WITHOUT PRIOR WRITTEN
 PERMISSION FROM FLEISCHMANN ARCHITECTS.

CERTIFY TO THE BEST OF MY
 KNOWLEDGE THAT THESE DRAWINGS
 COMPLY WITH ALL RELEVANT BUILDING
 CODES

PERMIT SET

05/06/2020

FGA PROJECT NUMBER
 19048

ISSUE DATE
 04-15-2020

NO	DATE	NOTES

SHEET NAME

DETAILS - HVAC

SHEET NUMBER
M9.3