

REFER TO THEATRE CONSULTANT DRAWINGS FOR SCOPE OF WORK DILINEATION AND ADDITIONAL ELECTRICAL REQUIREMENTS AND INFORMATION

**GENERAL NOTES**

- A. ELECTRICAL CONTRACTOR SHALL REFER TO THE ELECTRICAL SPECIFICATIONS FOR ADDITIONAL DESIGN STANDARDS. THE ELECTRICAL SPECIFICATIONS ARE A BINDING PART OF THE CONSTRUCTION DOCUMENTS.
- B. ALL GANG BOXES SHALL BE MINIMUM 3" DEEP U.O.N.
- C. ALL WIRE SHALL BE COPPER STRANDED.
- D. RECEPTACLE COVER PLATES IN CONCESSION, AUDITORIUM, VESTIBULES, AND STAGE SHALL BE BLACK. ALL REMAINING RECEPTACLE COVER PLATES SHALL BE WHITE.
- E. ELECTRICAL CONTRACTOR IS RESPONSIBLE FOR INSTALLATION OF ALL BOXES. BOXES TYING INTO LIGHTING SYSTEM PANEL "1LPLS" ARE FURNISHED BY DIV 11. REFER TO TP SERIES DRAWINGS FOR ADDITIONAL SCOPE INFORMATION.
- F. ALL USBUS-C RECEPTACLES IN THE DRESSING ROOMS SHALL BE INSTALLED AT 32" AFF. COORDINATE WITH MILLWORK CONTRACTOR.

**VOLT AIR**  
 THESE ITEMS HAVE BEEN ELECTRICALLY CHECKED BY GERALD A. CRIVONICH, P.E.  
 6005 Benjamin Road, Suite A  
 Tampa, Florida 33634  
 Tel: 888.881.9713  
 www.voltair.com  
 COA #27156 Project #0118940  
 Engineer of Record:  
 GERALD A. CRIVONICH, P.E. #42927

**FLEISCHMANGARCIA**  
 ARCHITECTURE & INTERIORS  
 3815 HOBBS AVENUE, SUITE 300  
 TAMPA, FLORIDA 33610  
 PHONE (813) 251-1884  
 FAX (813) 251-1884  
 www.fleischmangarcia.com

**HILLSBOROUGH COUNTY  
 NEW TAMPA PERFORMING ARTS  
 CENTER**  
 8550 HUNTERS VILLAGE RD.  
 TAMPA, FL 33647

**KEYNOTES**

- | NUMBER | NOTES  |
|--------|--|
| 1      | PATHWAY LOCATIONS FOR CABLE PASS THROUGHS - PROVIDE 4"X4" THROUGH WALL (PRODUCT PART # FT4SD) REFER TO DIV 11 TP SERIES DRAWINGS FOR ADDITIONAL INFORMATION.   |
| 2      | LOW VOLTAGE BACKBOX LOCATION FOR TERMINATION OF PERFORMANCE ETHERNET OR SUPPLEMENTAL CONTROLS - ALL BOXES ARE TO BE MINIMUM 2 1/4" DEEP U.O.N. AND ARE FURNISHED BY THE ELECTRICAL CONTRACTOR. ALL HOMERUNS ARE IN MINIMUM 3/4" CONDUIT. REFER TO DIV 11 TP SERIES DRAWINGS BOX SCHEDULE FOR ADDITIONAL INFORMATION. |
| 3      | WASHER AND DRYER PROVISIONS - COORDINATE EXACT LOCATIONS PRIOR TO ROUGH IN.  |
| 4      | APPROX LOCATION OF SOLAR PANELS FOR SERVICE TIE-IN (ADD ALTERNATE). EACH PANEL 80"X 40" PROVIDING 380W EACH. ESTIMATED 4500W MAX POWER OUTPUT. INCLUDE CORRESPONDING INVERTER AND DISCONNECTING MEANS AS REQUIRED.   |

THIS DESIGN AND DRAWING IS THE SOLE PROPERTY OF FLEISCHMANGARCIA. NO PART OF THIS WORK MAY BE REPRODUCED WITHOUT PRIOR WRITTEN PERMISSION FROM FLEISCHMANGARCIA.

CERTIFY TO THE BEST OF MY KNOWLEDGE THAT THESE DRAWINGS COMPLY WITH ALL RELEVANT BUILDING CODES

**PERMIT SET**

FGA PROJECT NUMBER  
19048

ISSUE DATE  
04-15-2020

NO.	DATE	NOTES

SHEET NAME

SECOND FLOOR  
PLAN - POWER

SHEET NUMBER  
**E2.2**

Order Plans @

www.LDILine.com