



1 FLEXIBLE DUCT TAKEOFF DETAIL
N.T.S.




TITUS RETURN GRILL ALUMINUM 272A
6X6 WITH OPPOSED BLADE DAMPER
(G.B.D.) FOR TAB ADJUSTMENT
(OR APPROVED EQUAL)



Model 356 6 x 6 in. Straight Boot Galvanized Steel
30 ga
Part #SHMSRB26BFUUU : Item
#7207347 | Manufacturer Part #356666
Specifications
Collection: Model 356
Diameter: 6 in
Gauge: 30 (OR APPROVED EQUAL)
Length: 6 in
Material: Galvanized Steel
Width: 6 in

2 A/C DUCTWORK ACCESSORIES
N.T.S.



LOREN COOK E.F. 100C17DEC WITH
GRAVITY DAMPER AND ROOF
CURB ACCESSORY RCA-18
(REQUEST CURB TO MATCH ROOF
PITCH)

3 EXHAUST FAN DETAIL
N.T.S.

ABBREVIATIONS

A/C	AIR CONDITIONING	INSUL	INSULATION
ACT	ACOUSTICAL CEILING TILE or ACOUSTICAL TREATMENT	JT	JOINT
ACT	ACOUSTICAL CEILING TILE or ACOUSTICAL TREATMENT	LAM	LAMINATE
AT	ABOVE FINISHED FLOOR	LAV	LAVATORY
B	BOARD	LP	LOW POINT
BLDG	BUILDING	MAX	MAXIMUM
BLK	BLOCK	MCH	MECHANICAL
BLK'S	BLOCKING	M/L	METAL
BLR	BUILD UP ROOFING	MN	MINIMUM
CL	CENTER LINE	MO	MASONRY OPENING
CJ	CONTROL JOINT	MD	MANUAL VOLUME DAMPER
CLD	CEILING	NA	NOT APPLICABLE
CMU	CONCRETE MASONRY UNIT	NC	NOT IN CONTRACT
COL	COLUMN	ODB	OPPOSED BLADE DAMPER
CONC	CONCRETE	OC	ON CENTER
CONT	CONTINUOUS	OPN'G(OP'N'G)	OPENING
CU	CONDENSING UNIT	PL	PLATE
DIA	DIAMETER	PLAS. LAM.	PLASTIC LAMINATE
DN	DOWN	PLYWD	PLYWOOD
DS	DOWN SPOUT	PR	PRESSURE TREATED
DWG	DRAWING	RAD	RADIUS
EW	ELECTRIC WATER COOLER	ROF	ROOF DRAIN
EJ	EXPANSION JOINT	RFD	REQUIRED
FL	FLOOR	SAT	SUSPENDED ACOUSTICAL TILE
EXP	EXPANSION	SS	STAINLESS STEEL
EXIST'G	EXISTING	SUSP. CLG.	SUSPENDED CEILING
FC	FLEXIBLE CONDUCT	STL	STEEL
FD	FLOOR DRAIN	SQ	SQUARE
FP	FIREPROOF	THK	THICK
FJ	FIELD JOINT	TREAT'D	TREATED
FIN	FINISH	TOM	TOP OF MASONRY
FL	FLOOR	TOS	TOP OF STEEL
FLASH'G	FLASHING	TY	TYPICAL
GA	GAUGE	VIR	VENT THRU ROOF
GALV	GALVANIZED	VF	VERIFY IN FIELD
GL	GLASS	W	WITH
HM	HOLLOW METAL	W/O	WITHOUT
HP	HIGH POINT	WD	WOOD

Order Plans @ www.LDILine.com



1224 Royal Dr. Phone: (770) 483-9502
Suite 110 Fax: (770) 483-8082
Corryers, GA 30094 http://www.raymondllc.com

METRO TRANSITION
CENTER BATHROOM
RENOVATIONS

BUILDING A & C



GA DEPARTMENT OF
CORRECTIONS
300 PATROL DRIVE
PO BOX 1529
FORSYTH, GA 31029



CERTIFICATIONS

CONSULTANT

DATE	NO.	BY

DATE	NO.	DESCRIPTION
5/26/20	1	FOR CONSTRUCTION

RELEASES

PROJECT NO.:	1080.022
DESIGN BY:	---
DRAWN BY:	EB
CHECKED BY:	---

MECHANICAL DETAILS

M501