



POWER PLAN - ANCHOR 2B
SCALE: 3/32" = 1'-0"

POWER PLAN - RETAIL 2C
SCALE: 3/32" = 1'-0"

- GENERAL NOTES:**
- ALL 120/208V SINGLE PHASE AND THREE PHASE, 15 AND 20 AMP RECEPTACLES INSTALLED OUTDOORS, IN BATHROOMS, KITCHENS, AND ROOFTOP AREAS SHALL HAVE GROUND FAULT CIRCUIT INTERRUPTOR PROTECTION.
 - CONTRACTOR SHALL COORDINATE ALL ELECTRICAL CONSTRUCTION WITH OTHER TRADES TO AVOID CONFLICTS.
 - CONTRACTOR SHALL VERIFY THERE IS NO OVERLOADING OF BRANCH CIRCUITS AND/OR PANEL BOARD REGARDLESS OF CIRCUITRY INDICATED.
 - CONDUITS BELOW SLAB SHALL BE PVC CONDUITS WITH METAL ELBOW ENCLOSED IN WALL/CILING CONDUITS SHALL BE METAL CONDUITS. ANY EXPOSED CONDUITS SHALL BE METAL CONDUITS ONLY. ENCLOSED IN CONCRETE CONDUITS SHALL BE PVC.

- KEY NOTES**
- PROVIDE BUILDING FIRE ALARM SYSTEM AND FIRE ALARM CONTROL PANEL. FIRE ALARM SYSTEM SHALL BE COORDINATED BY FIRE PROTECTION ENGINEER AND FIRE PROTECTION CONTRACTOR.
 - PROVIDE FIRE ALARM DEVICES. CONNECT FIRE ALARM DEVICES TO BUILDING FIRE ALARM PANEL.
 - TERMINATE CABINET. CONTACT TELEPHONE COMPANY LOCATION AND REQUIREMENTS WITH TELEPHONE COMPANY. REFER TO TELEPHONE COMPANY POINT OF SERVICE.
 - FIELD VERIFY LOCATION OF UTILITY TRANSFORMERS.
 - FIELD VERIFY TO FIELD LOCATE BUILDING 2C WIREWAY.
 - CONTRACTOR SHALL PROVIDE TIME SWITCH WITH MULTIPLE CONTACTS TO CONTROL MONUMENT SIGNAGE. TIME SWITCH TS-1 SHALL FUNCTION ON A SCHEDULED BASIS USING TIME-OF-DAY WITH AN INDEPENDENT PROGRAM SCHEDULE THAT CONTROLS THE TENANT SIGNAGE.
 - CONTRACTOR SHALL PROVIDE TIME SWITCH TO CONTROL MONUMENT SIGN. TIME SWITCH TS-2 SHALL FUNCTION ON A SCHEDULED BASIS USING TIME OF DAY WITH AN INDEPENDENT PROGRAM SCHEDULE THAT CONTROLS MONUMENT SIGN.
 - FIRE ALARM DEVICE SHALL BE INSTALLED AS CLOSE TO DOOR AS POSSIBLE. DEVICE SHALL BE INSTALLED ON OPPOSITE SIDE OF FUTURE PARTITION.
 - CONTRACTOR TO STUB UP ONE (1) 2" CONDUIT INTO BUILDING AS SHOWN. CONTRACTOR TO PROVIDE CAP FOR CONDUIT STUB UP.
 - PROVIDE 1" CONDUIT AND PULL STRING FROM LANDLORD TELEPHONE SERVICE CABINET TO EACH TENANT SPACE. FIELD LOCATE CONDUIT AND PULL STRING. A TOTAL OF FOUR (4) OF TENANTS SHALL HAVE CONDUIT IN SPACE.
 - CONTRACTOR TO STUB UP ONE (1) 3-1/2" CONDUIT INTO BUILDING AS SHOWN. CONTRACTOR TO PROVIDE CAP FOR CONDUIT STUB UP.



© 2019 D-Z-A ASSOCIATES, INC. THE ARCHITECT SHALL BE DEEMED THE AUTHOR OF THESE DOCUMENTS AND SHALL BE RESPONSIBLE FOR ANY REVISIONS AND OTHER MATTER, INCLUDING EQUIPMENT.

Rev. No.	Description	Date
▲	ISSUED FOR BID AND PERMIT	03/29/19
▲	ISSUED FOR BID	05/30/19
▲	RE-ISSUED FOR BID AND PERMIT	10/16/20

Salem Gate Market

ANCHOR 2B AND RETAIL 2C

1454 AND 1460 OLD SALEM ROAD
CONYERS, GEORGIA

ELECTRICAL POWER PLAN

Date	Drawn By	Checked By	Sheet No.
3/29/19	AK	AK	E1.1 (2)
18.110	AR		



Order Plans @ WWW.LDILine.com