


FIRE PROTECTION KEYNOTES
 APPLIES TO THIS SHEET
 REPRESENTED BY [Symbol]

1. PROVIDE A DOUBLE INTERLOCK PREACTION SYSTEM IN SECURITY ELECTRONICS ROOM.
2. PROVIDE SPRINKLER PROTECTION IN CHASES, IN THE SPACE ABOVE CELL CEILINGS AND ABOVE THE CEILINGS IN THE COMMON AREAS.
3. NO AUTOMATIC SPRINKLER COVERAGE REQUIRED IN THIS SPACE.
4. ADD (2) RISERS IN EXISTING SPRINKLER ROOM FOR EACH SMOKE COMPARTMENT IN BUILDING 2 - NEW CONSTRUCTION.
5. COORDINATE LOCATION OF NEW PIPING WITH EXISTING CONDITIONS.

DWG FP2.1.1

FIRST FLOOR FIRE PROTECTION PLAN - SOUTH
 1/8" = 1'-0"



KEY PLAN

MOSELEYARCHITECTS

1320 MAIN STREET, SUITE 300, COLUMBIA, SC 29201
 PHONE (803) 724-1252
 MOSELEYARCHITECTS.COM



Order Plans @ www.LDILine.com

MARION COUNTY LEC

591492
 MARION COUNTY
 2715 EAST HWY 76, MULLINS, SC 29574

PROJECT NO.	591492
DATE	OCTOBER 30, 2020
REVISIONS	
DATE	DESCRIPTION

FIRST FLOOR FIRE PROTECTION PLAN - SOUTH

FP2.1.2