

Order Plans @

ELECTRICAL SCHEDULE

ITEM #	TAG #	QTY	DESCRIPTION	VOLTS	PH	CYCLE	HP	BRKR SIZE	AMPS	ELEC CONN TYPE	PLUG TYPE	CONN RI HIGHT	ELECTRICAL REMARKS
10.01	E1	1	ICE/SODA DISPENSER	115 V	1	60 Hz	-	20.00 A	6.00 A	PLUG & CORD	NEMA 5-20P	24"	-
10.81	E1	3	CARBONATOR	120 V	1	60 Hz	1/3	20.00 A	6.20 A	PLUG & CORD	NEMA 5-20P	84"	ADDITIONAL ELECTRICAL OUTLETS TO BE PLACED 66" & 94" A.F.F. SEE DETAIL ON K4.0
11.03	E1	1	ICE/SODA DISPENSER	115 V	1	60 Hz	-	20.00 A	5.00 A	PLUG & CORD	NEMA 5-20P	48"	24VAC ELECTRICAL SYSTEM SUPPLIED USING 115V TRANSFORMER PROVIDED WITH DISPENSER E.C. TO SUPPLY & INSTALL 6FT. CORD & PLUG.
15.27	E1	1	HEAT TREAT COMBINATION SHAKE/SUNDAE MACHINE	208 V	3	60 Hz	2 1/2	45.00 A	35.00 A	PLUG & CORD	SEE RMKS	36"	-
15.64	E1	1	FROZEN BEVERAGE DISPENSER	208 V	1	60 Hz	(2) 1/6, (1) 1/4	30.00 A	20.00 A	PLUG & CORD	NEMA L5-20P	36"	-
16.16	E1	1	ICE MACHINE	115 V	1	60 Hz	-	20.00 A	12.20 A	DIRECT WIRED	DIRECT	72"	-
16.54	E1	1	ICE MACHINE REMOTE CONDENSING UNIT	208 V	1	60 Hz	1	0.00 A	1.30 A	DIRECT WIRED	DIRECT	18"	E.C. TO DIRECTLY WIRE UNIT TO CIRCULAR BREAKER
16.72	E1	1	ICE MACHINE	208 V	1	60 Hz	-	25.00 A	14.00 A	DIRECT WIRED	DIRECT	84"	-
17.56	E1	1	INFUSION TEA COFFEE BREWER	120 V	1	60 Hz	-	20.00 A	14.00 A	PLUG & CORD	NEMA 5-15P	24"	-
19.82	E1	1	BLENDER	120 V	1	60 Hz	3	20.00 A	8.60 A	PLUG & CORD	NEMA 5-20	24"	-
20.37	E1	1	41" EXPEDITER STATION STD FLOW	120 V	1	60 Hz	-	20.00 A	16.00 A	PLUG & CORD	NEMA 5-20P	0"	CONNECTS TO RECEPTACLE ON PREP MODULE "A" VIA POWER CORD
21.66	E1	1	60" PREP MODULE "A" - (ABCDIACBD)	208 V	3	60 Hz	-	0.00 A	1.08 A	DIRECT WIRED	DIRECT	0"	DO NOT THRU SERM. OVERSE. E.C. TO CONNECT TO LOAD CENTER PROVIDED. AS REQ'D FOR 150A-5 WIRE W/106A BREAKER. PERCENTAGE LOAD FOR LOAD CENTER IN THIS CABINET TO BE CALCULATED FROM COMBINED LOADS OF EQUIPMENT ATTACHED TO THIS CABINET.
21.67	E1	1	28" BUN TOASTER MODULE "B"										CONNECTS TO LOAD CENTER ON PREP MODULE "A"
21.68	E1	1	32.5" PREP MODULE "C"										CONNECTS TO LOAD CENTER ON PREP MODULE "A"
21.69	E1	1	20" PREP MODULE "D"										CONNECTS TO LOAD CENTER ON PREP MODULE "A"
23.45	E1	1	91" BROILER HOOD										E.C. TO CONNECT TO JB FOR HOOD'S LIGHT
23.77	E1	1	EXHAUST FAN	208 V	1	60 Hz	1	20.00 A	1.00 A	DIRECT WIRED	REFER TO REMARKS	12"	E.C. TO INTERCONNECT CIRCUIT W/ SAFETY INTERLOCK AT BUILDING'S MAIN BREAKER PANEL. CONNECTION HEIGHT @ 12" B.F.R.
24.44	E1	1	BROILER BK FLAMING HEART	120 V	1	60 Hz	-	20.00 A	3.50 A	PLUG & CORD	NEMA 5-15P	0"	CONNECTS INTO RECEPTACLE ON HOOD'S CHASE
25.12	E1	1	50" MEAT WELL FREEZER	120 V	1	60 Hz	-	20.00 A	7.60 A	PLUG & CORD	NEMA 5-20P	0"	CONNECTS INTO RECEPTACLE ON HOOD'S CHASE
30.04	E1	1	35" FRY STATION - ROC GEN 4.0	120 V	1	60 Hz	-	20.00 A	16.00 A	PLUG & CORD	NEMA L14-20P	24"	-
31.53	E1	1	3 - BANK FRYER	120 V	1	60 Hz	-	20.00 A	10.00 A	PLUG & CORD	NEMA 5-15P	0"	E.C. TO CONNECT (2) NEMA 5-15P INTO RECEPTACLE ON RACEWAYS HOOD
31.53	E2	1	3 - BANK FRYER	0 V	1	60 Hz	-	20.00 A	1.00 A	PLUG & CORD	-	0"	-
32.52	E1	1	PRODUCT HOLDING FREEZER	120 V	1	60 Hz	-	20.00 A	4.60 A	PLUG & CORD	NEMA 5-15P	24"	-
33.30	E1	1	67" FRYER HOOD										E.C. TO CONNECT TO JB FOR HOOD'S LIGHT
33.66	E1	1	EXHAUST FAN	208 V	1	60 Hz	1	20.00 A	1.00 A	DIRECT WIRED	REFER TO REMARKS	12"	E.C. TO INTERCONNECT CIRCUIT W/ SAFETY INTERLOCK AT BUILDING'S MAIN BREAKER PANEL. CONNECTION HEIGHT @ 12" B.F.R.
36.72	E1	1	MINI COMBI OVEN-STEAMER LH	208 V	3	60 Hz	-	20.00 A	20.00 A	PLUG & CORD	SEE RMKS	0"	E.C. TO SUPPLY & INSTALL CORD & PLUG
50.06	E1	1	MICROWAVE OVEN	230 V	1	60 Hz	-	20.00 A	15.30 A	PLUG & CORD	NEMA 6-20P	0"	CONNECTS INTO RECEPTACLE ON PREP MODULE "A", 5' 6" POWER CORD
50.06	E1	1	MICROWAVE OVEN	230 V	1	60 Hz	-	20.00 A	15.30 A	PLUG & CORD	NEMA 6-20P	0"	CONNECTS INTO RECEPTACLE ON PREP MODULE "D", 5' 6" POWER CORD
51.39	E1	1	MULTI-PRODUCT HOLDING UNIT	208 V	3	60 Hz	-	20.00 A	9.00 A	PLUG & CORD	NEMA 6-15P	60"	-
51.43	E1	2	MULTI-PRODUCT HOLDING UNIT	208 V	1	60 Hz	-	20.00 A	13.50 A	PLUG & CORD	NEMA 6-15P	0"	CONNECTS INTO RECEPTACLES ON PREP MODULE A & C
52.73	E1	1	REACH-IN FREEZER, RH	120 V	1	60 Hz	1/2	20.00 A	9.00 A	PLUG & CORD	NEMA 5-15P	24"	-
53.55	E1	1	REACH-IN UNDERCOUNTER REFRIGERATOR	115 V	1	60 Hz	1/5	20.00 A	3.30 A	PLUG & CORD	NEMA 5-15P	0"	CONNECTS INTO MODULE "D"
53.55	E1	1	REACH-IN UNDERCOUNTER REFRIGERATOR	115 V	1	60 Hz	1/5	20.00 A	3.30 A	PLUG & CORD	NEMA 5-15P	12"	-
55.12	E1	2	DUAL CONTINUOUS FEED TOASTER	208 V	1	60 Hz	-	20.00 A	15.00 A	PLUG & CORD	NEMA L6-30P	0"	CONNECTS INTO RECEPTACLE ON PREP MODULE "B"
59.51	E1	1	EGG COOKER	208 V	1	60 Hz	-	20.00 A	11.40 A	PLUG & CORD	NEMA L6-20P	0"	CONNECT INTO RECEPTACLE ON PREP MODULE "D"
931.88	E1	1	PORTABLE FILTER	120 V	1	60 Hz	1/3	0.00 A	6.20 A	PLUG & CORD	NEMA 5-15P	0"	VERIFY AND REWORK ALL EXISTING UTILITIES AS REQUIRED
931.91	E1	2	SHORTENING DISPOSAL SYSTEM	120 V	0	60 Hz	-	0.00 A	0.00 A	-	-	0"	VERIFY AND REWORK ALL EXISTING UTILITIES AS REQUIRED
940.01	E1	1	WALK-IN COOLING FREEZER	0 V	0	60 Hz	-	0.00 A	0.00 A	-	-	0"	VERIFY AND REWORK ALL EXISTING UTILITIES AS REQUIRED

ROBERISON LOIA ROOF ARCHITECTS & ENGINEERS
 3460 Preston Ridge Road, Suite 275, Alpharetta, GA 30005
 770.544.2400
 GA COA #PE060592 EXPIRES 06/30/2022



PALMETTO BURGER KING
 3765 ROOSEVELT HWY, PALMETTO, GA.
 FOR: **JP DESIGN & CONSTRUCTION**
 JACKSON, GA

REVISIONS

KITCHEN EQUIPMENT SCHEDULE

DATE: **10-30-20**
 PROJECT NUMBER: **20-197**
 SHEET NUMBER: **E-4.0**