

EXISTING CABINET LAYOUT

OUTSIDE LIGHTING, DISPENSER & PUMP CONTROLS



NEW CPI CABINET LAYOUT

DISPENSER & PUMP CONTROLS

ELECTRICAL SCOPE:

1. INSTALL NEW CPI DISPENSER CONTROL CABINET FOR (5) NEW DIESEL DISPENSERS & (2) NEW STP's.
2. CONNECT NEW E-STOP CONTROLS TO EXISTING E-STOP SYSTEM.
3. CONNECT NEW CANOPY LIGHTS, SIGNS & POLE LIGHTS TO EXISTING LIGHTING CONTACTORS & CONTROLS.
4. COORDINATE WITH CPI (CAROLINA PRODUCTS INC) FOR INTERCONNECTION REQUIREMENTS TO EXISTING FUEL EQUIPMENT & LIGHTING CONTROLS.
5. INSTALL NEW PANEL "E" FOR NEW DIESEL DISPENSERS, STP's AND LIGHTS.

PANELBOARD: 600 AMP MAIN BREAKER | 120/208 3-PHASE 65K AIC FULLY RATED | PANEL MDP EXISTING | BOLT-IN SURFACE-NEMA 1 | NEUTRAL BAR EQUIPMENT GROUND BAR

CIRCUIT DESCRIPTION	*	VA LOAD A	VA LOAD B	VA LOAD C	Brk.	Wire	Cond.	Nom.	Cond.	Wire	Brk.	*	VA LOAD A	VA LOAD B	VA LOAD C	*	CIRCUIT DESCRIPTION
PANEL A	1	4947			100/2	1/0	1	1	1	1/0	100/2					1	PANEL D
PANEL B	1		6570		100/2	1/0	1	2	1	1/0	100/2					1	PANEL D
PANEL A	1	5787			100/2	1/0	1	3	1	1/0	100/2	6,300	12665			1	PANEL D
PANEL C	1		7000S		200/2	3/0	1	4	1	3/0	200/2			13605		1	PANEL D
PANEL C	1			6638	200/2	3/0	1	5	1	3/0	200/2				7056	1	NEW PUMP 10
NEW PUMP 01	1	14826			125/3	2	1	6	1	6	80/3			7056		1	NEW PUMP 10
NEW PUMP 01			14826		125/3	2	1	7	1	6	80/3				7056	1	NEW PUMP 10
NEW PUMP 01	1	14826			125/3	2	1	8	1	6	80/3		7056			1	NEW PUMP 10
SPARE					60/3	6	1	9	1	10	30/3			3480		1	SPARE
SPARE					60/3	6	1	10	1	10	30/3				3480	1	SPARE
SPARE					60/3	6	1	11	1	10	30/3		3480			1	SPARE
SPARE					60/3	6	1	12	1	10	30/3			3480		1	SPARE
		44980	48393	39218	0								6300	25665	21157	18530	

CONNECTED VA (A): 80788
CONNECTED VA (B): 81192
CONNECTED VA (C): 69754
CONNECTED VA (ABC): 210734

	CONNECTED		DEMAND
NON-CONTINUOUS	*1 210734	100%	210734
CONTINUOUS	*2 0	125%	0
KITCHEN EQUIPMENT	*3 0	65%	0
SUBTOTAL:	210734		210734
NON-COINCIDENTAL	39060		39060
TOTAL	1709794		1709794

TOTAL NEUTRAL LOAD: 6,300 / (208)(1.73) = 17.5 AMPS
TOTAL DEMAND LOAD: 170,774 / (208)(1.73) = 474.8 AMPS

PANELBOARD: 225 AMP MLO | 120/208 1-PHASE 65K AIC SERIES RATED | PANEL D EXISTING | BOLT-IN SURFACE-NEMA 1 | NEUTRAL BAR EQUIPMENT GROUND BAR

CIRCUIT DESCRIPTION	*	VA LOAD A	VA LOAD B	VA LOAD C	Brk.	Wire	Cond.	Nom.	Cond.	Wire	Brk.	*	VA LOAD A	VA LOAD B	VA LOAD C	*	CIRCUIT DESCRIPTION
AUTO DIESEL PUMP	1	1120			20/1	12		1	1	12	20/1					1	SPARE
AUTO DIESEL PUMP	1		1120		20/1	12		2	1	12	20/1	360				1	SPARE
AUTO REGULAR PUMP 01	1	1120			20/1	12		3	1	12	20/1		360			1	SPARE
AUTO REGULAR PUMP 01	1		1120		20/1	12		4	1	12	20/1	360				1	SPARE
AUTO REGULAR PUMP 02	1	1120			20/1	12		5	1	12	20/1			360		1	SPARE
AUTO REGULAR PUMP 02	1		1120		20/1	12		6	1	12	20/1	360				1	SPARE
AUTO REGULAR PUMP 03	1	1120			20/1	12		7	1	12	20/1			360		1	SPARE
AUTO REGULAR PUMP 03	1		1120		20/1	12		8	1	12	20/1	360				1	SPARE
KEG	1	180		180	20/1	12		9	1	12	20/1			360		1	SPARE
LLS	1	240	240	240	20/1	12		10	1	12	20/1	360				1	SPARE
PANEL C	1	5945		1,380	100/2	3	1.25"	11	1	12	20/1		360			1	SPARE
PANEL E	1		4568		100/2	3	1.25"	12	1	12	20/1	360				1	SPARE
								13			20/1			360		1	SPARE
								14			20/1	360				1	SPARE
								15			20/1			360		1	SPARE
								16			20/1	360				1	SPARE
								17			20/1			360		1	SPARE
								18			20/1	360				1	SPARE
								19			20/1			360		1	SPARE
								20			20/1	360				1	SPARE
								21			20/1			360		1	SPARE
								22			20/1	360				1	SPARE
								23			20/1			360		1	SPARE
								24			20/1	360				1	SPARE
		13258	10988	2788									3600	3240	0		

CONNECTED VA (A): 16846
CONNECTED VA (B): 14196
CONNECTED VA (C): 2788

	CONNECTED		DEMAND
NON-CONTINUOUS	*1 25070	100%	25070
CONTINUOUS	*2 0	125%	0
KITCHEN EQUIPMENT	*3 0	65%	0
SUBTOTAL:	25070		25070
NON-COINCIDENTAL	0		0
TOTAL	25070		25070

TOTAL NEUTRAL LOAD: 6,300 / 208 = 30.3 AMPS
TOTAL DEMAND LOAD: 25,070 / 208 = 120.5 AMPS

* NEW CIRCUIT

PANELBOARD: 225 AMP MLO | 120/208 1-PHASE NRAIC RATED | PANEL E NEW | BOLT-IN SURFACE-NEMA 1 | NEUTRAL BAR EQUIPMENT GROUND BAR

CIRCUIT DESCRIPTION	*	VA LOAD A	VA LOAD B	VA LOAD C	Brk.	Wire	Cond.	Nom.	Cond.	Wire	Brk.	*	VA LOAD A	VA LOAD B	VA LOAD C	*	CIRCUIT DESCRIPTION
TRENCHER PUMP	1	1120			20/1	12	75°	1	1	75°	12	20/1				1	SPARE, ONE LINE ONLY
TRENCHER PUMP	1		1120		20/1	12	75°	2	1	75°	12	20/1	360			1	SPARE, ONE LINE ONLY
TRENCHER	1	1120			20/1	12	75°	3	1	75°	12	20/1		360		1	SPARE, ONE LINE ONLY
TRENCHER	1		1120		20/1	12	75°	4	1	75°	12	20/1	360			1	SPARE, ONE LINE ONLY
TRENCH CANOPY LIGHTS	1	400			20/1	12	75°	5	1	75°	12	20/1		360		1	SPARE, ONE LINE ONLY
TRENCH CANOPY LIGHTS	2		400		20/2	12	75°	6	1	75°	12	SWD	360			1	SPARE, ONE LINE ONLY
TRENCH CANOPY LIGHTS	2	400			20/2	12	75°	7	1	75°	12	20/1		360		1	SPARE, ONE LINE ONLY
TRENCH CANOPY LIGHTS	2		400		20/2	12	75°	8	1	75°	12	SWD	360			1	SPARE, ONE LINE ONLY
TRENCH CANOPY FANS	2	420		420	20/1	10	75°	9	1	75°							
TRENCH CANOPY FANS	2		420	420	20/1	10	75°	10	1	75°							
PSS CLOSERS	2	240			20/2	10	75°	11	1	75°							
PSS CLOSERS	2		320		20/2	10	75°	12	1	75°							
PSS CLOSERS	2	320			20/2	10	75°	13	1	75°							
PSS CLOSERS	2		320		20/2	10	75°	14	1	75°							
		4160	4160	840									1440	1080	0		

CONNECTED VA (A): 5160
CONNECTED VA (B): 4320
CONNECTED VA (C): 840

	CONNECTED		DEMAND
NON-CONTINUOUS	*1 5160	100%	5160
CONTINUOUS	*2 2720	125%	4888
KITCHEN EQUIPMENT	*3 0	65%	0
SUBTOTAL	9280		10216
NON-COINCIDENTAL	0		0
TOTAL	9280		10216

TOTAL NEUTRAL LOAD: 2,280 / 208 = 11.0 AMPS
TOTAL DEMAND LOAD: 10,216 / 208 = 49.1 AMPS



NOTE: ALL CONDUCTORS TO BE THWN, COPPER

REVISED SINGLE LINE DIAGRAM

120 / 208 VOLTS 600 AMPS 3-PHASE

Order Plans @ www.LDLinc.com

CLIENT:

CIRCLE K STORES, INC.

SOUTH ATLANTIC DIVISION
215 PENDLETON ST
WAYCROSS, GA 31501
PHONE: (912) 285-4011

DESIGN TEAM:

MDM SERVICES, INC.
engineering + environmental + construction
1056 KATHLEEN ROAD LAKELAND, FLORIDA 33805
(863) 646-8130
EB #004857

TANK & PIPING PLANS & SPECIFICATIONS

NO.	DATE	REVISION DESCRIPTION

NOT FOR CONSTRUCTION

RICHARD R. MORRIS, P.E.
GA REG # 033397

SITE ADDRESS:

CIRCLE K

1717 E 16th AVE.
CORDELE, CRISP COUNTY
GEORGIA

SCALE:	MDM JOB # 20183
DATE: 11/14/19	
DESIGNED BY:	
DRAWN BY: JR	FILE NAME:
CHECKED BY:	

DRAWING TITLE:

ELECTRICAL EQUIPEMENT PLAN

SHEET NO:

SE-2.0