


LIGHTING FIXTURE SCHEDULE					
TYPE MARK	VOLTAGE	WATTS	MODEL #	MANUFACTURER	COMMENTS
A	120/277	124	PDR-VHLED-LD1-15-W-UNV-L850-CD 1-90CRI	METALUX	LED HIGH BAY
AE	120/277	124	PDR-VHLED-LD1-15-W-UNV-L850-CD 1-90CRI-EL20W	METALUX	EMERGENCY LED HIGH BAY
A2	120/277	56	4VT2-LD4-B-DR-W-UNV-L840-CD1-W L-U	METALUX	EXTERIOR - INDUSTRIAL LED HI-BAY
A2E	120/277	56	4VT2-LD4-B-DR-W-UNV-L840-CD1-W L-U-EL20W	METALUX	EXTERIOR - INDUSTRIAL LED HI-BAY W/ 90 MINUTE BATTERY
B	120/277	40	74250 SYL PANELF1A/040UNVD840/24G/WH	SYLVANIA	2X4 LED FLAT PANEL - 4000K - FROSTED LENS
BE	120/277	40	74242 SYL PANELF1A/040UNVD840/24G/WH/E	SYLVANIA	2X4 LED FLAT PANEL - 4000K - FROSTED LENS WITH 90 MINUTE BATTERY PACK
B1	120/277	40	74242 SYL PANELF1A/040UNVD840/24G/WH WITH DRYWALL KIT	SYLVANIA	2X4 LED FLAT PANEL - 4000K - FROSTED LENS WITH DRYWALL KIT
B1E	120/277	40	74242 SYL PANELF1A/040UNVD840/24G/WH/E WITH DRYWALL KIT	SYLVANIA	2X4 LED FLAT PANEL - 4000K - FROSTED LENS WITH 90 MINUTE BATTERY PACK WITH DRYWALL KIT
CE	120/277	30	4000K-LED-30SL-LN-UNV-L840-CD1 U	METALUX	4' UTILITY LED STRIP WITH 90 MIN BATTERY PACK.
D	120/277	13	TPR-4000K-CMX40-EXT50-4FT-4MAG	TPR	EXTERIOR CANOPY LED STRIP LIGHT
D1	120/277	19	LD6 B15 D010 / EUB610208040 / 6LBM2LI	PORTFOLIO	6" LED DOWNLIGHT
D2	120/277	19	LD6 B15 D010 EM7 / EUB610208040 / 6LBM2LI	PORTFOLIO	EMERGENCY 6" LED DOWNLIGHT WITH 90 MINUTE BATTERY PACK
D2	120/277	19	LD6 B15 D010 / EUB610208040 / 6LBSW2LI	PORTFOLIO	6" LED WALL WASHER
FE	120/277	47	IST-E02-LED-E1-BL2-BBB	MCGRAW-EDISON	EXTERIOR WALL PACK WITH 90 MINUTE BATTERY PACK. 12"-0" A.F.F.
FE2	120/277	58	XTOR6B-C8P-BK	LUMARK	EXTERIOR WALL PACK WITH BATTERY PACK 9"-0" A.F.F.
G	120/277	46	WP-L-8B-C	LUMARK	EXTERIOR WALL PACK
GE	120/277	24	IST-AF-350-LED-120-T4FT-BZ-BBB	LUMARK	EXTERIOR WALL PACK FULL CUT OFF WITH 90 MINUTE BATTERY PACK
P1	120/277	213	GLEON-AF-04-LED-E1-SL4-HSS	EATON	POLE LIGHT
P2	120/277	225	GLEON-AF-04-LED-E1-5WQ	EATON	POLE LIGHT
WS	120/277	25	ENS3-A7E140-BLCK-120-277V	GE	WALL PACK
X	120/277	1	LPX-7	COOPER LIGHTING	EXIT SIGNS WITH STANDARD BATTERY PACK WITH SELF DIAGNOSTICS.

NOTES: ALL LIGHT TYPES ARE NOT NECESSARILY USED.

GENERAL NOTES

- ARCHITECT TO VERIFY ALL FINISHES AND FIXTURES PRIOR TO PURCHASE.
- FIXTURES A AND AE SHALL BE MOUNTED WITH CABLE AT ALL FOUR CORNERS.
- DIMMING BALLAST CAPABLE OF REDUCING POWER TO LESS THAN 35% OF RATED POWER.
- ALL FIXTURES IN SHOP AREA TO BE MOUNTED AT 12' AFF AND SUPPORTED AT ALL FOUR CORNERS. REFER TO PHOTOMETRIC PLAN FOR MOUNTING HEIGHT.

NATIONAL ACCOUNT LIGHTING VENDOR - CITY LIGHTING PRODUCTS, INC - TREY ADAMS @ 704-235-3133



1925 Prospect Ave.
Orlando, FL 32814
P (407) 661-9100
F (407) 661-9101
www.c-p.com
Florida Corporate Certificate #AA 000626

Chadwick & Peterson
Architects Engineers Planners
ORLANDO • PHILADELPHIA

CLIENT NAME
Cross Development
4336 Marsh Ridge
Carrollton, TX 75010

PROJECT NAME
Caliber Collision Five Forks (161)
1215 East Butler Rd
Greenville, SC 29607

SHEET TITLE
Electrical Details

10/22/2020

RELEASE
PERMIT COMMENT RESPONSE 04/22/2020

PROJECT NO.
220087

DATE
07/08/2020

DRAWN
TWO

CHECKED
JS

E5.0