



EXISTING FLOOR PLAN  
w/STRUCTURAL MODIFICATIONS  
SCALE: 1/8" = 1'-0"




SECTION A  
SCALE: 3/4" = 1'-0"




ELEVATION 1  
SCALE: 1/2" = 1'-0"


NOTE: DURING DEMOLITION PHASE CONTRACTOR SHALL PRESERVE 8" MINIMUM OF EXISTING HORIZONTAL REINFORCING ON EACH SIDE OF NEW OPENING IN ORDER TO INTEGRATE SAID REINFORCING INTO NEW MASONRY.



SECTION B  
SCALE: 1" = 1'-0"



DETAIL 1  
SCALE: 1" = 1'-0"



DETAIL 2  
SCALE: 1" = 1'-0"

**STRUCTURAL NOTES:**

- CONTRACTOR SHALL FIELD VERIFY ALL CONDITIONS AND DIMENSIONS PRIOR TO THE ORDERING OF MATERIALS AND THE COMMENCING OF CONSTRUCTION.
- COORDINATE ALL WORK WITH ARCHITECTURAL AND MECHANICAL DRAWINGS.
- PRIOR TO CMU DEMOLITION, THE EXISTING WALL ABOVE THE OPENING SHALL BE SHORED ON EACH SIDE OF WALL. SHORING SYSTEM SHALL BE CAPABLE OF SUPPORTING 800 P.S.F. (SEAD LOAD).
- UPON COMPLETION OF DEMOLITION WORK, CONTRACTOR SHALL NOTIFY ENGINEER OF ANY DISCREPANCIES BETWEEN PLANS AND ACTUAL FIELD CONDITIONS. IF NECESSARY, ENGINEER SHALL REINSPECT ALL EXISTING STRUCTURAL MEMBERS AND CONNECTIONS PRIOR TO CONTRACTOR MAKING ANY NEW STRUCTURAL MODIFICATIONS.
- CONCRETE SHALL BE 3,000 PSI MINIMUM COMPRESSIVE STRENGTH AT 28 DAYS.
- REINFORCING STEEL SHALL CONFORM TO ASTM A615, GRADE 60.
- EPOXY SHALL BE SIKADUR H MOD 32 OR EQUAL.
- ALL MASONRY WORK SHALL CONFORM TO AGC-535, LATEST EDITION, F<sub>m</sub> = 1,500 PSI. USE TYPE S OR M MORTAR.
- STRUCTURAL DESIGN LOADS: 2018 INTERNATIONAL BUILDING CODE w/2020 GEORGIA AMENDMENTS  
DL = ACTUAL LOAD  
WL = EXPOSURE "B" V<sub>W</sub> = 115 mph V<sub>W</sub> = 90 mph  
BUILDING OCCUPANCY CATEGORY II IMPORTANCE FACTOR 1.0 (I<sub>w</sub>)  
ENCLOSED BUILDING, INTERNAL PRESSURE COEFFICIENT +0.18 (GCp)  
LI ROOF = 20 (REDUCED) ASCE 7-16 CODE  
GROUND SNOW LOAD  
FROST LINE DEPTH

**STRUCTURAL SCOPE OF WORK:**

- PROVIDE STRUCTURAL SUPPORT FOR (2) 12\"/>
- PROVIDE NEW CONCRETE THRESHOLDS AT EACH NEW WALL OPENING.
- PROVIDE NEW CONCRETE LANDING AT SIDE (SOUTH) EXTENSION OF SPACE TO SERVE NEW DOOR OPENING.

Order Plans @

CLARK, GERR, LATHAM  
ENGINEERS ARCHITECTS  
1100 S. W. 10TH AVE. SUITE 100  
DAVENPORT, NC 27834  
TEL: (757) 267-3400  
FAX: (757) 267-3401  
CCL JOB No. 2010-00

mark	date	description

date	project	designed	drawn	checked	title
12/29/20	2108-00	TBC/DAB	ASH	TRE	

**RRMM ARCHITECTS, P.C.**  
Robert S. Barz, Jr., Architect  
Duane M. Harver, Architect  
1317 Executive Blvd., Suite 200  
Chesapeake, VA 23320  
(757) 622-2828 / fax (757) 622-8883



**DOLLAR TREE**  
NORTHSIDE PLAZA, DEAL #12293  
DALTON, GA  
EXISTING ROOF FRAMING PLAN  
w/STRUCTURAL MODIFICATIONS

sheet  
**S-1.0**