



② LEVEL 1 - SPRINKLER PLAN
1/8" = 1'-0"

Order Plans @

WWW.LDILINE.COM

HAZARD CLASS LEGEND

- LIGHT HAZARD (0.10 GPM/SQFT)
- ORDINARY HAZARD GROUP 1 (0.15 GPM/SQFT)
- ORDINARY HAZARD GROUP 2 (0.20 GPM/SQFT)

DRAWING NOTES

1. REFER TO FP-001 FOR GENERAL NOTES, ABBREVIATIONS, AND LEGEND.
2. REFER TO FP-001 FOR FURTHER CLARIFICATION ON DEMOITION AND NEW WORK EFFORTS.
3. ALL NEW ARM-OVERS SHALL BE 1-INCH IN DIAMETER UNLESS OTHERWISE INDICATED.

KEYED NOTES

1. DEMOLISH PENDENT SPRINKLER BACK TO BRANCHLINE AND CAP.
2. FURNISH AND INSTALL CONCEALED DRY-TYPE PENDENT SPRINKLER WITH CHROME COVER PLATE AND HIGH-TEMPERATURE RESPONSE RATING. A MINIMUM 14-INCHES OF BARREL LENGTH MUST BE WITHIN THE HEATED SPACE ABOVE THE COOLER/FREEZER. REFER TO NFPA 13. COOLERS WITH AUTOMATIC DEFROSTING SHALL BE INTERMEDIATE-TEMPERATURE CLASSIFICATION OR HIGHER PER NFPA 13. SEAL ANNULAR SPACE WITH INSULATION EQUAL TO FULL THICKNESS OF COOLER ENCLOSURE.
3. FURNISH AND INSTALL PENDENT SPRINKLER TO ENSURE NFPA 13 COMPLIANT COVERAGE.
4. ADD NEW ARM-OVER TO RELOCATE SPRINKLER TO NEW LOCATION AS INDICATED BY DIMENSIONS. FINAL ARRANGEMENT IS REQUIRED TO SATISFY NFPA 13 SPACING CRITERIA. EXISTING CONFIGURATION IS IN EXCESS OF NFPA 13 SPACING REQUIREMENTS.

ENGINEERS
 ARCHITECTS
 PLANNERS
 SCIENTISTS
 CONSTRUCTION MANAGERS
KCI
 1015 WISCONSIN AVE. STEEF
 BETHESDA, MD 20814
 TEL: (301) 461-5000
 FAX: (301) 461-5006

mark	date	by	description

date	project	designed	drawn	checked
1/5/2021	2108/08	MCP	MCF	MEH

RRMM
 ARCHITECTS, PC
 Robert S. Berz, Jr., Architect
 Duane M. Harver, Architect
 1317 Executive Blvd, Suite 200
 Chesapeake, VA 23320
 (757) 622-2628 / fax (757) 622-6883

M. NEW E. VLACHNER
 ENGINEER
 No. PE038361
 PROFESSIONAL
 REGISTERED
 STATE OF VIRGINIA
 1-5-2021

project
DOLLAR TREE
 NORTHSIDE PLAZA, DEAL #12283
 DALTON, GA
 drawing
 SPRINKLER FLOOR PLAN

sheet
FP-101

