



- ### OCCUPANCY SENSOR NOTES
- OCCUPANCY SENSORS IN RESTROOMS SHALL BE PROGRAMMED FOR AUTOMATIC ON AND MAXIMUM AVAILABLE TIME DELAY SETTINGS.
  - OCCUPANCY SENSORS IN DEEL, PRODUCE, AND BAKERY PREP AREAS SHALL BE PROGRAMMED WITH MAXIMUM AVAILABLE TIME DELAY SETTINGS.
  - OCCUPANCY SENSORS IN WALK-IN COOLERS/FREEZERS SHALL BE LOW TEMPERATURE RATED, WALL MOUNTED 8" ABOVE DOOR, ADJUST AIMING FOR MAXIMUM COVERAGE, 10 MINUTE TIME DELAY.
  - ALL OTHER OCCUPANCY SENSORS SHALL BE PROGRAMMED WITH THE MINIMUM AVAILABLE TIME DELAY SETTING UNLESS NOTED OTHERWISE.
  - ALL SINGLE-POLE OCCUPANCY SENSORS SHALL BE PROGRAMMED FOR MANUAL ON LIGHTING CONTROL UNLESS NOTED OTHERWISE.
  - ALL BI-LEVEL OCCUPANCY SENSORS SHALL BE PROGRAMMED FOR AUTOMATIC ON LIGHTING CONTROL FOR 50% OF FIXTURES AND WITH MANUAL ON MODE FOR REMAINING FIXTURES.
  - WHERE TWO OCCUPANCY SENSORS ARE SHOWN IN THE SAME LOCATION WIRE FOR PARALLEL OPERATION.

- ### GENERAL LIGHTING NOTES
- EXIT SIGN MOUNTING
    - WALL FIXTURE: CENTER 12" ABOVE DOOR OPENING.
    - CEILING FIXTURE: ON CEILING OR AT HEIGHT SPECIFIED ON DRAWINGS.
    - PENDANT FIXTURE: MATCH HEIGHT OF EXISTING PENDANT MOUNTED EXIT SIGNS. IF STORE DOES NOT HAVE PENDANT MOUNTED EXIT SIGNS, THEN PENDANT MOUNT SIGN 24" BELOW BOTTOM OF BAR JOIST.
    - VERIFY MOUNTING HEIGHT WITH AHJ.
    - COMBINE LOCATIONS OF EXIT SIGNS TO ENSURE STORE SIGNAGE DOES NOT OBSTRUCT THEIR VIEW.
    - THE USE OF TRITIUM BASED RADIOACTIVE EXIT SIGNAGE IS PROHIBITED.
  - EMERGENCY LIGHT FIXTURE INSTALLATION
    - WALL FIXTURE: 12" BELOW FINISHED CEILING OR +15" IN AREAS OF EXPOSED STRUCTURE, UNLESS NOTED OTHERWISE.
    - PENDANT FIXTURE: BOTTOM CHORD OF BAR JOIST OR AT HEIGHT SPECIFIED ON DRAWINGS.
    - REMOTE HEAD FIXTURE: HEADS CENTERED ABOVE OPENING +4'-0", UNLESS NOTED OTHERWISE. BATTERY PACK MOUNTED ON TOP OF SIGN. 1" WALL 12" BELOW FINISHED CEILING OR A BAR JOIST IN AREAS OF EXPOSED STRUCTURE.
    - REFER TO MANUFACTURER'S WRITTEN INSTRUCTIONS FOR BATTERY TO CHARGE CONTINUOUSLY FOR A MINIMUM OF 24 HOURS BEFORE INITIAL TESTING.
    - EMERGENCY LIGHT HAS BEEN POWERED. NOT TURN OFF FOR EXTENDED PERIODS OF TIME.
  - EXIT SIGNS, EMERGENCY LIGHTS AND NIGHT LIGHTS SHALL NOT BE SWITCHED.
  - IN AREAS OF OPEN STRUCTURE, MOUNT STRIP FIXTURE TO BOTTOM CHORD OF BAR JOIST, UNLESS NOTED OTHERWISE.
  - PROVIDE SEPARATE BOXES FOR GANGED SWITCHES ON SEPARATE BRANCH CIRCUITS.
  - FIXTURES DENOTED WITH "A&J" ARE TO BE FASTENED ON UNISTRUT CHANNELS MOUNTED TO THE BOTTOM SIDE OF THE TOP CHORD OF BAR JOISTS. LOCATE THE FIXTURES RUNNING PERPENDICULAR TO BAR JOISTS WITHIN BAR JOISTS WEBSING SPACES. DO NOT FASTEN FIXTURE OR UNISTRUT CHANNELS TO ROOF DECK.

- ### KEYNOTES
- EXISTING LIGHT FIXTURES TO REMAIN UNLESS NOTED OTHERWISE.
  - EXISTING LIGHT FIXTURE TO BE DEMOLISHED.
  - CONNECT TO EXISTING CIRCUIT.
  - EXISTING LIGHT FIXTURES TO BE RELOCATED TO NEW LOCATION AS SHOWN.

**brr**  
 ARCHITECT OF RECORD  
 JOHN P. FRANK  
 8111 MEDICAL AVENUE  
 OVERLAND PARK, KS 66204  
 www.brrinc.com  
 TEL: 913-342-9909  
 FAX: 913-342-9904

STIPULATION FOR REUSE  
 THIS DRAWING HAS BEEN PREPARED FOR THE EXCLUSIVE USE OF THE CLIENT. IT IS THE PROPERTY OF HENDERSON ENGINEERS AND ARCHITECTS, INC. AND IS NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF HENDERSON ENGINEERS AND ARCHITECTS, INC. THE USER OF THIS DRAWING SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPROPRIATE AGENCIES AND AUTHORITIES.

CONSULTANTS  
**HENDERSON**  
 ENGINEERS  
 & ARCHITECTS, INC.  
 8845 LEBLANC DRIVE, SUITE 300  
 ATLANTA, GA 30338  
 TEL: 770.423.0000 FAX: 770.423.0001  
 WWW.HENDERSONENGINEERS.COM  
 GA. LICENSE NO. 1000000000  
 FL. LICENSE NO. 1000000000  
 CA. LICENSE NO. 1000000000  
 EXPRESS 00000001

Walmart  
**ATLANTA (GRESHAM)**  
 2427 GRESHAM RD SE 30316  
 STORE NO: 03709-233  
 JOB NUMBER: 216060706 | PHOTO: SP/BB

ISSUE BLOCK	

CHECKED BY: BC/BW  
 DRAWN BY: JRF  
 PHOTO CYCLE: 09/25/20  
 DOCUMENT DATE: 11/20/20

NOT FOR CONSTRUCTION

LIGHTING PLAN

SHEET: E1

**1 LIGHTING PLAN**  
 1" = 20'-0"

EXISTING LIGHTING FIXTURES NOT SHOWN ARE EXISTING TO REMAIN AND ARE NOT AFFECTED BY THE SCOPE OF WORK ON THIS PROJECT. THIS INCLUDES ALL GENERAL LIGHTING, EGRESS LIGHTING AND EXIT LIGHTING.

EXISTING CONDITIONS WERE TAKEN FROM ORIGINAL DRAWINGS AND MAY NOT REFLECT EXACT "AS-BUILT" CONDITIONS. CONTRACTOR SHALL FIELD VERIFY ALL EXISTING CONDITIONS PRIOR TO SUBMITTING FINAL BIDS. CONTRACTOR SHALL CAREFULLY COORDINATE NEW WORK AND DEMOLITION WITH ALL OTHER DISCIPLINES AND EXISTING CONDITIONS.

EACH SUBCONTRACTOR IS RESPONSIBLE FOR HAVING A THOROUGH KNOWLEDGE OF ALL DRAWINGS AND SPECIFICATIONS IN THEIR RELATED FIELD. THE FAILURE TO ACQUAINT THEMSELVES WITH THIS KNOWLEDGE DOES NOT RELIEVE THE RESPONSIBILITY OF PERFORMING THE WORK PROPERLY. NO ADDITIONAL COMPENSATION SHALL BE ALLOWED BECAUSE OF CONDITIONS THAT OCCUR DUE TO FAILURE TO FAMILIARIZE WORKERS WITH THIS KNOWLEDGE.

Order Plans @

www.LDILine.com

ADJUST AIMING OF EMERGENCY LIGHT LAMP HEADS AS REQUIRED TO PROVIDE PROPER ILLUMINATION AT FLOOR, AVOIDING OBSTACLES AND SHADOWS AFTER STORE SET-UP IS COMPLETE, TYP

TENANT FINISH OUT BY OTHERS UNDER A SEPARATE CONTACT