



STEEL COLUMN SCHEDULE			
MARK	SIZE	BASIS	REMARKS
SC-1	HSS 8x4	12x10x3/4	6\"/>

FOOTING SCHEDULE		
MARK	SIZE	REINFORCING
F20.12	2'-0\"/>	
F30	3'-0\"/>	
F40	4'-0\"/>	

MASONRY WALL SCHEDULE					
LABEL	TYPE	VERT. REINF. AT FULL HEIGHT SECTIONS	VERT. REINF. BELOW AND ABOVE OPENINGS (U.O.)	JAMBS EA. SIDE OF OPENING (U.O.)	ENDS AND CORNERS
MAIN BUILDING (TWALL = 21'-4\")	8\"/>				
MAIN BUILDING (TWALL = 24'-6\")	8\"/>				

MASONRY WALL NOTES:  
A) ALL MASONRY VERT. REINF. CELLS SHALL BE FILLED W/ 3000 PSI GROUT MIX, TYP.  
B) PROVIDE HORIZONTAL JOINT REINF. PER STRUCTURAL NOTES ON S201.

**1 FOUNDATION PLAN**  
1/4" = 1'-0"

**FOUNDATION NOTES:**

- 1) EL. = +0'-0" IS FOR REFERENCE ONLY. SEE CIVIL FOR NAVD ELEVATION.
- 2) [Symbol] DENOTES MASONRY WALLS. SEE SCHEDULE THIS SHEET.
- 3) [Symbol] DENOTES METAL STUD FRAMING, SEE ARCH FOR LOCATION AND EXTENTS, SEE S001.
- 4) SC-# DENOTES STEEL COLUMN, SEE SCHEDULE THIS SHEET.
- 5) MC-# DENOTES MASONRY COLUMN, SEE DETAIL ON S201.
- 6) F-# DENOTES CONCRETE FOOTINGS, SEE SCHEDULE ON THIS SHEET. TOP OF CONCRETE FOOTING ELEVATION = +4" BELOW TOP OF SLAB. BOTTOM OF ALL FOOTINGS SHALL BE 18" MIN. BELOW LOWEST ADJACENT FINISH GRADE. VERIFY ALL TOP AND BOTTOM OF FOOTING ELEVATIONS W/ CIVIL AND MEP PRIOR TO FABRICATION AND CONSTRUCTION.
- 7) T.E. DENOTES THICKENED EDGE, SEE SECTION.
- 8) [Symbol] DENOTES C.M.U. WALL CONTROL JOINT LOCATION, SEE DETAIL ON S201.
- 9) C.J. DENOTES SLAB ON GRADE CONTROL JOINT, SEE DETAIL ON S201.
- 10) SEE ARCH FOR DIMENSIONS NOT SHOWN.
- 11) SEE ARCH AND MEP FOR ALL SLEEVES, PIPES, INSERTS AND EMBEDDED ITEMS.
- 12) SEE ARCH AND MEP FOR SLAB ON GRADE SLOPES AND RECESSES.
- 13) CENTER ALL COLUMNS AND WALLS ON FOOTING U.O. ON PLAN OR SECTION.
- 14) G.C. VERIFY W/ARCH/MEP DRAWINGS FOR ROOF DRAIN LINES, STORM LINES, FIRE RISERS, AND SANITARY LINES.
- 15) FLOOR SINK OR FLOOR DRAIN, SEE ARCH FOR LOCATION AND EXTENTS. PROVIDE ADDITIONAL REINFORCING PER S201, TYP.
- 16) PROVIDE #5 AT 12" O.C. BOTTOM TRANSV. AT F20.12 FOOTING FOR 5 LF MIN., CENTERED W/ MASONRY COLUMN OR STEEL COLUMN PER PLAN, TYP.

**HIGGENBOTHAM**  
Structural Engineers  
3222 Corrine Drive, Suite F  
Orlando, Florida 32803  
Phone: 407 286 1787  
Fax: 407 286 2281  
FLORIDA, CA, NO. 28950

1925 Prospect Ave.  
Orlando, FL 32814  
P (407) 661-9100  
P (407) 661-9101  
www.ep.com  
Florida Corporate Certificate #AA 000626

**Ep**  
**Enhaci & Peterson**  
Architects Engineers Planners

CLIENT NAME  
**BLACKFIN PARTNERS INVESTMENTS, INC.**  
4400 PCA BLVD, SUITE 600  
PALM BEACH GARDENS, FL 33410

PROJECT NAME  
**7-ELEVEN #1795 - OCALA, FL**  
9000 BLOCK OF SE MARICAMP ROAD  
OCALA, FL 34470

JUAN B. CANO, P.E.  
FLORIDA LICENSE NO. 69377

PROJECT NO.	DATE	DRAWN	REVISION	CHECKED
2200365	12/17/2020	REE		JSC

**S101**