

GENERAL ELECTRICAL NOTES:

- "A1/E-501" INDICATES DETAIL NUMBER/SHEET NUMBER.
- "DP/1" INDICATES MATERIAL LIST ITEM IN HEX SYMBOL.
- (X) INDICATES KEY NOTE USED TO DESCRIBE ADDITIONAL INFORMATION OF WORK REQUIRED, SPECIFIC TO THE SHEET IT IS SHOWN ON.
- "NL" INDICATES FIXTURE IS UNSWITCHED FOR NIGHT LIGHT.
- ALL ELECTRICAL CONDUCTORS SHALL BE COPPER, U.O.N.
-
- ABBREVIATION KEY:
 EC ELECTRICAL CONTRACTOR
 GC GENERAL CONTRACTOR
 MC MECHANICAL CONTRACTOR
 C CONDUIT
 TYP TYPICAL
 UG UNDERGROUND
 +#* MOUNTING HEIGHT FROM FINISHED FLOOR TO CENTERLINE

ELECTRICAL INSTALLATION NOTES:

- THE COMPLETE INSTALLATION SHALL BE IN ACCORDANCE WITH THE A.D.A.A.G. (AMERICANS WITH DISABILITIES ACT ACCESSIBILITY GUIDELINES)
- CIRCUIT NUMBERS ARE SHOWN FOR CIRCUIT IDENTIFICATION. CIRCUITING SHALL AGREE WITH NUMBERING ON THE PANEL PROVIDED. WHERE COMMON NEUTRAL IS USED FOR TWO OR THREE CIRCUITS, EACH SHALL ORIGINATE FROM DIFFERENT PHASE LEGS OF THE PANEL BUS. COMMON NEUTRALS SHALL NOT BE USED FOR COMPUTER OR OFFICE RECEPTACLES. BALANCE THE LOAD ON PANEL AS EVENLY AS POSSIBLE BETWEEN EACH PHASE.
- CIRCUIT SERVING EXIT FIXTURES IN SALES AREA SHALL BE RUN IN SEPARATE CONDUIT FROM ALL OTHER CIRCUITS. INSTALL A MANUFACTURER'S LOCK-ON DEVICE ON CIRCUIT BREAKER FEEDING EMERGENCY EQUIPMENT.
- A #12 GREEN INSULATED GROUND CONDUCTOR SHALL BE INSTALLED WITH CIRCUIT CONDUCTORS TO ALL RECEPTACLES.
- FLUSH MOUNT ALL TOGGLE SWITCHES AT +48" FROM FINISHED FLOOR (CENTERLINE DIMENSION), EXCEPT WHERE OTHERWISE NOTED.
- FLUSH MOUNT ALL DUPLEX RECEPTACLES AND TELECOMMUNICATION OUTLETS AT HEIGHT FROM FINISHED FLOOR TO CENTERLINE AS NOTED ON PLANS.
- CONTRACTOR SHALL VERIFY ALL FURNITURE, MODULAR FURNITURE AND EQUIPMENT LOCATIONS WITH ARCHITECTURAL PLANS, ELEVATIONS AND REVIEWED SHOP DRAWINGS PRIOR TO ROUGH-IN. PRIOR TO MAKING THE ACTUAL ELECTRICAL INSTALLATION THIS CONTRACTOR SHALL ADJUST RECEPTACLES, OUTLETS OR CONNECTION LOCATIONS TO ACCOMMODATE FURNITURE AND/OR EQUIPMENT.
- BOXES LOCATED ON OPPOSITE SIDES OF NON-FIRE RATED WALLS SHALL BE OFFSET A MINIMUM OF 6" HORIZONTALLY. BOXES ON OPPOSITE SIDES OF FIRE RATED WALLS SHALL BE OFFSET A MINIMUM OF 24" HORIZONTALLY (IN DIFFERENT STUD SPACES). "THRU-THE-WALL" BOXES SHALL NOT BE ALLOWED WITHOUT PRIOR WRITTEN APPROVAL OF THE ARCHITECT/ENGINEER.
- ELECTRICAL EQUIPMENT SHALL BE INSTALLED TO AVOID INTERFERENCE WITH THE OPERATION OF AND/OR ACCESS TO OTHER EQUIPMENT. ALL MOUNTING OF ELECTRICAL ITEMS ON EQUIPMENT SUPPLIED BY ANOTHER CONTRACTOR SHALL BE APPROVED IN ADVANCE BY THE OTHER CONTRACTOR AND OWNER.
- ALL FINAL ELECTRICAL CONNECTIONS TO MOTORS AND EQUIPMENT SUBJECT TO VIBRATION SHALL BE MADE WITH FLEXIBLE METAL CONDUIT. USE LIQUIDTIGHT CONDUIT AND FITTINGS WHERE SUBJECT TO MOISTURE. ROUTE GROUND WIRE FROM CIRCUIT GROUND TO MOTOR GROUND THROUGH FLEXIBLE CONDUIT.
- CONTRACTOR SHALL BE RESPONSIBLE FOR ALL OPENINGS REQUIRED IN WALLS. ALL OPENINGS SHALL BE REPAIRED TO MATCH EXISTING BY A QUALIFIED CONTRACTOR AT THE EXPENSE OF THIS CONTRACTOR. ALL CONDUIT PENETRATIONS THROUGH BUILDING WALLS SHALL BE GROUDED OR SEALED CLOSED. WHERE CONDUIT PENETRATES WALLS AND FLOORS SEAL WITH A U.L. LISTED SEALANT. SEAL PENETRATIONS WITH INTUMESCENT CAULK, PUTTY, OR SHEET INSTALLED PER MANUFACTURER'S RECOMMENDATIONS. ALL MATERIALS USED TO SEAL PENETRATIONS OF FIRE WALLS AND FLOORS SHALL BE TESTED AND CERTIFIED AS A SYSTEM PER ASTM E814 STANDARDS FOR FIRE TESTS OR THROUGH PENETRATION FIRESTOPS AS MANUFACTURED BY 3M, THOMAS & BETTS, OR DUPONT.
- ALL CONDUIT SHALL BE CONCEALED IN WALLS, PARTITIONS OR ABOVE CEILING UNLESS OTHERWISE INDICATED ON THE PLANS OR IN THE SPECIFICATIONS. CONDUIT MAY BE EXPOSED IN BACKROOM TO DISTRIBUTION PANEL ONLY IN VERTICAL RUNS. IF NO CEILING IS INSTALLED, CONDUIT SHALL BE RUN JUST BELOW ROOF DECK AT BOTTOM OF UPPER CHORD OF ROOF JOISTS TO PREVENT POSSIBLE DAMAGE FROM ROOFING SYSTEMS ABOVE. COORDINATE LOCATIONS IN SALES AREA WITH MECHANICAL SYSTEM LOCATIONS. ALL CONDUIT SHALL BE PARALLEL AND/OR PERPENDICULAR TO THE BUILDING STRUCTURE UNLESS NOTED OR APPROVED BY ALDI REPRESENTATIVE.
- CONTRACTOR SHALL INSTALL AT EACH SERVICE ENTRANCE A PERMANENT DIRECTORY ACCORDING TO ARTICLE 230.2(E), OF THE NATIONAL ELECTRICAL CODE.
- ELECTRICAL CONTRACTOR SHALL PROVIDE ARCHITECTURAL WARNING LABELS FOR ALL DISCONNECT SWITCHES PER NFPA 70A AND NFPA 70B STANDARDS.


MATERIAL LIST				
ITEM	SYMBOL	DESCRIPTION	APPR'D	MFG
THE SYMBOLS AND THE MATERIAL LIST ARE FOR THE CONVENIENCE OF THE CONTRACTOR. EACH CONTRACTOR SHALL BE RESPONSIBLE FOR VERIFICATION OF QUANTITIES AND SHALL FURNISH ALL MATERIAL REQUIRED, WHETHER SPECIFIED OR NOT, TO PRODUCE A COMPLETE AND SATISFACTORY WORKING SYSTEM.				
CATALOG NUMBERS SHALL NOT BE CONSIDERED COMPLETE BUT ARE GIVEN ONLY TO AID THE CONTRACTOR IN THE SEARCH FOR MATERIAL. NO MATERIAL SHALL BE ORDERED BY MANUFACTURER AND CATALOG NUMBER ONLY. EACH CONTRACTOR SHALL FIRST READ THE COMPLETE DESCRIPTION OF THE MATERIAL ON THESE DRAWINGS AND SPECIFICATIONS. THE FIRST MANUFACTURER LISTED IS THE BASIS OF DESIGN. "STANDARD COLOR" INDICATES FACTORY FINISH COLORS AVAILABLE AT NO ADDITIONAL CHARGE.				
WHERE DEVICES ARE GANGED TOGETHER, THE PLATE SHALL BE OF THE GANGED STYLE FOR THE NUMBER AND TYPE OF DEVICES USED.				
ITEM	SYMBOL	DESCRIPTION	APPR'D	MFG
1	DEVICE COLOR	ALL SWITCH, RECEPTACLE AND OUTLET COLORS SHALL BE GRAY, UNLESS INDICATED OTHERWISE.	PASS & SEYMOUR	OR APPROVED EQUAL
2	COVER PLATES	ALL SWITCHES, RECEPTACLES, AND OUTLETS SHALL BE COMPLETE WITH COVERPLATES. COVERPLATES IN ALL SPACES SHALL BE STAINLESS STEEL UNLESS INDICATED OTHERWISE.	PASS & SEYMOUR HUBBELL BRYANT EAGLE LEVITON	OR APPROVED EQUAL
3	SWITCH - TOGGLE HANDLE, MAINTAINED CONTACT, SINGLE POLE, SINGLE THROW, SPECIFICATION GRADE, SIDE AND BACK WIRED, 20 AMP, 120/277 VOLT, U.L. LISTED.		PASS & SEYMOUR 521	OR APPROVED EQUAL
4	SWITCH - TOGGLE HANDLE, THREE WAY, SPECIFICATION GRADE, SIDE AND BACK WIRED, 20 AMP, 120/277 VOLT, U.L. LISTED.		PASS & SEYMOUR 523	OR APPROVED EQUAL
5	SWITCH - PUSH-BUTTON, DIGITAL TIMER, TIME OUT SETTING FROM 5 MIN-12 HOUR (SET TO 30 MIN WITH AUDIBLE ALERT ONLY), 120/277 VOLT, U.L. LISTED.		WATTS TOPPER T-400	OR APPROVED EQUAL
6a	CEILING MOUNTED 360° ULTRASONIC OCCUPANCY SENSOR, LINE VOLTAGE 120/277, 500 SQ FT COVERAGE		WATTS TOPPER #UT-355-1 HUBBELL #C0801500P120	
6b	CEILING MOUNTED 360° PASSIVE INFRARED OCCUPANCY SENSOR, LOW VOLTAGE, PROVIDE POWER PACK, 500 SQ FT COVERAGE.		WATTS TOPPER C120E-1 HUBBELL #COMINRS/LVPP	
6c	WALL MOUNTED - PASSIVE INFRARED OCCUPANCY SENSOR, 120/277 VOLT, U.L. LISTED, 30SEC-30MIN TIME DELAY		WATTS TOPPER #WS-250-W HUBBELL #LHRS1W	OR APPROVED EQUALS
7a	RECEPTACLE, DUPLEX - N.E.M.A. 5-20R 125 VOLT, 20 AMP, SPECIFICATION GRADE, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, U.L. LISTED.		PASS & SEYMOUR 5362	OR APPROVED EQUAL
7b	RECEPTACLE, DUPLEX - N.E.M.A. 5-20R 125 VOLT, 20 AMP, SPECIFICATION GRADE, TAMPER RESISTANT, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, U.L. LISTED.		PASS & SEYMOUR 885TR	OR APPROVED EQUAL
8	RECEPTACLE, DOUBLE DUPLEX (QUAD) - [2] N.E.M.A. 5-20R, 125 VOLT, 20 AMP, SPECIFICATION GRADE, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, U.L. LISTED. 'I' INDICATES ISOLATED GROUND TYPE WITH ORANGE NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, ORANGE COVERPLATE WITH 'ISO, GND.' STENCILED IN BLACK, U.L. LISTED.		PASS & SEYMOUR 5362	OR APPROVED EQUAL
9a	RECEPTACLE, GROUND FAULT DUPLEX - N.E.M.A. TYPE 5-15R, 125 VOLT, 15 AMP, SPECIFICATION GRADE, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, TEST AND RESET BUTTONS IN FACE, U.L. LISTED.		PASS & SEYMOUR 1591	OR APPROVED EQUAL
9b	RECEPTACLE, GROUND FAULT DUPLEX - N.E.M.A. TYPE 5-15R, 125 VOLT, 15 AMP, SPECIFICATION GRADE, TAMPER RESISTANT, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, TEST AND RESET BUTTONS IN FACE, U.L. LISTED.		PASS & SEYMOUR 1595TR	OR APPROVED EQUAL
10	RECEPTACLE, GROUND FAULT DUPLEX - N.E.M.A. TYPE 5-15R, 125 VOLT, 15 AMP, SPECIFICATION GRADE, WEATHER RESISTANT, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, TEST AND RESET BUTTONS IN FACE, U.L. LISTED, MOUNTED IN RECESSED BOX WITH GASKET AND EXTRA STAINLESS STEEL HANDLE, WEATHERPROOF WHILE-IN-USE COVER.		PASS & SEYMOUR #1591TRWR SPECIFICATION GRADE, WEATHER RESISTANT, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, TEST AND RESET BUTTONS IN FACE, U.L. LISTED, MOUNTED IN RECESSED BOX WITH GASKET AND EXTRA STAINLESS STEEL HANDLE, WEATHERPROOF WHILE-IN-USE COVER.	
11	RECEPTACLE, GROUND FAULT DUPLEX - N.E.M.A. TYPE 5-15R, 125 VOLT, 15 AMP, SPECIFICATION GRADE, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, TEST AND RESET BUTTONS IN FACE, U.L. LISTED, N.E.M.A. 3R RATED WHILE IN USE, CLEAR NON-LOCKING TYPE, STANDARD WITH VERTICAL MOUNT, U.L. LISTED.		PASS & SEYMOUR 1591-3703	OR APPROVED EQUAL
12	RECEPTACLE, SOLID GROUND DUPLEX - N.E.M.A. 5-20R, 125 VOLT, 20 AMP, SPECIFICATION GRADE, 3 WIRE GROUNDING TYPE, ORANGE NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, TEST AND RESET BUTTONS IN FACE WITH 'ISO, GND.' STENCILED IN BLACK, U.L. LISTED.		PASS & SEYMOUR 1G56300	OR APPROVED EQUAL
13a	RECEPTACLE, SIMPLEX - N.E.M.A. 15-20, 125 VOLT, 15 AMP, 3 WIRE GROUNDING, SPECIFICATION GRADE, MOUNTED IN CAST BOX, RECEPTACLE SHALL BE WATER TIGHT WITH THE WIPED CAP OR PLUG IN PLACE, FURNISH MATCHING PLUG AND INSTALL ON SUMP PUMP.		CROUSE-HINDS D596 D592D	
13b	RECEPTACLE, SIMPLEX - N.E.M.A. 5-20R 125 VOLT, 20 AMP, SPECIFICATION GRADE, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, U.L. LISTED.		PASS & SEYMOUR 5361	OR APPROVED EQUAL
14	JUNCTION BOX - 4 SQUARE GALVANIZED STEEL WITH METAL COVER, MOUNTED AS HIGH AS POSSIBLE. REFER TO DETAILS ON E501 FOR CONNECTIONS TO CHECKOUT.		STEEL CITY OR APPROVED EQUAL	
15	LOCKING RECEPTACLE, N.E.M.A. TYPE L15-20, 250 VOLT, 20 AMP, 3 PHASE GROUNDING, TWIST LOCK, FLUSH MOUNT.		HUBBELL 42DA OR APPROVED EQUAL.	
16	JUNCTION BOX - 4x4" SQUARE GALVANIZED STEEL WITH METAL COVER.		STEEL CITY OR APPROVED EQUAL.	
17	TELEPHONE/VOICE ONLY OUTLET - SINGLE GANG RECESSED BOX WITH COVER AND 3/4" CONDUIT TO ABOVE CEILING OR TO JOIST WEB, VERIFY LOCATION.		STEEL CITY OR APPROVED EQUAL.	
18	DUPLEX VOICE/DATA OUTLET - SINGLE GANG RECESSED BOX WITH COVER AND 3/4" CONDUIT TO ABOVE CEILING (UNLESS OTHERWISE NOTED), VERIFY LOCATION.		STEEL CITY OR APPROVED EQUAL.	
19	POWER WALL - FURNISHED BY ALDI INSTALLED BY E.C.		FURNISHED BY ALDI INSTALLED BY E.C.	
20	DISCONNECT SWITCH, GENERAL DUTY 3 POLE, NON-FUSIBLE, 3 WIRE, 240 VOLT, 60 AMP, NEMA 1 ENCLOSURE.		SQUARE "D" DU322 GENERAL ELECTRIC CUTLER HAMMER SIEMENS	
21	DISCONNECT SWITCH, GENERAL DUTY 3 POLE, NON-FUSIBLE, 3 WIRE, 240 VOLT, 30 AMP, NEMA 3R ENCLOSURE.		SQUARE "D" DU321R8 GENERAL ELECTRIC CUTLER HAMMER SIEMENS	
22	DISCONNECT SWITCH, GENERAL DUTY 3 POLE, NON-FUSIBLE, 3 WIRE, 240 VOLT, 30 AMP, NEMA 1 ENCLOSURE.		SQUARE "D" DU321 GENERAL ELECTRIC CUTLER HAMMER SIEMENS	
23	DISCONNECT SWITCH, GENERAL DUTY 3 POLE, NON-FUSIBLE, 3 WIRE, 240 VOLT, 100 AMP, NEMA 3R ENCLOSURE.		SQUARE "D" DU323R8 GENERAL ELECTRIC CUTLER HAMMER SIEMENS	
24	DISCONNECT SWITCH, GENERAL DUTY 3 POLE, FUSIBLE, 4 WIRE, 240 VOLT, 400 AMP, NEMA 1 ENCLOSURE.		SQUARE "D" D325N GENERAL ELECTRIC CUTLER HAMMER SIEMENS	
25	DISCONNECT SWITCH, GENERAL DUTY 3 POLE, NON-FUSIBLE, 3 WIRE, 240 VOLT, 100 AMP, NEMA 1 ENCLOSURE.		SQUARE "D" DU323 GENERAL ELECTRIC CUTLER HAMMER SIEMENS	

ITEM	SYMBOL	DESCRIPTION	APPR'D	MFG
26	MANUAL SWITCH, 120 VOLT, 30 AMP, 2 POLE, SURFACE MOUNT, NO OVERLOADS, NEMA 1 ENCLOSURE.		SQUARE "D" CLASS 25 1D K01 GENERAL ELECTRIC CUTLER HAMMER SIEMENS	
27	VIBRATING BELL - 24 VOLT AC, 92 DB AT 10' FEET, 6" DIAMETER GONG, REFER TO DIAGRAM ON E-501.		EDWARDS #340-A-G5 OR APPROVED EQUAL	
28	BUZZER - 24 VOLT AC, 70 DB AT 10' FEET, MOUNT ON OUTSIDE OF SINGLE GANG STAINLESS STEEL BOX PER MANUFACTURER, REFER TO DIAGRAM ON E-501.		EDWARDS #340A-G5 OR APPROVED EQUAL	
29	BUZZER - 24 VOLT AC, 84 DB AT 10' FEET, MOUNT ON OUTSIDE OF SINGLE GANG STAINLESS STEEL BOX PER MANUFACTURER, REFER TO DIAGRAM ON E-501.		EDWARDS #123A-G5 OR APPROVED EQUAL	
30	CHIME - 24 VOLT AC, 81 DB AT 10' FEET, SURFACE MOUNT PER MANUFACTURERS INSTRUCTIONS TO STAINLESS STEEL BOX, REFER TO DIAGRAM ON E-501.		EDWARDS #338-G5 OR APPROVED EQUAL	
31	TRANSFORMER - 120 VOLT PRIMARY, 24 VOLT AC SECONDARY, 100 VA, MOUNT ON PANEL 'L2', REFER TO DIAGRAM ON E-301 & E-501.		EDWARDS #8B-100 OR APPROVED EQUAL	
32	PUSHBUTTON - SURFACE MOUNT, WEATHERPROOF, 24 VOLT AC NORMALLY OPEN CONTACT, REFER TO DIAGRAM E-501.		TORKALIN #TA1788 OR APPROVED EQUAL	
33	PUSHBUTTON - SURFACE MOUNT, RECTANGULAR, BROWN HOUSING WITH IVORY BUTTON, 24 VOLT AC NORMALLY OPEN CONTACT, REFER TO DIAGRAM E-501.		EDWARDS #634 OR APPROVED EQUAL	
34	PUSHBUTTON - SNAP FIT IN 5/8" HOLE, BLACK BUTTON BASED 1/8" 24 VOLT AC, 1/2" 24 AMP CONTACT, REFER TO DIAGRAM E-501.		TORKALIN #TA1788 OR APPROVED EQUAL	
35	PANIC ALARM PUSHBUTTON - MOUNT ON WALL 6" AC OVER THE ENTRANCE. PROVIDE 2x4" BOX WITH 1/2" CONDUIT TO ALARM PANEL. VERIFY WITH ARCHITECTURAL DRAWINGS AND OWNERS REP. REFER TO OWNERS REPRESENTATIVE			
36	KEY PAD - E.C. SHALL PROVIDE 2x4" BOX WITH 1/2" CONDUIT TO ABOVE CEILING, OR BOTTOM OF ROOF DECK (IF NO CEILING).		STEEL CITY OR APPROVED EQUAL.	
37	JUNCTION BOX SINGLE GANG - GALVANIZED STEEL WITH METAL COVER, RECESSED MOUNT, 3/4" CONDUIT EXTENDED TO ABOVE CEILING UNLESS OTHERWISE NOTED.		STEEL CITY OR APPROVED EQUAL.	
38	KEY PAD - E.C. SHALL PROVIDE RECESSED 2x4" BOX WITH 3/4" CONDUIT TO ABOVE CEILING, BOTTOM OF ROOF DECK (IF NO CEILING).		STEEL CITY OR APPROVED EQUAL.	
39	JUNCTION BOX - 4" SQUARE GALVANIZED STEEL WITH METAL COVER, PROVIDE 1/2" CONDUIT TO HOUSE REMOTE DETEX DOOR ALARM SOUNDER.		STEEL CITY OR APPROVED EQUAL.	
40	SURFACE MOUNTED 6" SQ. DEEP JUNCTION BOX, GALVANIZED STEEL WITH METAL COVER		STEEL CITY OR APPROVED EQUAL.	
41	OVERHEAD DOOR CONTACT LOCATION - PROVIDE 3/4" CONDUIT FROM 6" ABOVE DOOR HEAD TO BOTTOM OF ROOF DECK.			
42	TEMPERATURE SENSOR - PROVIDE SINGLE GANG BOX WITH MINIMUM 3/4" CONDUIT TO ABOVE CEILING.		STEEL CITY OR APPROVED EQUAL.	
43	FACILITY STATUS DISPLAY - PROVIDE MINIMUM 3/4" CONDUIT TO ABOVE CEILING.			
44	SMOKE DETECTOR - DUCT TYPE, IONIZATION, 120 VOLT OPERATION, 4 WIRE, CLASS "B" WIRING, SAMPLING TUBES AND HOUSING FOR MOUNTING IN AIR DUCT PER MANUFACTURERS INSTRUCTIONS, 2 FORM "C" CONTACTS RATED FOR 10 AMPS, COMPLETE WITH BACK BOX, BASE AND MOUNTING HARDWARE, REMOTE KEYED TEST STATION WITH POWER AND ALARM INDICATORS. REFER TO MECHANICAL DRAWINGS FOR MODEL # AND STYLE.		FURNISHED AND INSTALLED BY M.C. WIRED BY E.C.	
45	ELECTRIC HAND DRYER - ADA COMPLIANT UNIVERSAL VOLTAGE, 950WATT TOTAL, STAINLESS STEEL COVER, SURFACE MOUNT, 35 SECOND TIME CYCLE, 16,000 LFM FAN.		EXCEL DRYER THINAIR #TA 58	
46	RECEPTACLE, SIMPLEX, WITH MATCHING PLUG - N.E.M.A. L5-30R AND L5-30P, 125 VOLT, 30 AMP, SPECIFICATION GRADE, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, TWIST LOCK, U.L. LISTED.		PASS & SEYMOUR L5-30P L5-30R OR APPROVED EQUAL	
47	RECEPTACLE, SIMPLEX, WITH MATCHING PLUG - N.E.M.A. L14-20R AND L14-20P, 125/250 VOLT, 20 AMP, SPECIFICATION GRADE, 4 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, U.L. LISTED.		PASS & SEYMOUR L14-20P L14-20R OR APPROVED EQUAL	
48	CARD READER - PROVIDE SINGLE GANG BOX WITH MINIMUM 1/2" CONDUIT TO JUNCTION BOX MOUNTED AT ROOF DECK ABOVE EXTERIOR E-COMMERCE DOOR. IF CARD READERS ARE NOT INSTALLED PROVIDE BLANK COVER PAINTED TO MATCH SURROUNDING SURFACES. REFER TO ARCH ELEVATIONS FOR MOUNTING HEIGHT.		STEEL CITY OR APPROVED EQUAL.	
49	DOOR CONTACT - PROVIDE SINGLE GANG BOX WITH MINIMUM 1/2" CONDUIT TO JUNCTION BOX MOUNTED AT ROOF DECK ABOVE EXTERIOR E-COMMERCE DOOR.		STEEL CITY OR APPROVED EQUAL.	
50	ELECTRIC DOOR STRIKE - PROVIDE DOOR FRAME BOX WITH MINIMUM 1/2" CONDUIT TO JUNCTION BOX MOUNTED AT ROOF DECK ABOVE EXTERIOR E-COMMERCE DOOR.		STEEL CITY OR APPROVED EQUAL.	

Issued:	Date:
A Client Review Set	01/21/21
B Permit Set	02/03/21
C Bid Set	02/12/21
D	
Revisions:	Date:
1	
2	
3	
4	
5	
6	
7	
8	
9	

DO NOT SCALE PLANS

Copying, Printing, Software and other processes required to produce these prints can stretch or skew the actual paper of layout. Therefore, scaling of this drawing may be inaccurate. Contact us consultants with any need for additional dimensions or clarifications.




ms consultants, inc.
 engineers, architects, planners
 5444 Wade Park Blvd.
 Suite160
 Raleigh, NC 27607-4299
 phone 919.772.5565
 fax 919.779.2308

DRAWN BY:	RWN
REVIEWED BY:	KFF

Seal ENGINEER FIRM LICENSE #C-3239

PROFESSIONAL OF RECORD:
 JASON E. CHRISTOFF No. 6201061051
 EXP. DATE: 10/31/2020



ALDI Inc.
 Store No. 87
 2526 Freedom Dr
 Charlotte, NC 28208
 Mecklenburg County
 Project Name & Location:

Material List & Notes	
Drawing Name:	
Prototype Rls. 06/03/20	Project No. 40452-30
Type 100x154 FMR	
	E-001
Scale: As Noted	Drawing No.