

	1	2	3	4	5	6
E	<p>GENERAL NOTES</p> <p>1. ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH: (A) NFPA 70-2017 (NATIONAL ELECTRICAL CODE); (B) ANSI C2-2017 (NATIONAL ELECTRICAL SAFETY CODE); (C) THE NATIONAL ELECTRICAL CONTRACTORS' ASSOCIATION (NECA); (D) APPLICABLE LOCAL CODES AND FEDERAL AND STATE LAWS.</p> <p>2. ELECTRICAL DRAWINGS ARE PARTIALLY DIAGRAMMATIC. REFER TO ARCHITECTURAL, STRUCTURAL, AND CIVIL DRAWINGS FOR GUIDANCE ON DIMENSIONS, DETAILS, AND LOCATIONS OF DUCTS AND PIPES. INSTALL THE ELECTRICAL SYSTEMS WITHOUT INTERFERING WITH PIPES, STRUCTURAL STEEL, OR OTHER SYSTEMS.</p> <p>3. NOT ALL SYMBOLS INCLUDED IN THE SYMBOLS LEGEND ARE USED IN THESE PLANS. FOR EACH SYMBOL THAT IS USED IN THESE PLANS, REFER TO SCHEDULES, NOTES, DETAILS, AND SPECIFICATIONS FOR REQUIREMENTS BEYOND THOSE EXPRESSED IN THE SYMBOL DEFINITION.</p> <p>4. WHERE PLANS INDICATE A REQUIREMENT FOR INSTALLATION OF CONDUIT AND WIRING BETWEEN TWO POINTS BUT DO NOT SHOW THE CONDUIT ROUTE, THE SPECIFIC ROUTE SHALL BE DETERMINED BY CONTRACTOR BASED ON FIELD CONDITIONS.</p> <p>5. MINIMUM DEPTH FOR CONDUIT IS 24" BELOW FINISHED GRADE TO TOP OF CONDUIT, UNLESS INDICATED OTHERWISE. CIVIL DRAWINGS OVERRULE THE ELECTRICAL DRAWINGS ON THE TOPIC OF CONDUIT BURIAL DEPTHS.</p> <p>6. EVERY USED CONDUIT ENTERING AN ENCLOSURE FROM BELOW GRADE SHALL BE SEALED WITH 3M MODEL 08578 STRIP CAULK. EVERY SPARE CONDUIT ENTERING AN ENCLOSURE FROM BELOW GRADE SHALL BE SEALED WITH A THREADED PVC CAP. ROUTE TRACER WIRE THROUGH A HOLE DRILLED IN THE PVC CAP AND USE SILICONE CAULK TO SEAL THE TRACER WIRE PENETRATION.</p> <p>7. SEAL CONDUIT PENETRATIONS OF BELOW-GRADE ENCLOSURES USING CONCRETE.</p> <p>8. THE TERM "CONDUIT" AS USED ON THIS PROJECT DOES NOT IMPLY A QUANTITY OF ONE SINGLE CONDUIT; THE TERM IS ALSO APPLIED TO ARRANGEMENT OF MULTIPLE CONDUITS IN A DUCT BANK. SEE PLANS FOR CONDUIT QUANTITIES.</p> <p>9. INSTALL ALL POWER AND COMMUNICATIONS CIRCUITS IN INDIVIDUAL CONDUITS UNLESS SPECIFIED OTHERWISE ON DRAWINGS.</p> <p>10. PROVIDE GROUNDING AS SHOWN ON PLANS AND ALL ELECTRICAL PANELS AND EQUIPMENT, BUILDINGS, STRUCTURES, AND FOUNDATIONS, EQUIPMENT PADS AND RACKS, RTG RAILS, ALL HIGH MAST LIGHTING AND ANTENNAS, AND CHAIN LINK FENCE (NOT TO EXCEED 200' BETWEEN GROUND RODS), PROVIDE GROUND RODS (3/4"x10'-0") AND MINIMUM #40 BARE COPPER WIRE (UON). USE EXOTHERMIC WELDS FOR ALL BELOW-GRADE GROUNDING CONNECTIONS.</p> <p>11. "PROVIDE" IS DEFINED TO MEAN THAT THE CONTRACTOR SHALL FURNISH, INSTALL, ADJUST, TEST AND INTEGRATE INTO A COMPLETE SYSTEM THE ITEM INDICATED, INCLUDING ALL HARDWARE, WIRING, AND MISCELLANEOUS ITEMS AS NECESSARY FOR A COMPLETE AND OPERATIONAL SYSTEM.</p> <p>12. UNLESS SPECIFICALLY NOTED TO BE EXISTING, ALL WORK AND MATERIAL SHOWN ARE NEW AND SHALL BE PROVIDED BY THE CONTRACTOR. THE CONTRACTOR SHALL FURNISH ALL LABOR, MATERIAL, EQUIPMENT, APPURTENANCES, SERVICES AND SUPERVISION FOR A COMPLETE ELECTRICAL SYSTEM AS SHOWN ON THE DRAWINGS. ALL MATERIAL AND EQUIPMENT SHALL BE WORKED INTO A COMPLETE, CONVENIENT, AND ECONOMICAL SYSTEM OR SYSTEMS. ALL APPARATUS, PARTS, MATERIAL, AND ACCESSORIES WHICH ARE NECESSARY TO ACCOMPLISH THIS RESULT SHALL BE PROVIDED AND SHALL INCLUDE OTHER EQUIPMENT SELECTIONS TO MEET THE PARAMETERS INDICATED. MANUFACTURER'S INSTRUCTIONS, WRITTEN OR OTHERWISE, SHALL BE FOLLOWED UNLESS SUPERSEDED HEREIN.</p> <p>13. THE CONTRACTOR SHALL CLOSELY STUDY THE CONSTRUCTION SEQUENCE AND NOTES AS OUTLINED. SLIGHT DEVIATIONS FROM WORK SPACES MAY BE NECESSARY TO FULLY COMPLETE A CONSTRUCTION AREA AS OUTLINED ON THAT SHEET. THE DEVIATIONS SHALL BE HELD TO A MINIMUM AND SHALL BE FULLY COORDINATED WITH THE OWNER AND OWNER'S REP. ALL SUCH DEVIATIONS SHALL BE MADE WITH NO ADDITIONAL COST TO THE OWNER.</p> <p>14. THE CONTRACTOR SHALL VISIT THE SITE TO INVESTIGATE EXISTING CONDITIONS PRIOR TO BID. DOCUMENT ANY APPARENT DEVIATION BETWEEN EXISTING CONDITIONS OBSERVED AND THOSE INDICATED IN THE PLAN SET THAT MAY RENDER A PLAN REQUIREMENT INEXECUTABLE AND/OR UNSAFE. PROVIDE SAID DOCUMENTATION TO THE OWNER'S REPRESENTATIVE.</p> <p>15. IN THE EVENT THAT FIELD CONDITIONS BECOME APPARENT DURING CONSTRUCTION THAT RENDER A PLAN REQUIREMENT INEXECUTEABLE AND/OR UNSAFE, PROVIDE DOCUMENTATION OF SAID CONDITIONS TO THE OWNER'S REPRESENTATIVE. INCLUDE A SUGGESTED REMEDY AND ASSOCIATED MATERIAL, LABOR, AND COST ADJUSTMENTS REQUIRED TO PERFORM THE WORK. AWAIT DIRECTION FROM THE OWNER'S REPRESENTATIVE BEFORE PROCEEDING.</p> <p>16. CONDUIT ROUTINGS SHALL NOT INTERFERE WITH NEW OR EXISTING EQUIPMENT, PIPING, CONDUIT OR WORK AND SHALL NOT OBSTRUCT ACCESS TO ANY EQUIPMENT.</p> <p>17. A SEPARATE EQUIPMENT GROUNDING CONDUCTOR SHALL BE INSTALLED WITH EACH CIRCUIT. THE EQUIPMENT GROUNDING CONDUCTOR SHALL BE INSTALLED AND CONNECTED IN A MANNER THAT ENSURES THAT THE REMOVAL OF ANY DEVICE OR EQUIPMENT DOES NOT DISRUPT THE CONTINUITY OF THE LOW IMPEDANCE FAULT CURRENT PATH BACK TO THE POWER SOURCE.</p> <p>18. HORSEPOWER RATINGS AND EQUIPMENT RATINGS ARE SHOWN FOR BASIS OF DESIGN. FRACTIONAL HORSEPOWER RATINGS ARE NOT SHOWN.</p> <p>19. THE CONTRACTOR SHALL VERIFY LOCATION, DIMENSIONS, AND ELECTRICAL CHARACTERISTICS OF ALL EQUIPMENT BEING FURNISHED BEFORE ROUGH-IN. THE CONTRACTOR SHALL ACCOUNT FOR DESIGN MODIFICATIONS NECESSARY TO PROPERLY INSTALL EQUIPMENT THAT DEVIATES IN ANY WAY FROM EQUIPMENT IDENTIFIED IN PLANS AS BASIS OF DESIGN. SAID MODIFICATIONS SHALL BE MADE AT NO ADDITIONAL COST TO THE OWNER.</p> <p>20. THE CONTRACTOR SHALL PROVIDE ALL WIRING, CONDUIT, AND ASSOCIATED APPURTENANCES FOR EQUIPMENT PROVIDED BY OTHERS, UNLESS OTHERWISE NOTED.</p> <p>21. THE CONTRACTOR SHALL EXAMINE THE CONTRACT DOCUMENTS AS A WHOLE. THE CONTRACTOR SHALL PROVIDE STARTERS, CIRCUITRY, PROTECTIVE DEVICES, AND ASSOCIATED APPURTENANCES FOR ALL EQUIPMENT REQUIRING POWER. THIS INCLUDES EQUIPMENT INDICATED ON ELECTRICAL PLANS AS WELL AS EQUIPMENT REQUIRED BY SPECIFICATIONS, ADDITIONAL PLANS, SCHEDULES, BILLS OF MATERIALS, AND ANY OTHER DOCUMENTS INCLUDED IN THE COMPLETE SET OF CONSTRUCTION DOCUMENTS PROVIDED TO THE CONTRACTOR BY THE OWNER.</p> <p>22. PROVIDE HACR TYPE CIRCUIT BREAKERS FOR MECHANICAL TYPE EQUIPMENT.</p> <p>23. PROVIDE A CIRCUIT DIRECTORY IN EACH PANELBOARD IN ACCORDANCE WITH NEC SECTION 408.</p> <p>24. COORDINATE INSTALLATION OF NEW DEVICES AND EQUIPMENT WITH EXISTING DEVICES AND EQUIPMENT. PROVIDE ALL MATERIALS AND LABOR NECESSARY TO ACHIEVE A FUNCTIONALLY AND AESTHETICALLY COHESIVE INSTALLATION.</p> <p>25. PROVIDE A #12 (MIN.) COPPER TRACER WIRE WITH INSULATION THAT IS NOT WHITE, GRAY, OR GREEN IN COLOR IN ALL NEW SPARE CONDUITS. THE TRACER WIRE MAY ALSO SERVE AS THE FILL CONDUCTOR IN ADDITION TO THE FOIL BACKED WARNING TAPE. EVERY SPARE CONDUIT SHALL BE LABELED ON EACH END WITH DESTINATION.</p> <p>26. PAINT ALL SURFACE MOUNTED CONDUITS TO MATCH ADJACENT SURFACE UNLESS OTHERWISE NOTED.</p> <p>27. PROVIDE 6'-0" CLEARANCE IN ALL DIRECTIONS FROM EACH GENERATOR.</p> <p>28. VERIFY THE LOCATION OF ALL EXISTING UTILITIES PRIOR TO PERFORMING ANY SITE MODIFICATIONS.</p> <p>29. PROVIDE NEW WIRING DEVICE CIRCUIT LABELS AND PANELBOARD DIRECTORIES FOR EXISTING ITEMS THAT ARE MODIFIED.</p> <p>30. UNLESS NOTED OTHERWISE, ALL WIRING SHALL BE COPPER, UL LISTED, RATED FOR 600 VOLTS, TYPE THHN/THWN, NO. 12 AWG MINIMUM. CONDUCTORS LARGER THAN NO. 12 AWG AND CONTROL, INSTRUMENTATION, AND COMMUNICATIONS CONDUCTORS SHALL BE STRANDED.</p>					
D	<p>31. DRAWINGS ARE BASED ON EXISTING PLANS AND NON-DESTRUCTIVE FIELD INVESTIGATIONS. THE CONTRACTOR SHALL VISIT THE EXISTING SITE AND FAMILIARIZE THEMSELVES WITH THE EXISTING CONDITIONS.</p> <p>32. PROVIDE ELECTRICAL DEMOLITION WORK AS INDICATED AND AS NECESSARY TO EXECUTE NEW WORK. REROUTE AND RECONNECT ANY CIRCUITS THAT WILL REMAIN IN USE THAT MUST BE TEMPORARILY DISCONNECTED IN ORDER TO EXECUTE OTHER WORK REQUIRED BY THESE PLANS.</p> <p>33. COORDINATE WITH THE OWNER AND TURN OVER REQUESTED EQUIPMENT (E.G. SWITCHBOARDS, LIGHTING CONTROL PANELS, MARINE PEDESTALS). REMAINING MATERIAL BEING REMOVED UNDER DEMOLITION SHALL BECOME THE PROPERTY OF THE CONTRACTOR AND SHALL BE REMOVED COMPLETELY FROM THE SITE, UNLESS OTHERWISE NOTED.</p> <p>34. EXISTING CONDUITS THAT WILL NOT BE REUSED SHALL BE REMOVED WHERE THEY WILL BE EXPOSED AFTER COMPLETION OF CONSTRUCTION DOWN TO 2' BELOW FINISHED GRADE. REMOVE ALL WIRING FROM ABANDONED CONDUITS. CUT-OFF ABANDONED CONDUITS 2' BELOW THE FINISHED SURFACE.</p> <p>35. UNLESS DESIGNATED FOR MODIFICATION BY THESE PLANS, ANY EXISTING ELECTRICAL CONDUIT, WIRING, EQUIPMENT, OR ASSOCIATED SUPPORT STRUCTURE THAT IS MODIFIED DURING CONSTRUCTION SHALL BE RESTORED TO ITS PREVIOUS CONDITION AT SOLE COST TO THE CONTRACTOR.</p> <p>36. WHERE A DEVICE IS DESIGNATED FOR REMOVAL, REMOVE JUNCTION BOXES, WIRE, CONDUIT, AND ALL ASSOCIATED APPURTENANCES FROM THE CONNECTED DEVICE TO THE NEXT ACTIVE DEVICE, JUNCTION BOX, OR POWER SOURCE.</p> <p>37. COORDINATE ALL ELECTRICAL SERVICE REQUIREMENTS WITH UTILITY.</p> <p>38. THE UTILITY, GEORGIA POWER, POINT OF CONTACT IS BILL KOSKIEWICZ (912-306-2137, WTKOSKIE@SOUTHERNCO.COM)</p> <p>39. THE GC SHALL SUBCONTRACT WITH COMTRAN FOR ALL FIBER WORK. POC IS PHILLIP CLARK, 404-867-2566.</p> <p>40. LIGHTING FIXTURE CATALOG NUMBERS ARE INDICATIVE OF THE FIXTURE FEATURES REQUIRED. CONTRACTOR SHALL PROVIDE FIXTURES WITH THE PROPER TRIM, VOLTAGE AND OPTIONS NECESSARY FOR INSTALLATION.</p> <p>41. REGARDLESS OF CATALOG NUMBER, ALL EMERGENCY FIXTURES SHALL BE PROVIDED MEANS OF BACKUP POWER.</p> <p>42. CONNECT EXIT SIGNS AHEAD OF LOCAL SWITCHING.</p>					
C	<p>31. DRAWINGS ARE BASED ON EXISTING PLANS AND NON-DESTRUCTIVE FIELD INVESTIGATIONS. THE CONTRACTOR SHALL VISIT THE EXISTING SITE AND FAMILIARIZE THEMSELVES WITH THE EXISTING CONDITIONS.</p> <p>32. PROVIDE ELECTRICAL DEMOLITION WORK AS INDICATED AND AS NECESSARY TO EXECUTE NEW WORK. REROUTE AND RECONNECT ANY CIRCUITS THAT WILL REMAIN IN USE THAT MUST BE TEMPORARILY DISCONNECTED IN ORDER TO EXECUTE OTHER WORK REQUIRED BY THESE PLANS.</p> <p>33. COORDINATE WITH THE OWNER AND TURN OVER REQUESTED EQUIPMENT (E.G. SWITCHBOARDS, LIGHTING CONTROL PANELS, MARINE PEDESTALS). REMAINING MATERIAL BEING REMOVED UNDER DEMOLITION SHALL BECOME THE PROPERTY OF THE CONTRACTOR AND SHALL BE REMOVED COMPLETELY FROM THE SITE, UNLESS OTHERWISE NOTED.</p> <p>34. EXISTING CONDUITS THAT WILL NOT BE REUSED SHALL BE REMOVED WHERE THEY WILL BE EXPOSED AFTER COMPLETION OF CONSTRUCTION DOWN TO 2' BELOW FINISHED GRADE. REMOVE ALL WIRING FROM ABANDONED CONDUITS. CUT-OFF ABANDONED CONDUITS 2' BELOW THE FINISHED SURFACE.</p> <p>35. UNLESS DESIGNATED FOR MODIFICATION BY THESE PLANS, ANY EXISTING ELECTRICAL CONDUIT, WIRING, EQUIPMENT, OR ASSOCIATED SUPPORT STRUCTURE THAT IS MODIFIED DURING CONSTRUCTION SHALL BE RESTORED TO ITS PREVIOUS CONDITION AT SOLE COST TO THE CONTRACTOR.</p> <p>36. WHERE A DEVICE IS DESIGNATED FOR REMOVAL, REMOVE JUNCTION BOXES, WIRE, CONDUIT, AND ALL ASSOCIATED APPURTENANCES FROM THE CONNECTED DEVICE TO THE NEXT ACTIVE DEVICE, JUNCTION BOX, OR POWER SOURCE.</p> <p>37. COORDINATE ALL ELECTRICAL SERVICE REQUIREMENTS WITH UTILITY.</p> <p>38. THE UTILITY, GEORGIA POWER, POINT OF CONTACT IS BILL KOSKIEWICZ (912-306-2137, WTKOSKIE@SOUTHERNCO.COM)</p> <p>39. THE GC SHALL SUBCONTRACT WITH COMTRAN FOR ALL FIBER WORK. POC IS PHILLIP CLARK, 404-867-2566.</p> <p>40. LIGHTING FIXTURE CATALOG NUMBERS ARE INDICATIVE OF THE FIXTURE FEATURES REQUIRED. CONTRACTOR SHALL PROVIDE FIXTURES WITH THE PROPER TRIM, VOLTAGE AND OPTIONS NECESSARY FOR INSTALLATION.</p> <p>41. REGARDLESS OF CATALOG NUMBER, ALL EMERGENCY FIXTURES SHALL BE PROVIDED MEANS OF BACKUP POWER.</p> <p>42. CONNECT EXIT SIGNS AHEAD OF LOCAL SWITCHING.</p>					
B	<p>31. DRAWINGS ARE BASED ON EXISTING PLANS AND NON-DESTRUCTIVE FIELD INVESTIGATIONS. THE CONTRACTOR SHALL VISIT THE EXISTING SITE AND FAMILIARIZE THEMSELVES WITH THE EXISTING CONDITIONS.</p> <p>32. PROVIDE ELECTRICAL DEMOLITION WORK AS INDICATED AND AS NECESSARY TO EXECUTE NEW WORK. REROUTE AND RECONNECT ANY CIRCUITS THAT WILL REMAIN IN USE THAT MUST BE TEMPORARILY DISCONNECTED IN ORDER TO EXECUTE OTHER WORK REQUIRED BY THESE PLANS.</p> <p>33. COORDINATE WITH THE OWNER AND TURN OVER REQUESTED EQUIPMENT (E.G. SWITCHBOARDS, LIGHTING CONTROL PANELS, MARINE PEDESTALS). REMAINING MATERIAL BEING REMOVED UNDER DEMOLITION SHALL BECOME THE PROPERTY OF THE CONTRACTOR AND SHALL BE REMOVED COMPLETELY FROM THE SITE, UNLESS OTHERWISE NOTED.</p> <p>34. EXISTING CONDUITS THAT WILL NOT BE REUSED SHALL BE REMOVED WHERE THEY WILL BE EXPOSED AFTER COMPLETION OF CONSTRUCTION DOWN TO 2' BELOW FINISHED GRADE. REMOVE ALL WIRING FROM ABANDONED CONDUITS. CUT-OFF ABANDONED CONDUITS 2' BELOW THE FINISHED SURFACE.</p> <p>35. UNLESS DESIGNATED FOR MODIFICATION BY THESE PLANS, ANY EXISTING ELECTRICAL CONDUIT, WIRING, EQUIPMENT, OR ASSOCIATED SUPPORT STRUCTURE THAT IS MODIFIED DURING CONSTRUCTION SHALL BE RESTORED TO ITS PREVIOUS CONDITION AT SOLE COST TO THE CONTRACTOR.</p> <p>36. WHERE A DEVICE IS DESIGNATED FOR REMOVAL, REMOVE JUNCTION BOXES, WIRE, CONDUIT, AND ALL ASSOCIATED APPURTENANCES FROM THE CONNECTED DEVICE TO THE NEXT ACTIVE DEVICE, JUNCTION BOX, OR POWER SOURCE.</p> <p>37. COORDINATE ALL ELECTRICAL SERVICE REQUIREMENTS WITH UTILITY.</p> <p>38. THE UTILITY, GEORGIA POWER, POINT OF CONTACT IS BILL KOSKIEWICZ (912-306-2137, WTKOSKIE@SOUTHERNCO.COM)</p> <p>39. THE GC SHALL SUBCONTRACT WITH COMTRAN FOR ALL FIBER WORK. POC IS PHILLIP CLARK, 404-867-2566.</p> <p>40. LIGHTING FIXTURE CATALOG NUMBERS ARE INDICATIVE OF THE FIXTURE FEATURES REQUIRED. CONTRACTOR SHALL PROVIDE FIXTURES WITH THE PROPER TRIM, VOLTAGE AND OPTIONS NECESSARY FOR INSTALLATION.</p> <p>41. REGARDLESS OF CATALOG NUMBER, ALL EMERGENCY FIXTURES SHALL BE PROVIDED MEANS OF BACKUP POWER.</p> <p>42. CONNECT EXIT SIGNS AHEAD OF LOCAL SWITCHING.</p>					
A	<p>31. DRAWINGS ARE BASED ON EXISTING PLANS AND NON-DESTRUCTIVE FIELD INVESTIGATIONS. THE CONTRACTOR SHALL VISIT THE EXISTING SITE AND FAMILIARIZE THEMSELVES WITH THE EXISTING CONDITIONS.</p> <p>32. PROVIDE ELECTRICAL DEMOLITION WORK AS INDICATED AND AS NECESSARY TO EXECUTE NEW WORK. REROUTE AND RECONNECT ANY CIRCUITS THAT WILL REMAIN IN USE THAT MUST BE TEMPORARILY DISCONNECTED IN ORDER TO EXECUTE OTHER WORK REQUIRED BY THESE PLANS.</p> <p>33. COORDINATE WITH THE OWNER AND TURN OVER REQUESTED EQUIPMENT (E.G. SWITCHBOARDS, LIGHTING CONTROL PANELS, MARINE PEDESTALS). REMAINING MATERIAL BEING REMOVED UNDER DEMOLITION SHALL BECOME THE PROPERTY OF THE CONTRACTOR AND SHALL BE REMOVED COMPLETELY FROM THE SITE, UNLESS OTHERWISE NOTED.</p> <p>34. EXISTING CONDUITS THAT WILL NOT BE REUSED SHALL BE REMOVED WHERE THEY WILL BE EXPOSED AFTER COMPLETION OF CONSTRUCTION DOWN TO 2' BELOW FINISHED GRADE. REMOVE ALL WIRING FROM ABANDONED CONDUITS. CUT-OFF ABANDONED CONDUITS 2' BELOW THE FINISHED SURFACE.</p> <p>35. UNLESS DESIGNATED FOR MODIFICATION BY THESE PLANS, ANY EXISTING ELECTRICAL CONDUIT, WIRING, EQUIPMENT, OR ASSOCIATED SUPPORT STRUCTURE THAT IS MODIFIED DURING CONSTRUCTION SHALL BE RESTORED TO ITS PREVIOUS CONDITION AT SOLE COST TO THE CONTRACTOR.</p> <p>36. WHERE A DEVICE IS DESIGNATED FOR REMOVAL, REMOVE JUNCTION BOXES, WIRE, CONDUIT, AND ALL ASSOCIATED APPURTENANCES FROM THE CONNECTED DEVICE TO THE NEXT ACTIVE DEVICE, JUNCTION BOX, OR POWER SOURCE.</p> <p>37. COORDINATE ALL ELECTRICAL SERVICE REQUIREMENTS WITH UTILITY.</p> <p>38. THE UTILITY, GEORGIA POWER, POINT OF CONTACT IS BILL KOSKIEWICZ (912-306-2137, WTKOSKIE@SOUTHERNCO.COM)</p> <p>39. THE GC SHALL SUBCONTRACT WITH COMTRAN FOR ALL FIBER WORK. POC IS PHILLIP CLARK, 404-867-2566.</p> <p>40. LIGHTING FIXTURE CATALOG NUMBERS ARE INDICATIVE OF THE FIXTURE FEATURES REQUIRED. CONTRACTOR SHALL PROVIDE FIXTURES WITH THE PROPER TRIM, VOLTAGE AND OPTIONS NECESSARY FOR INSTALLATION.</p> <p>41. REGARDLESS OF CATALOG NUMBER, ALL EMERGENCY FIXTURES SHALL BE PROVIDED MEANS OF BACKUP POWER.</p> <p>42. CONNECT EXIT SIGNS AHEAD OF LOCAL SWITCHING.</p>					



Rev.	Date	Description	Mark

GEORGIA PORTS AUTHORITY
GCT CAPACITY IMPROVEMENTS - PHASE 2

ELECTRICAL GENERAL NOTES

Designed by:	JAG	Date:	12/21/20
Dwn by:	BRL	MAN Project No.:	5531-264B
Reviewed by:	JHP	DAW	5531-264B
Submitted by:	MOFFATT & NICHOL	GPA Project No.:	1910-1011C
		Drawing Scale:	AS NOTED
		Plot scale:	1" = 10' (SHEET)

2 EAST BRYAN ST., STE 501
SAVANNAH, GA 31401
912.231.0044

moffatt & nichol

SEAL

Sheet Reference No.
E-001

INDEX: OF

BID ISSUE
ISSUED: 2021-02-03
NOT TO BE USED FOR CONSTRUCTION

DRAWING SCALES SHOWN BASED ON 22"x34" DRAWING

File: G:\16\16531-264-2020 Capacity Improvements\600 CAD\1_Achiev_Phase2\2020_Prel_Elec\5531264E-001.dwg, Plotted: 2/2/2021 11:21 AM by GREGG ALAN, Saved: 2/2/2021 10:34 PM by AGREGG