


Order Plans @ [www.idline.com](http://www.idline.com)




**NOTE**  
1. SIZE PER NEC TABLE 310.66, COPPER.

GENERATOR SCHEDULE (SEE SCHEDULE NOTE 1)						
GENERATOR SIZE (KW)	TYPICAL LENGTH A	TYPICAL WIDTH B	TYPICAL NEC/DOOR C	WATER JACKET (W)	AC ALTERNATOR HEATER (A)	BATTERY CHARGER (B)
15	72"	34"	36"	1500W/240V	250W/120V	100W/120V

**SCHEDULE NOTE**  
1. COORDINATE EXACT SIZE AND ALL CHARACTERISTICS WITH GENERATORS PROVIDED.


**C4** TYPICAL GENERATOR PLAN  
SCALE: NTS



**A4** CONCRETE GENERATOR PAD  
SCALE: NTS

**BID ISSUE**  
ISSUED: 2021-02-03  
NOT TO BE USED FOR CONSTRUCTION

DRAWING SCALES SHOWN BASED ON 22"x34" DRAWING



Mark	Description	Date	Appr

**GEORGIA PORTS AUTHORITY**  
GCT CAPACITY IMPROVEMENTS - PHASE 2  
**ELECTRICAL DETAILS**

Designed by: JAG	Date: 12/21/20	Rev:
Dwn by: BRL	MAN Project No: 5531-264B	
Reviewed by: JHP	DAW	
Submitted by: MOFFATT & NICHOL	GPA Project No: 1910-1011C	
	Drawing Scale: AS NOTED	
	Plot scale: 1:1 (0 SHEET)	

2 EAST BRYAN ST., STE 501  
SAVANNAH, GA 31401  
912.231.0044  
**moffatt & nichol**

SEAL

Sheet Reference No.  
**E-505**  
INDEX: OF