

**GENERAL CONSTRUCTION NOTES**

- CONTRACTOR SHALL NOTIFY CITY OF WEST POINT OFFICE 24 HOURS PRIOR TO WATER SYSTEM CONSTRUCTION AT (706) 645-3545.
- THE LOCATION OF EXISTING UTILITY LINES SHOWN ARE APPROXIMATE. THE APPROXIMATE POSITION OF CERTAIN UNDERGROUND UTILITIES AND STRUCTURES ARE SHOWN ACCORDING TO THE BEST AVAILABLE INFORMATION. THE CONTRACTOR IS RESPONSIBLE FOR DETERMINING THE EXACT LOCATION OF ALL UTILITIES PRIOR TO BEGINNING CONSTRUCTION. THE CONTRACTOR SHALL LOCATE, EXCAVATE, AND EXPOSE ALL EXISTING UNDERGROUND LINES IN ADVANCE OF TRENCHING AND OTHER CONSTRUCTION OPERATIONS. ANY DAMAGE DONE TO EXISTING UTILITIES SHALL BE REPAIRED OR REPLACED BY THE CONTRACTOR AT HIS OWN EXPENSE. THE CONTRACTOR MUST CALL UTILITIES PROTECTION, INC. "CALL BEFORE YOU DIG", TELEPHONE NUMBER 811.
- CONTRACTOR TO REMOVE ABANDONED GAS MAIN AS NEEDED TO ACCOMMODATE INSTALLATION OF NEW STORM DRAIN AND CUT SECTIONS. PRICE OF REMOVAL SHALL BE INCLUDED IN BID PRICE FOR OTHER ITEMS.
- CONTRACTOR SHALL PROVIDE SHOP DRAWINGS AS REQUIRED FOR THE APPROVAL OF THE ENGINEER AND CITY OF WEST POINT. THESE DRAWINGS SHALL BEAR THE CERTIFICATION THAT HE HAS REVIEWED.
- ALL EXCAVATION INCLUDING TRENCHING, BORE PITS, ETC. WITHIN THE ROADWAY CLEAR RECOVERY ZONE, SHALL BE BACKFILLED AT THE END OF EACH WORK DAY.
- THE ESCAPE OF SEDIMENT FROM THE SITE SHALL BE PREVENTED BY THE INSTALLATION OF EROSION AND SEDIMENT CONTROL MEASURES AND PRACTICES PRIOR TO, OR CONCURRENT WITH, LAND-DISTURBING ACTIVITIES.
- EROSION CONTROL MEASURES WILL BE MAINTAINED AT ALL TIMES. IF FULL IMPLEMENTATION OF THE APPROVED PLAN DOES NOT PROVIDE FOR EFFECTIVE EROSION CONTROL, ADDITIONAL EROSION AND SEDIMENT CONTROL MEASURES SHALL BE IMPLEMENTED TO CONTROL OR TREAT THE SEDIMENT SOURCE.
- CONTRACTOR SHALL RE-GRASS ALL DISTURBED AREAS IMMEDIATELY AFTER PIPELINE CONSTRUCTION.

**GAS NOTES**

- ALL GAS LINES SHALL BE IPS POLYETHYLENE UNLESS NOTED OTHERWISE.
- ALL FITTINGS AND BENDS SHALL BE BUTT WELDED OR ELECTRO-FUSED. CONTRACTOR SHALL INSTALL TWO (2) 45' BENDS IN LIEU OF ONE (1) 90' BEND WHEN ALIGNMENT PERMITS.
- THE MINIMUM COVER OVER THE TOP OF THE GAS LINE PIPE SHALL BE THREE FEET (3') AND MAXIMUM DEPTH OF COVER SHALL BE FOUR FEET (4') UNLESS OTHERWISE DIRECTED BY THE ENGINEER.

DWG. NO.	DESCRIPTION
44-0001	COVER
44-0002	GENERAL NOTES AND DRAWING INDEX
44-0003	SUMMARY SHEET
44-0004	UTILITY RELOCATION PLAN
44-0005	UTILITY RELOCATION PLAN
44-0006	CROSS SECTIONS
44-0007	CROSS SECTIONS
44-0008	CROSS SECTIONS
44-0009	CROSS SECTIONS
44-0010	CROSS SECTIONS
44-0011	CROSS SECTIONS

Order Plans @ [www.LDInking.com](http://www.LDInking.com)

PROPERTY AND EXISTING R/W LINE	
REQUIRE R/W LINE	
CONSTRUCTION LIMITS	
EASEMENT FOR CONSTR. & MAINTENANCE OF SLOPES	
EASEMENT FOR CONSTR. OF SLOPES	
EASEMENT FOR CONSTR. OF DRIVES	

BEGIN LIMIT OF ACCESS.....BLA	
END LIMIT OF ACCESS.....ELA	
LIMIT OF ACCESS	
REQ'D R/W AND LIMIT OF ACCESS	
ESA-SEE ENVIRONMENTAL RESOURCES IMPACT TABLE IN GENERAL NOTES FOR CONSTRUCTION RESTRICTIONS	



ATLANTA  
AUGUSTA  
ST. SIMONS ISLAND

REVISIONS DATES


STATE OF GEORGIA  
DEPARTMENT OF TRANSPORTATION  
CITY OF WEST POINT, GEORGIA  
UTILITY RELOCATION PLANS

PROJECT 0013999  
COUNTY TROUP

DRAWING No.  
44-0002