



LIGHTING FIXTURE SCHEDULE

TYPE	VOLTS	WATTAGE	DESCRIPTION	LIGHT SOURCE		COLOR TEMP.	MANUF. #1	MODEL #1	MANUF. #2	MANUF. #3	NOTES
				LUMENS	TYPE						
A1	120	16	VANDAL RESISTANT LINEAR WALL MOUNT	2,000	LED	3500 K	HE WILLIAMS	WMA-2-L20/835-AF-DRV-UNV	CERTOLUX	KENNA	
A2	120	30	ARCHITECTURAL EGRESS LIGHT	1,500	LED	3500 K	LUMINAIRE	WMA-4-L40/835-AF-DRV-UNV	CERTOLUX	KENNA	1
C	120	42	LENSED STRIP LIGHT	5,400	LED	3500 K	COLUMBIA	LCL4-35ML-EU	LITHONIA	PHILIPS	2
C-EM	120	42	LENSED STRIP LIGHT	5,400	LED	3500 K	COLUMBIA	LCL4-35ML-EU-ELL14	LITHONIA	PHILIPS	2
D	120	94	ANTI-MICROBIAL LENSED STRIP LIGHT	8,400	LED	3500 K	HUBBELL	SCS18-B-35LW-EU	LITHONIA	PHILIPS	
D-EM	120	94	ANTI-MICROBIAL LENSED STRIP LIGHT	8,400	LED	3500 K	HUBBELL	SCS18-B-35LW-EU	LITHONIA	PHILIPS	
F1	120	15	OPEN REFLECTOR DOWNLIGHT	1,500	LED	3500 K	HALO	HC615D010RMB22-HM6835-61WDW	PRESCOLITE	LIGHTOLIER	
F1-EM	120	15	OPEN REFLECTOR DOWNLIGHT	1,500	LED	3500 K	HALO	HC615D010REM14RMB22-HM6835-61WDW	PRESCOLITE	LIGHTOLIER	
F2	120	22	OPEN REFLECTOR DOWNLIGHT	2,000	LED	4000 K	HALO	HC620D010RMB22-HM6840-61WDW	PRESCOLITE	LIGHTOLIER	
F2-EM	120	22	OPEN REFLECTOR DOWNLIGHT	2,000	LED	4000 K	HALO	HC620D010REM14RMB22-HM612840-61WDW	PRESCOLITE	LIGHTOLIER	
FL1	120	22	10" IN-GRADE LED UPLIGHT	1,597	LED	4000 K	KIM LIGHTING	LTV82FFNF18L-4KUV	GARDCO	HYDREL	
H	120	25	11" ROUND VANDAL RESISTANT SURFACE MOUNT FIXTURE	10,700	LED	4000 K	FAILSAFE	TRE11-LD4-25W-40-OPL-BK-UNV-ED	LUMINAIRE	NEW STAR	
H-EM	120	25	11" ROUND VANDAL RESISTANT SURFACE MOUNT FIXTURE	10,700	LED	4000 K	FAILSAFE	TRE11-LD4-25W-40-OPL-BK-UNV-ED-SW/CL-17G	LUMINAIRE	NEW STAR	
P1	208	110	DIE CAST ALUMINUM RECTANGULAR AREA LIGHT	11,800	LED	4000 K	BEACON	VPS-48L-110-24W-UNV-A-1-T-F	LITHONIA	GARDCO	
P2	208	110	DIE CAST ALUMINUM RECTANGULAR AREA LIGHT	12,500	LED	4000 K	BEACON	VPS-48L-110-4K7-2-UNV-A-1-T-F	LITHONIA	GARDCO	
UT		0	UTILITY PROVIDED PARKING LOT AND DRIVEWAY LIGHTING		LED						

EQUIPMENT DATA SCHEDULE

ID	EQUIPMENT INFORMATION				CIRCUIT INFORMATION				STARTER			CONTROL		DISCONNECT		NOTES		
	FLA	MCA	MVA	VOLT	PANEL NO.	APPARENT LOAD	WIRE & CONDUIT SIZE	TYPE	FURNISH	INSTALL	FURNISH	INSTALL	TYPE	FURNISH	INSTALL			
AC-1				208	1	A	12,14	120 VA	(none)				MC	MC		MC	EC	2
CU-1			30.0	208	1	A	12,14	1830 VA	3/4" - 2#10, 1#10 GND				MC	MC		EC	EC	1,2
EF-1				120	1	A	3	240 VA	3/4" - 2#12, 1#12 GND				MC	MC				
EF-2				120	1	A	9	240 VA	3/4" - 2#12, 1#12 GND				MC	MC				
EF-3				115	1	A		240 VA	3/4" - 2#12, 1#12 GND				MC	MC				
EF-4				120	1	A	1	240 VA	3/4" - 2#12, 1#12 GND				MC	MC				
EH-1	12.5			277	1	MDP	3	3500 VA	3/4" - 3#12, 1#12 GND				MC	MC		MC	EC	4
EW1				208	3	A	6,8,10	10000 VA	1-1/4" - 3#4, 1#8 GND				PC	PC		EC	EC	1
HP-1		8.0	15.0	480	3	MDP	2	5318 VA	3/4" - 3#12, 1#12 GND				MC	MC		EC	EC	1

ABBREVIATIONS
 EC - ELECTRICAL CONTRACTOR P.C. - PLUMBING CONTRACTOR CC - CONTROL CONTRACTOR MS - MANUAL MOTOR STARTER NF - NON-FUSED
 VC - VENTILATING CONTRACTOR G.C. - GENERAL CONTRACTOR M.C. - MECHANICAL CONTRACTOR FS - FUSED SWITCH TS - MOTOR RATED TOGGLE SWITCH
 HC - HEATING CONTRACTOR S.C. - SPRINKLER CONTRACTOR (E) - EXISTING FWR - FULL VOLTAGE NON-REVERSING

NOTES:
 1. CONTRACTOR TO PROVIDE NEMA 3R DISCONNECT.
 2. POWER TO AC UNIT SUPPLIED VIA OUTDOOR CU UNIT. MECHANICAL CONTRACTOR TO SUPPLY POWER WIRING TO AC.
 3. RECEPTACLE PROVIDED WITH UNIT. ELECTRICAL CONTRACTOR TO PROVIDE WIRING.
 4. DISCONNECT PROVIDED WITH UNIT.

Order Plans @ WWWW.LDILine.com

Lancaster County, South Carolina
Heath Springs Soccer Complex

200 Boyd Falle Road
Heath Springs, SC 29058

△ Revisions:

Proj. No.: 80703
Date: 10/09/2020

Sheet Name:
LIGHTING AND
EQUIPMENT
SCHEDULES

E-602