



10/09/2020

PLUMBING FIXTURES

LEGEND		MOUNTING HEIGHT	SUPPLY			WASTE & VENT						FIXTURE	SUPPLY TRIM	SUPPLY/STOP	WASTE TRIM	API/DR	MISC.	SEE FIXTURE SCHED NOTES							
MARK	DESCRIPTION		C.W.	H.W.	TEMPERED	FIX OUTLET	TRAP	FIX DRAIN	WASTE-MIN	VENT-MIN	INDIRECT	AIR GAP	AIR BREAK	MFR.	CAT. Nos	MFR.	CAT. Nos		MFR.	CAT. Nos	MFR.	CAT. Nos			
DF1	DRINKING FOUNTAIN/ WH/ BI-LEVEL/ ADA	27" TO BOTTOM OF LOW UNIT, 33" TO BOTTOM OF HIGH UNIT	1/2"			1-1/2"	1-1/2"	1-1/2"	1-1/2"	1-1/2"			H	VRCTLDLDC	H	2167CC	H	-	E	C8912CECO		1,3,5,13			
LV1	LAVATORY/ CT/ SO/ .5 GPM/ TMV/ ADA	34" TO RIM	1/2"	1/2"	1/2"	1-1/4"	1-1/2"	1-1/2"	1-1/2"	1-1/2"			A	116.662.AB.1	D	2165CCLK	E	155AECO	E	8912CBECO		1,3,4,8,10,11			
LV2	LAVATORY/ WH/ SO/ .5 GPM/ TMV/ ADA	34" TO RIM	1/2"	1/2"	1/2"	1-1/4"	1-1/2"	1-1/2"	1-1/2"	1-1/2"			D	116.662.AB.1	D	2165CCLK	E	155AECO	E	8912CBECO		1,3,4,8,10,11			
MB1	MOP BASIN/ FS/ 24"x24"x10" DEEP/ 2.0 GPM	42" TO FAUCET	1/2"	1/2"		3"	3"	3"	3"	1-1/2"			G	897-RCF	D	UNIT	G	UNIT	-	ROUGH		2,6			
SK1	HAND WASHING SINK/ WH/ SS/ SO FAUCET/ 1.5 GPM/ TMV/ ADA	34" TO RIM	1/2"	1/2"	3/8"	1-1/4"	1-1/2"	1-1/2"	1-1/2"	1-1/2"			K	ELV2-19SACC	K	2165CCLK	K	LK18	E	8912CBECO		1,3,4,10,11			
SK2	3 COMPARTMENT SINK/ FS/ SS/ 2.2 GPM/ TMV	-	1/2"	1/2"		-	-	-	-	-			J	MF3-2020-20L	D	2165LK	-	-	-	-		12,14			
UR1	URINAL/ WH/ SO FV (BATTERY)/ 1.0 GPF/ ADA	17" TO LIP	3/4"			2"	INT	2"	2"	1-1/2"			A	6590.001	B	ROYAL 180 SMO-1.0-OR	B	-	A	-	A	-	1,3,13,15		
WB1	ICE MAKER OUTLET BOX/ 0.1 GPM	36" TO BOTTOM	1/2"										F	696-G1010MF	F	-	-	-	-	-					
WC1	WATER CLOSET/ WH/ SO FV (BATTERY)/ 1.6 GPF	15" TO RIM	1"			4"	INT	4"	4"	2"			A	2257.101	B	ROYAL 111 SMO-1.6-OR	B	-	A	-	A	-	C	1655SCT	1,7,9
WC2	WATER CLOSET/ WH/ SO FV (BATTERY)/ 1.6 GPF/ ADA	17" TO RIM	1"			4"	INT	4"	4"	2"			A	2257.101	B	ROYAL 111 SMO-1.6-OR	B	-	A	-	A	-	C	1655SCT	1,3,7,9,15

- FIXTURE SCHEDULE NOTES:**
- VERIFY MOUNTING HEIGHT OF FIXTURE WITH ARCHITECTURAL PLANS PRIOR TO ROUGH-IN.
 - PROVIDE FIAT MODEL #832-AA HOSE AND BRACKET, FIAT MODEL #889-CC MOP BRACKET, FIAT MODEL #E-77-AA VINYL BUMPER GUARDS AND FIAT MODEL #102-224 WALL GUARDS. COORDINATE MOUNTING OF ACCESSORIES WITH ARCHITECT.
 - FIXTURE AND INSTALLATION SHALL CONFORM TO ADA REQUIREMENTS.
 - PROVIDE ASSE #1070 THERMOSTATIC MIXING VALVE SET TO DELIVER 105°F WATER TEMPERATURE.
 - PROVIDE OPTIONAL CANE APRON ELKAY #88324C FOR HIGH UNIT.
 - PROVIDE CHECK VALVES IN WATER SUPPLIES.
 - TOILET SEAT TO BE WHITE, COMMERCIAL GRADE, OPEN FRONT, ANTIMICROBIAL TYPE.
 - PROVIDE THRU WALL OR IN WALL BRACKET FOR CONCEALED ARM SUPPORT.
 - PROVIDE FOOT SUPPORT CARRIER WITH ADDITIONAL FOOT SUPPORT AND ROD LENGTH.
 - PROVIDE TRUEBRO #102 E-Z LAV GUARD.
 - COORDINATE ELECTRICAL REQUIREMENTS WITH ELECTRICAL CONTRACTOR.
 - EACH BASIN MUST INDEPENDENTLY AND INDIVIDUALLY BE CHARGED TO FLOOR SINK PER NORTH CAROLINA PLUMBING CODE.
 - PROVIDE CHAIR CARRIER.
 - PROVIDE ASSE #1070 THERMOSTATIC MIXING VALVE SET TO DELIVER 115°F WATER TEMPERATURE.
 - FLUSH VALVE SENSORS FOR ADA REQUIREMENTS ARE TO BE LOCATED ON THE ROOM WIDE AREA SIDE.

Order Plans @ WWW.LDILine.com

Lancaster County, South Carolina
Indian Land Soccer Complex

10167 Harrisburg Road
Indian Land, SC 29707

Revisions:

Proj. No.: 80702
Date: 10/09/2020

Sheet Name:
PLUMBING SCHEDULES

P-601