

GENERAL NOTES

1. ALL CONDUITS SHALL BE ROUTED ABOVE THE CEILING UNLESS THE DEVICE IS FLOOR MOUNTED.
2. ALL OUTLET HEIGHTS MEASURED ABOVE FINISHED FLOOR TO CENTER OF OUTLET.
3. NOT ALL ELECTRICAL & DATA OUTLETS MAY BE SHOWN ON THIS PLAN, REFER TO ELECTRICAL POWER PLAN(S)
4. ALL DATA TO HAVE 3/4" RIGID RUN TO ABOVE DROP CEILING. IF IN OPEN CEILING, RUN TO BOTTOM OF JOIST.



KEY NOTES:

1. RUN CONDUIT FROM CEILING DOWN DIRECTLY INTO TOP OF HOOD CONTROL PANEL

ELECTRICAL ROUGH-IN LEGEND

⊖	20A, 125V, DUPLEX RECEPTACLE OUTLET.
⊕	COMBO OUTLET, USB CHARGER & TAMPER PROOF RECEPTACLE
⊖⊕	20A, 125V, DOUBLE DUPLEX RECEPTACLE OUTLET
⊖⊕⊖	20A, 125V, DUPLEX RECEPTACLE WITH ISOLATED GROUND
⊖⊕⊖⊖	208 VOLT RECEPTACLE
⊖⊕⊖⊖⊖	JUNCTION BOX, CEILING MOUNTED
⊖⊕⊖⊖⊖⊖	JUNCTION BOX, WALL MOUNTED
⊖⊕⊖⊖⊖⊖⊖	DATA OUTLET
⊖⊕⊖⊖⊖⊖⊖⊖	TELEPHONE OUTLET
⊖⊕⊖⊖⊖⊖⊖⊖⊖	TELEPHONE/DATA OUTLET
⊖⊕⊖⊖⊖⊖⊖⊖⊖⊖	ELECTRICAL RELAY
S	EQUIPMENT CONTROL SWITCH

CONSULTANT:
JOHN SPONSSELLER, ARCHITECT
 8025 W. 25TH PL.
 LAKEWOOD, CO 80214
 TEL: (303) 815-0161



GOOD TIMES RESTAURANTS, INC.
 141 Union Blvd, Suite 400
 Lakewood, CO 80228
 303-384-1430

BAD DADDY'S BURGER BAR "EASTCHASE"
 THE VENUE EASTCHASE
 NWC EASTCHASE PKWY & EASTCHASE LN.
 MONTGOMERY, AL 36117

Issue Record:

4.23.2019	FOR PLAN REVIEW

Revisions:

5.6.2019	WALKIN BOX
7.1.2019	CANOPY REVS
2.10.2021	TO GO REVS

Drawn:
DRAWN BY: JS, KC

Checked:
CHECKED BY: JS

Project No.
PROJECT#: 19-207

Contact:

ELECTRICAL ROUGH-IN PLAN AT KITCHEN

▲

K6

Date of Last Print:
 2.10.2021

1 ELECTRICAL ROUGH-IN PLAN AT KITCHEN
 1/2" = 1'-0" NOTE: