

4 AE501 — W04 PLAN & SECTION DETAIL
1 1/2" = 1'-0"



3 AE501 — W03 PLAN & SECTION DETAIL
1 1/2" = 1'-0"



NOTE: FOR W02* VARIATION, USE 6" STEEL STUDS INSTEAD OF 8"

2 AE501 — W02 PLAN & SECTION DETAIL
1 1/2" = 1'-0"



1 AE501 — W01 PLAN & SECTION DETAIL
1 1/2" = 1'-0"



SE4



M8



M4

GENERAL PARTITION NOTES

1. ALL INTERIOR WALLS SHALL BE SEISMIC
2. REFER TO T SERIES SHEETS FOR ALL UL DESIGNS.
3. METAL STUD GAUGE AND SPACING TO BE DETERMINED BY METAL STUD MANUFACTURER GUIDELINES AND TEST REPORTS IN ORDER TO MEET THE FOLLOWING PERFORMANCE REQUIREMENTS FOR HORIZONTAL DEFLECTION, UON IN THE SPECIFICATIONS.
   A. TYPICAL PARTITION STUD GAUGE SHALL BE DESIGNED TO AN L/120 DEFLECTION OR LESS AS REQUIRED BY CODE, UON.
   B. ON PARTITION TO RECEIVE TILE, PARTITION STUD GAUGE SHALL BE DESIGNED TO AN L/360 DEFLECTION OR LESS AS RECOMMENDED BY THE TILE COUNCIL OF NORTH AMERICA.
4. PARTITION DIMENSIONING AND PARTITION TYPE DESIGNATIONS ARE INDEPENDENT OF APPLIED FINISHES. REFER TO FINISH SCHEDULE FOR INFORMATION REGARDING APPLIED FINISHES.
5. ALL PARTITIONS TO RUN FROM FINISH FLOOR TO UNDERSIDE OF DECK, UON.
6. PROVIDE WATER RESISTANT GWB FULL LENGTH OF TOILET / URINAL WALLS AND WITHIN 2 FEET HORIZONTALLY AND 4 FEET VERTICALLY OF SINKS, LAVATORIES AND JANITORS CLOSETS AND ARE NOT SCHEDULED TO RECEIVE TILE OR SHOWER / TUB SURROUNDS.
7. ON NON-RATED WALLS SCHEDULED TO RECEIVE TILE OR SHOWER / TUB SURROUNDS, PROVIDE CEMENTITIOUS BACKER BOARD IN LIEU OF GWB. ON RATED WALLS SCHEDULED TO RECEIVE TILE OR SHOWER / TUB SURROUNDS, REFER TO PARTITION TYPE AND UL DESIGN.
8. REFER TO LIFE SAFETY PLAN FOR LOCATIONS OF WALLS WITH HOURLY RATINGS AND LOCATIONS OF SMOKE BARRIER PARTITIONS.
9. INSTALL ALL FIRE RATED WALL ASSEMBLIES IN STRICT ACCORDANCE WITH APPLICABLE CODES, ORDINANCE, OR LAWS AND UL DESIGN.
10. ALL PENETRATIONS IN RATED WALL ASSEMBLIES SHALL BE BY UL APPROVED FIRE RATED ASSEMBLIES.
11. ALL FIRE RATED AND SMOKE BARRIER PARTITIONS SHALL BE LABELED ABOVE CEILING WITH 2" TALL (MIN) LETTERS AT NOT MORE THAN 8'-0" OC. AN EXAMPLE LABEL IS AS FOLLOWS: "ONE HOUR FIRE PARTITION"



5 AE501 — W05 PLAN & SECTION DETAIL
1 1/2" = 1'-0"



S6N



SE6N



S6N



SE6NFT



S6NFT

9 AE501 — PARTITION TYPES
1 1/2" = 1'-0"

Order Plans @ WWW.LDILine.com

City of Asheville/ Parks & Recreation

DR. WESLEY GRANT SR. CENTER EXPANSION

885 LIVINGSTON STREET
ASHEVILLE, NC 28801

DESIGNER

CLARKNEXSEN

301 COLLEGE STREET, SUITE 300
ASHEVILLE, NORTH CAROLINA 28801
828-252-9808

CLARK NEXSEN LICENSE NUMBER: C-1928

CORPORATE SEAL

CLARK NEXSEN, INC. CERT NO. 50680 ASHEVILLE, NC

PROFESSIONAL SEAL

2021.03.15 12:16:36-04'00'

SUBMITTAL

03.12.2021

CONSTRUCTION DOCUMENTS

REVISIONS

KEY PLAN

SHEET

PARTITION TYPES AND DETAILS

AE501

DESIGN: Designer
DRAWN: Author
REVIEW: Checker

CN 7904-A

3/9/2021 - 11:42:21 AM
C:\Users\dmiller\ac\Revit_temp\Archive\AE501_PARTITION TYPES_A19_dmiller.rvt