

**GENERAL NOTES**

A. SEE LIGHTING CIRCUIT SCHEDULE ON EL101 AND PANEL SCHEDULES FOR CIRCUITING REQUIREMENTS OF EACH SPACE. ALL EMERGENCY AND EXIT FIXTURES WILL BE CONNECTED TO LIGHT CIRCUIT IN ROOM SERVED.

**KEY NOTES**

- NO WORK IN THIS AREA UNLESS OTHERWISE NOTED.
- PROVIDE NIGHT NDC TOUCH SCREEN, DIGITAL TIME CLOCK TO CONTROL FRONT SIDE WALK, OUTDOOR BASKETBALL COURT AND OUTDOOR POOL AREA POLE MOUNTED LIGHTING. COORDINATE TIME SETTINGS WITH OWNER. PROVIDE TWO NPDM BYPASS SWITCHES (ONE FOR POOL AREA AND ONE FOR OUTDOOR BASKETBALL COURT). BYPASS SWITCH FOR POOL AREA TO BE LOCATED BESIDE DIGITAL TIME CLOCK AND BYPASS SWITCH FOR OUTDOOR COURT SHALL BE LOCATED IN THE GYM. FRONT SIDE WALK LIGHTING SHALL BE ONLY CONTROLLED BY DIGITAL TIME CLOCK WITH NO BYPASS SWITCH.
- EXISTING EXTERIOR LIGHTING CONTACTOR/TIME CLOCK AND H-O-A SWITCH.
- NPDM SWITCH TO BE WIRED AS BYPASS SWITCH TO CONTROL POLE MOUNTED OUTDOOR BASKETBALL COURT LIGHTING.
- LIGHT FIXTURE TO BE CONTROLLED VIA DIGITAL TIME CLOCK WITH BYPASS SWITCH. SEE NOTE 2 ABOVE.
- LIGHT FIXTURE TO BE CONTROLLED VIA DIGITAL TIME CLOCK WITH NO BYPASS SWITCH. SEE NOTE 2 ABOVE.
- NPDM SWITCH TO CONTROL LIGHTING IN CONNECTOR 101 AND CORRIDOR 102.
- NPDM DX SWITCH TO CONTROL TYPE M LIGHTING AT NEW FRONT DESK AREA.
- NPDM 4P DX SWITCH TO CONTROL PLAN SOUTH LIGHTING IN PROGRAM SPACE.
- NPDM 4P DX SWITCH TO CONTROL PLAN NORTH LIGHTING IN PROGRAM SPACE.
- PROVIDE IOTA IIS 1100 INVERTER TO POWER POOL AREA EMERGENCY LIGHTING. SEE TIME CLOCK CONTROL OF SWIMMING POOL AND COURT LIGHTING CONTROL SYSTEM RISER ON SHEET EP502 FOR MORE INFORMATION AND INTEGRATION INTO THE NIGHT LIGHTING CONTROL SYSTEM.
- EXISTING EXIT SIGN TO BE DEMOLISHED. REMOVE CIRCUITRY BACK TO NEAREST FIXTURE ON CIRCUIT AND PROVIDE BLANK STAINLESS STEEL COVERPLATE ON BOX.
- EXISTING PENDANT LIGHT FIXTURE TO BE DEMOLISHED. REMOVE CIRCUITRY BACK TO NEAREST FIXTURE ON CIRCUIT AND PROVIDE BLANK STAINLESS STEEL COVERPLATE ON BOX.

**LIGHTING CIRCUIT SCHEDULE**

ROOM DESCRIPTION	PANEL	CIRCUIT NUMBER
CONNECTOR 101	JA	1
CORRIDOR 102	JA	1
FRONT DESK TYPE M LITS	JA	1
OFFICE 103	JA	1
POOL ST. RISER ROOM 104	JA	1
M. RESTROOM 105	JA	1
W. RESTROOM 106	JA	1
FAMILY BATHRM 107	JA	1
HK/STORAGE 108	JA	1
ELEC 109	JA	1
IT ROOM 110	JA	1
STORAGE 112	JA	1
PROGRAM SPACE 111	JA	3
GYM 115 (Z1)	JA	5
GYM 115 (Z2)	JA	7
GYM 115 (Z3)	JA	7
POOL EQ. ROOM 120	PP	9
PH. BUFFER 121	PP	9
CHEM. STORAGE 122	PP	9
OUTDR. BALL CT. TYPE M LITG	JA	9
OUTDR. TYPE B LITG.	JA	11
OUTDR. TYPE B LITG.	JA	11


**GRAPHIC SCALE(S)**



City of Asheville Parks & Recreation  
**DR. WESLEY GRANT SR.  
CENTER EXPANSION**

285 LIVINGSTONE STREET  
ASHEVILLE, NC 28801

CLARK NEXSEN  
201 COLLEGE STREET, SUITE 300  
ASHEVILLE, NORTH CAROLINA 28801  
828.252.6699  
CLARK NEXSEN LICENSE NUMBER: C-1428



REVISIONS  
03.12.2021  
**CONSTRUCTION DOCUMENTS**

DATE: 03/12/2021  
SHEET: FIRST FLOOR - LIGHTING  
**EL101**

DATE: 03/12/2021  
DRAWN: BRADY  
REVIEW: BRADY  
CN 7904-A

**1 FIRST FLOOR - LIGHTING**  
1/8" = 1'-0"

S:\projects\2021\03\11\_24\_21\11\_24\_21\_001\031124001.dwg  
C:\Users\brady\OneDrive\Documents\11\_24\_21\_001\_031124001.dwg