


Facilities Management
 1161 West Samford Avenue
 Auburn University, AL 36849
 Phone: (334) 844-4810
 Fax: (334) 844-9458
*Safety is our first priority.
 Think Safety. Act Safely.*

No.	Revision	Date
-	-	00/00/00



JMR+H
 Architecture, P.C.
 446 Dexter Avenue
 Montgomery, AL 36104
 Phone: (334) 420-5672
 Fax: (334) 420-5692
 JMR+H Project Number: 19-968
 Drawn By: DT

**Auburn University Building
 Ham Wilson Arena Renovations
 Project Number 19-451**

SHEET TITLE:
 UTILITY PLAN

DRAWN BY:
 WLH
 CHECKED BY:
 CLT
 DATE:
 JANUARY 21, 2021
 FILE NUMBER:
 -
 PROJECT NUMBER:
 19-451
 SHEET NUMBER:

C5.0
 11 of 61



Order Plans @ www.LDILine.com

- SPECIAL NOTES:**
- SEE SHEET C0.0 FOR APPLICABLE UTILITY NOTES.
 - RPZ BACKFLOW PREVENTOR ON FIRE LINE INSIDE BUILDING. SEE PLUMBING/FIRE PROTECTION PLANS FOR DETAILS.
 - ALL WATER LINE IMPROVEMENTS SHOWN ARE ASSOCIATED WITH THE NEW FIRE PROTECTION SYSTEM FOR THE BUILDING AND ARE TO BE INCLUDED IN THE BASE BID. BACKFILL AND REPLACEMENT OF PAVEMENT SURFACES IN PATH OF UTILITY INSTALLATION ARE TO BE INCLUDED IN THE BASE BID AS WELL. ALL OTHER UTILITY IMPROVEMENTS SHOWN ARE TO BE PART OF THE BID ALTERNATE.
 - ALL GAS WORK SHALL BE PERFORMED BY AN AUBURN PREQUALIFIED CONTRACTOR.

UTILITY LEGEND	
— 6" F —	6" DIP CL350 FIRE WATER LINE SERVICE
— 4" FDC —	4" DIP CL 350 FIRE DEPARTMENT CONNECTION
◀	GATE VALVE
▶	THRUST BLOCK
⊙	POST INDICATOR VALVE (SEE DETAIL)
— G —	MPDE GAS LINE
⊗	REMOTE FIRE DEPARTMENT CONNECTION (SEE PLUMBING PLANS FOR DETAILS)

