MATCH LINE STA. 108+00 DRAWING No. 44-0003

MATCH LINE STA. 114+00 DRAWING No. 44-0005

INSTALL 6" INSERTED VALVE EQUILVALENT TO EZ VALVE IN BOX. CUT AND PLUG MAIN WITH 6" D.I.R.J. CAP

CONNECT TO EXISTING 8" WATER MAIN AND INSTALL TWO (2) 8" 45° D.I.R.J. BENDS. ROTATE FITTINGS AS NEEDED FOR VERTICAL CLEARANCE

POTHOLE EXISTING WATER MAIN FOR DEPTH OF PIPE

GPC/45' T# 10-6928

GPC/*** T# 15-112469

GPC/30' CENTERLINE INTERSECTION DELESSEPS AVE STA 106+98.08 SALVADOR ST STA 401+02.49

GPC/40'

GPC/35'

GPC/30'

2-6CU+ 2ACSRN

2-4WPCU

2-6CU+ 4CUN

4ALDPX

LIMIT OF CONSTRUCTION STA 401+43.40

LIMIT OF CONSTRUCTION STA 500+00.00

9 BEANIE M. & MARY J. VINCENT

18 GEERTIE B. BERGER

13 EMMA T. SIMON

20

SIMON M. EICHENLAUB

DELESSEPS AVENUE BAPTIST CHURCH

ESA HISTORICAL BOUNDARY SACKVILLE HISTORIC DISTRICT CONTRACTOR SHALL NOT STAGE EQUIPMENT WITHIN HISTORICAL BOUNDARY

EXISTING: 2" PLASTIC GAS MAIN NOP: 60 PSIG

RETIRED 4" CAST IRON GAS MAIN

CONNECT TO EXISTING 6" WATER MAIN WITH 6" X 6" TAPPING SLEEVE AND VALVE IN MANHOLE WITH CONCRETE THRUST BLOCK. RESTRAIN EXISTING 6" WATER MAIN (SEE DETAIL) N 741990.5942 E 990832.8247

INSTALL 6" INSERTED VALVE EQUILVALENT TO EZ VALVE IN BOX. CUT AND PLUG MAIN WITH 6" D.I.R.J. CAP

CONNECT TO EXISTING 6" WATER MAIN WITH 6" X 6" TAPPING SLEEVE AND VALVE IN MANHOLE WITH CONCRETE THRUST BLOCK. RESTRAIN EXISTING 6" WATER MAIN (SEE DETAIL) N 741981.5089 E 990864.6140

REMOVE AND DISPOSE ±30 LF OF EXISTING 6" WATER MAIN.

CLOSE VALVE AND EXTEND 6" DI HYDRANT BY ±5LF AND RELOCATE HYDRANT

LOCATE AND CLOSE VALVE AT MAIN. RELOCATE EXISTING METER AND EXTEND SERVICE LINE ±5 LF

LOCATE AND CLOSE VALVE AT MAIN. RELOCATE EXISTING METER AND EXTEND SERVICE LINE ±7 LF

UMHST FR: 20.57 IE: 15.75 (SE) IE: 15.67 (NW) IE: 15.65 (SW) IE: 13.37 (N) IE: 13.27 (S) IE: 3.65 (E) IE: 3.65 (W)

UMHST FR: 17.04 IE: 12.45 (S) IE: 12.37 (W) IE: 11.12 (N) IE: 3.99 (E) IE: 3.99 (NW)

REQ'D R/W

ORANGE BARRIER FENCE (TYP.)

(2 TYP.) 6" D.I.R.J. 45° BEND ROTATE BENDS AS NECESSARY.

REMOVE AND REPLACE ±50 SY OF ASPHALT PAVEMENT.

INSTALL ±30LF OF NEW 6" D.I. WATER MAIN (PRESSURE CLASS 350)

PROTECT EXISTING WATER METERS

LOCATE AND CLOSE VALVE AT MAIN. RELOCATE EXISTING METER AND EXTEND SERVICE LINE ±5 LF

CLOSE VALVE AND EXTEND 6" DI HYDRANT BY ±5LF RELOCATE HYDRANT

LOCATE AND CLOSE VALVE AT MAIN. RELOCATE EXISTING METER AND EXTEND SERVICE LINE ±7 LF

(2) CONNECT TO RELOCATED WATER MAIN WITH 6" X 2" TAPPING SADDLE AND 2" CORPORATION STOP. INSTALL ±20 LF OF 2" POLYETHYLENE TUBING. RELOCATE METER AND RECONNECT TO SERVICE. ABANDON EXISTING SERVICE LINE.

(2 TYP.) 6" D.I.R.J. 45° BEND ROTATE BENDS AS NECESSARY.

PROTECT EXISTING WATER METERS

LOCATE AND CLOSE VALVE AT MAIN. RELOCATE EXISTING METER AND EXTEND SERVICE LINE ±5 LF

EXISTING: 2" PLASTIC GAS MAIN NOP: 60 PSIG

21 3-1/0ACSR+ 2ACSRN

22 2ALTPX

23

24 6CU+ 4ACSRN

25 DAVID JOHNSON

26 6CU+ 4ACSRN

27

28

29 GPC/40' T# 37-112532

30

31

16 2-2ACSR FRANCES SIMPSON & CHRIS WOODS

GPC/40' DATA SHEET 14 T# 969209

GPC/40' ESA - SEE ENVIRONMENTAL RESOURCES IMPACT TABLE IN SELECTIVE NOTES FOR CONSTRUCTION RESTRICTIONS

1/0ALTPX

ESA-HISTORICAL BOUNDARY SACKVILLE HISTORIC DISTRICT CONTRACTOR SHALL NOT STAGE EQUIPMENT WITHIN HISTORICAL BOUNDARY

Order Plans @ WWW.DILine.com

PROPERTY AND EXISTING R/W LINE
REQUIRED R/W LINE
CONSTRUCTION LIMITS
EASEMENT FOR CONSTR & MAINTENANCE OF SLOPES
EASEMENT FOR CONSTR OF SLOPES
EASEMENT FOR CONSTR OF DRIVES

BEGIN LIMIT OF ACCESS.....BLA
END LIMIT OF ACCESS.....ELA
LIMIT OF ACCESS
REQ'D R/W & LIMIT OF ACCESS
ORANGE BARRIER FENCE
ESA - ENV. SENSITIVE AREA (SEE ERIT 4-)

THOMAS & HUTTON
Engineering | Surveying | Planning | GIS | Consulting
50 Park of Commerce Way • PO Box 2727
Savannah, GA 31402-2727 • 912.234.5300
www.thomasandhutton.com
Charleston, SC | Columbia, SC | Myrtle Beach, SC
Savannah, GA | Wilmington, NC

SCALE IN FEET
0 20 40 80

REVISION DATES

UTILITY RELOCATION PLANS
DELESSEPS/LA ROCHE AVE FM
WATERS AVE TO SKIDAWAY RD

CHECKED:		DATE:		DRAWING No.
BACKCHECKED:		DATE:		44-0003
CORRECTED:		DATE:		
VERIFIED:		DATE:		

7/31/2015 GPLN