

NOTE:
1. CEILING RADIATION DAMPER DAMPER SHALL BE UL 555C LISTED. DAMPER SHALL BE RECTANGULAR TO MATCH DUCT CONFIGURATION/SIZE AND SHALL OPERATE WITH A UL LISTED FUSIBLE LINK. PROVIDE DAMPER WITH INSULATION (UL LISTED) ON BACKSIDE OF DAMPER BLADE WHERE REQUIRED PER MANUFACTURER. DAMPER INSTALLATION AND APPLICATION SHALL BE PER MANUFACTURER'S INSTRUCTIONS AND APPROVAL. SEE INFORMATION AND REQUIREMENTS FOR CRD AT CRD DETAIL.
2. ALL COMPONENTS/MATERIALS (INCLUDING CONTROL WIRING) IN CLOSET SHALL BE PLENUM RATED (MEET ASTM E84 CRITERIA 25/50 FLAME/SMOKE DEVELOPED RATING OR LESS).
3. DOOR PROVIDED BY OTHERS (SEE ARCH). DOOR SHALL HAVE MIN 1.45 SF FREE AREA.
4. IF A COMBUSTIBLE DOOR IS USED, THEN THE INSIDE SURFACE OF DOOR SHALL BE PAINTED WITH A INTUMESCENT PAINT IN ORDER TO PROVIDE A 25/50 FLAME/SMOKE DEVELOPED RATING FOR PLENUM RATED CRITERIA (FIRE RETARDANTS, INC. BURN BARRIER NO. 10-10 OR EQUAL).
5. REFRIGERANT LINES SHALL BE ROUTED SUCH THAT LINES ARE TIGHT TO CLOSET WALLS IN ORDER TO ALLOW ADEQUATE CLEARANCE FOR WATER HEATER DRAIN PAN. DO NOT BLOCK FCU ACCESS OR FILTER PULL WITH REFRIGERANT LINE.
6. IF CEILING HEIGHT IS GREATER THAN 8FT, THE EXTRA HEIGHT ABOVE 8FT SHALL BE APPLIED TO THE DISTANCE BETWEEN THE FCU AND THE CEILING. (I.E. TO THE 18" SHOWN HERE)

1 APARTMENT FCU DETAIL - R.A THRU DOOR
Scale: None



SIDEWALL RETURN GRILLE TABLE

FCU TONNAGE	GRILLE SIZE	GRILLE TYPE
1.5, 2.0	16x16	NAILOR 6145H OR EQUAL. BAKED ENAMEL, COLOR BY ARCH., STEEL, 1/4" BLADE SPACING, 45° DEFLECTION, NC<30 & ΔP<0.10" AT THE CFM INDICATED.
2.5, 3.0, 3.5	20x20	
4.0, 5.0	24X36	

NOTES:
1. DUCT CONFIGURATION SHOWN IS GENERAL. CONFIGURE DUCT AS NEEDED TO ACCOMMODATE SPACE PROVIDED.
2. IF RADIUS ELBOW CANNOT BE USED, THEN PROVIDE RECTANGULAR ELBOW WITH TURNING VANES. (SUPPLY DUCT ONLY)
3. LINE SUPPLY DUCT FIRST 10 FEET FROM UNIT U.N.O. LINE EXPOSED SPIRAL DUCT ENTIRE LENGTH AS SPECIFIED.
4. SUPPLY DUCT DISCHARGE ELBOW SHALL TURN IN THE DIRECTION OF FAN ROTATION.

2 COMMON AREA FCU DETAIL - SIDEWALL R.A.G.
Scale: None



3 "PANCAKE" HORIZONTAL FCU DETAIL
Scale: None



NOTES:
1. WALL LOUVER & DAMPER ASSEMBLY SHALL BE SUPPORTED BY BUILDING PROVIDER/MANUFACTURER. COORDINATE BETWEEN TRADES.
2. OPERATION OF DAMPER SHALL BE THRU ONE ACTUATOR.
3. CONTROL DAMPER SHALL HAVE THE FOLLOWING CHARACTERISTICS: EXTRUDED ALUMINUM BLADES AND FRAME, BLADES SHALL BE FLAT TYPE 0.125" THICK, BLADE EDGE SEALS SHALL BE NEOPRENE AND MECHANICALLY LOCKED IN EXTRUDED SLOTS. JAMB SEALS SHALL BE DESIGNED FOR EASY REPLACEMENT IN THE FIELD. BEARINGS SHALL BE CONCEALED IN FRAME, BEARINGS SHALL BE NON-CORROSIVE MOLDED SYNTHETIC, PERFORMANCE DATA SHALL BE OBTAINED BY TESTING IN ACCORDANCE WITH AMCA STANDARD 500. PERFORMANCE: PRESSURE DROP SHALL NOT BE GREATER THAN 0.04" AT 1000 FPM AND LEAKAGE SHALL NOT BE GREATER THAN 3 CFM/SQ FT WITH A 1" STATIC PRESSURE CLOSED OVER A 18"x12" SIZE. DAMPER SHALL BE OPPOSED OR PARALLEL BLADE CONFIGURATION.
4. DAMPER SHALL BE NORMALLY CLOSED (FAIL CLOSED).

4 WALL LOUVER DETAIL
Scale: None



NOTES:
1. NON-RATED DRYER BOXES SHALL NOT BE INSTALLED IN A RATED WALL.
2. DRYER WALL BOXES WHICH ARE LOCATED IN RATED WALLS SHALL BE OF METAL CONSTRUCTION EQUAL TO IN-O-VATE TECHNOLOGIES DRYER BOX MODEL #425.0
3. NON-RATED WALL BOXES MAY BE PREFABRICATED OR MADE OF PLASTIC.
4. DIMENSIONS OF BOX ARE APPROXIMATE.
5. MOUNT BOX SUCH THAT TRANSITIONAL DUCT MAY BE INSTALLED W/ NO BENDS.
6. FLEXIBLE DUCT CONNECTING DRYER TO DRYER WALL BOX MAY BE TRIMMED TO PROPER LENGTH AND SHALL NOT BE COILED.

5 DRYER WALL BOX DETAIL
Scale: None

Installation Instructions

CONNECTING APPLIANCE USING 4-WIRE CONNECTION (MUST BE USED FOR MOBILE HOME INSTALLATION) (Cont.)

6. Connect power cord as follows:
   A. Connect the 2 hot lines to the outer screws of the terminal block (marked L1 and L2).
   B. Connect the neutral (white) line to the center of the terminal block (marked N).
7. Attach ground wire of power cord with the green ground screw (hole above strain relief bracket). Tighten set (wire) screw to secure.
8. Properly secure power cord to strain relief.
9. Reinstall the cover.

WARNING: NEVER LEAVE THE COVER OFF OF THE TERMINAL BLOCK.

EXHAUST INFORMATION

WARNING - IN CANADA AND IN THE UNITED STATES, THE REQUIRED EXHAUST DUCT DIAMETER IS 4" (10cm). DO NOT USE DUCT LONGER THAN SPECIFIED IN THE EXHAUST LENGTH TABLE.

Using exhaust hoods other than specified will:
- Increase the drying time and the energy cost.
- Reduce the dryer life.
- Accumulate lint, creating a potential fire hazard.

The correct exhaust installation is YOUR RESPONSIBILITY.
Problems due to incorrect installation are not covered by the warranty.

Use only metal dryer exhaust parts or metal foil transition duct approved with UL listed transition duct.

The MAXIMUM ALLOWABLE duct length and number of bends in the exhaust system depends upon the type of bend, number of turns, the type of exhaust hood (wall cap) and all conditions noted on the chart.

2½" DRYER EXHAUST LENGTH

No. of 90° Elbows	Hood	Wall Cap
1	50 Feet	40 Feet
2	40 Feet	30 Feet
3	30 Feet	20 Feet
4	20 Feet	10 Feet
5	10 Feet	5 Feet

EXHAUST INFORMATION (cont.)

2½" DRYER EXHAUST LENGTH

RECOMMENDED MAXIMUM LENGTH

Exhaust Hood

Recommended

Use only for short runs (see below)

90° Elbow

45° Elbow

No. of 90° Elbows	Hood	Wall Cap
1	50 Feet	40 Feet
2	40 Feet	30 Feet
3	30 Feet	20 Feet
4	20 Feet	10 Feet
5	10 Feet	5 Feet

- For an exhaust system with only one elbow, replace the elbow with two 45° elbows to reduce the exhaust system's resistance to airflow.
- The maximum length includes all the straight sections and each elbow of the system (transition duct included).

EXHAUST SYSTEM CHECK LIST

HOOD OR WALL CAP
- Terminate in a manner to prevent back drafts or entry of birds or other wildlife.
- Termination should prevent material accumulation or the exhaust or flow and should require little or no maintenance to prevent clogging.
- **Never** install a screen in or over the exhaust duct. This could cause lint build up.
- Wall caps must be installed at least 12 in. above ground level or any other obstruction with the opening pointed down.

SEPARATION OF TURNS
For best performance, separate all turns by at least 4 ft. of straight duct, including distance between last turn and exhaust hood.

TURNS OTHER THAN 90°
- One turn of 45° or less may be ignored.
- Two 45° turns should be treated as one 90° turn.
- Each turn over 45° should be treated as one 90° turn.

SEALING OF JOINTS
- All joints should be tight to avoid leaks. The male end of each section of duct must point away from the dryer.
- Do not assemble the ductwork with fasteners that extend into the duct. They will serve as a collection point for lint.
- Duct joints can be made air and moisture tight by wrapping the overlapped joints with duct tape.
- Horizontal runs should slope down toward the outdoors 1/4 inch per foot.

INSULATION
Duct work that runs through an unheated area or in which air conditioning should be insulated to reduce condensation and lint build-up.

6

NOTES:
1. PROVIDE ALL DRYERS WITH A 4"ø HOODED CAP. DO NOT PROVIDE CAPS WITH BIRD CAGE, OR LOUVERED CAP.
2. SEE DRAWINGS M1.1 THROUGH M1.9 FOR SPECIFIC DRYER VENT LENGTHS FOR EACH APARTMENT UNIT TYPE.
3. THIS DRYER TO BE USED IN STACKED APPLICATIONS.

6 OWNER SPECIFIED STACKED DRYER - GUD24ESS
Scale: None

Installation Instructions

EXHAUSTING THE DRYER (cont.)





EXHAUST LENGTH

Using exhaust longer than specified length will:
- Increase the drying times and the energy cost.
- Reduce the dryer life.
- Accumulate lint, creating a potential fire hazard.

The correct exhaust installation is YOUR RESPONSIBILITY.

Problems due to incorrect installation are not covered by the warranty.

The MAXIMUM ALLOWABLE length of the exhaust system depends upon the type of duct, number of turns, the type of exhaust hood (wall cap) and all conditions noted on the chart.
- Internal elbows added for side or bottom vent conversions must be included in the total elbow count.
- Any elbow greater than 45° should be treated as a 90° elbow.
- Two 45° elbows will be treated like one 90° elbow.
- For every additional 90° elbow reduce the allowable vent system length by 10 feet.
- When calculating the total vent system length, you must add all the straight pieces and elbows of the system (including the transition duct).

EXHAUST LENGTH FOR NORMAL VENT MODELS

RECOMMENDED MAXIMUM LENGTH

Exhaust Hood Types

Recommended

Use only for short runs (see below)

90° Elbow

45° Elbow

No. of 90° Elbows	Hood	Wall Cap
1	50 Feet	40 Feet
2	40 Feet	30 Feet
3	30 Feet	20 Feet
4	20 Feet	10 Feet
5	10 Feet	5 Feet

EXHAUST LENGTH FOR LONG VENT MODELS

RECOMMENDED MAXIMUM LENGTH

Exhaust Hood Types

Recommended

Use only for short runs (see below)

90° Elbow

45° Elbow

No. of 90° Elbows	Hood	Wall Cap
1	200 Feet	175 Feet
2	190 Feet	165 Feet
3	180 Feet	155 Feet
4	170 Feet	145 Feet
5	160 Feet	135 Feet

8

NOTES:
1. PROVIDE ALL DRYERS WITH A 4"ø HOODED CAP. DO NOT PROVIDE CAPS WITH BIRD CAGE, OR LOUVERED CAP.
2. SEE DRAWINGS M1.1 THROUGH M1.9 FOR SPECIFIC DRYER VENT LENGTHS FOR EACH APARTMENT UNIT TYPE.
3. THIS DRYER TO BE USED IN SIDE BY SIDE INSTALLATIONS.

7 OWNER SPECIFIED STAND ALONE DRYER - GFDN110E
Scale: None

Owner Plans
WWW.LDILine.com

Seal

CRAIG MARVIN GRADICK REGISTERED ENGINEER AGRICULTURE 109123 STATE OF TENNESSEE

5-14-2020

2PA
POOLE & POOLE ARCHITECTURE
3736 Winterfield Road, Suite 102
Midlothian, Virginia 23113
Telephone 804.225.0215
www.2pa.net

Project: 1928
CADD File:
Drawn By: NT
Checked By: CB

Permit Release:
May 15, 2020
Construction Release Set:
May 15, 2020

Revisions

No.	Date	Description

ASI / RFI Revisions

No.	Date	Description

© 2019 Poole & Poole Architecture, LLC
Drawings and specifications are and shall remain the property of Poole & Poole Architecture, LLC and shall not be used or reproduced in whole or part in any form without prior written consent of Poole & Poole Architecture, LLC.

PHILLIPS GRADICK ENGINEERING, P.C. PGE # NC3139
1107 E. Morehead Street, Suite 208, Charlotte, NC 28204
(704) 900-5910 (T) (704) 900-5917 (F)

This drawing upon transmittal of which it and all remain the property of the Engineer, is not to be used in whole or in part for any purpose without the permission of Phillips Gradick Engineering, P.C. This Drawing is copyrighted and protected under Section 102 of the U.S. Copyright Act 1990. The protection includes but is not limited to design and construction techniques. Unauthorized use of these plans without the express written permission of Phillips Gradick Engineering, P.C. is prohibited.

Borough 33
an Apartment Community by
33 Broad MF, LLC
in Chattanooga, Tennessee

Drawing Title:
Mechanical Detail

M0.3

REVISED FOR CONSTRUCTION