

Order Plans @ www.LDILine.com

- NOTES:
1. SEE M.I.X. SERIES SHEETS FOR APARTMENT HVAC.
 2. ALL CORRIDOR SUPPLY AIR DUCT & AIR DISTRIBUTION IS LOCATED IN RATED ASSEMBLY. PROVIDE C.R.D. FOR EACH PENETRATION.
 3. FOR MECHANICAL SYSTEMS SERVING THE CORRIDORS, THE O.A. INTAKE LOWER SHALL BE INSTALLED A MINIMUM OF 10'-0" FROM APARTMENT UNITS TOILET EXHAUST. ADJUST TERMINATION POINT OF EXHAUST DUCTS AS NECESSARY FOR EACH APARTMENT UNIT.
 4. O.A. DUCT AT MECHANICAL CLOSET WILL REQUIRE A C.R.D. AT CEILING PENETRATION.
 5. PROVIDE FSD WHERE MECHANICAL UNIT RETURNS PENETRATE CORRIDOR WALLS.
 6. REFRIGERANT LINES ARE TO BE RUN THRU MECHANICAL CLOSETS.



1 Building 1 - Second Level
Scale: 3/32" = 1'-0"

Plan

Seal

ZPA
POOLE & POOLE ARCHITECTURE
3736 Winterfield Road, Suite 102
Midlothian, Virginia 23113
Telephone 804.275.0215
www.zpa.net

Project: 1928
CADD File:
Drawn By: JC
Checked By: CB

Permit Release:
May 15, 2020
Construction Release Set:
May 15, 2020

Revisions

No.	Date	Description	Owner Comments
1	03/19/21		


ASI / RFI Revisions

No.	Date	Description
-----	------	-------------

© 2019 Poole & Poole Architecture, LLC. Drawings and specifications are the property of Poole & Poole Architecture, LLC and shall not be used or reproduced without the prior written consent of Poole & Poole Architecture, LLC.

PHILLIP S. GRADNICK
ENGINEERING, P.C.
1109 S. Brentwood
Memphis, TN 38118
228-462-8822

Borough 33
an Apartment Community by
33 Broad MF, LLC
in Chattanooga, Tennessee



Drawing Title:
Building 1
Building Plan

M2.1b

ISSUED FOR CONSTRUCTION