

Order Plans @ [www.LDILine.com](http://www.LDILine.com)

- NOTES:
1. SEE M.I.X. SERIES SHEETS FOR APARTMENT FINAC.
  2. ALL CORRIDOR SUPPLY AIR DUCT & AIR DISTRIBUTION IS LOCATED IN RATED ASSEMBLY. PROVIDE C.R.D. FOR EACH PENETRATION.
  3. FOR MECHANICAL SYSTEMS SERVING THE CORRIDORS, THE O.A. INTAKE LOUVER SHALL BE INSTALLED A MINIMUM OF 10'-0" FROM APARTMENT UNITS TO EXHAUST. ADJUST TERMINATION POINT OF EXHAUST DUCTS AS NECESSARY FOR EACH APARTMENT UNIT.
  4. O.A. DUCT AT MECHANICAL CLOSET WILL REQUIRE A C.R.D. AT CEILING PENETRATION.
  5. PROVIDE FSD WHERE MECHANICAL UNIT RETURNS PENETRATE CORRIDOR WALLS.
  6. REFRIGERANT LINES ARE TO BE RUN THRU MECHANICAL CLOSETS.

Seal



03/19/21



**ZPA**  
POOLE & POOLE ARCHITECTURE  
3736 Winterfield Road, Suite 102  
Midlothian, Virginia 23113  
Telephone 804.275.0215  
www.zpa.net

Project: 1928  
CADD File:  
Drawn By: JC  
Checked By: CB

Permit Release:  
May 15, 2020  
Construction Release Set:  
May 15, 2020

Revisions

No.	Date	Description
1	03/19/21	Owner Comments

ASI / RFI Revisions


No.	Date	Description
-----	------	-------------

© 2019 Poole & Poole Architects, LLC  
Drawings and specifications are the property of Poole & Poole Architects, LLC and shall not be used or reproduced without the prior written consent of Poole & Poole Architects, LLC.



PHILIP GRADNICK  
ENGINEERING, P.C. P.E. #10000  
110 W. Brentwood Drive  
Chattanooga, TN 37416  
423.440.1111  
03/19/21

**Borough 33**  
an Apartment Community by  
33 Broad MF, LLC  
in Chattanooga, Tennessee



Drawing Title:  
Building 1  
Building Plan

**M2.1c**



1 Building 1 - Third Level  
Scale: 3/32" = 1'-0"

Plan

ISSUED FOR CONSTRUCTION