

Order Plans @ www.LDOnline.com

- NOTES:
1. SEE M1.X SERIES SHEETS FOR APARTMENT HVAC.
 2. ALL CORRIDOR SUPPLY AIR DUCT & AIR DISTRIBUTION IS LOCATED IN RATED ASSEMBLY. PROVIDE C.R.D. FOR EACH PENETRATION.
 3. FOR MECHANICAL SYSTEMS SERVING THE CORRIDORS, THE O.A. INTAKE LOWER SHALL BE INSTALLED A MINIMUM OF 10'-0" FROM APARTMENT UNITS TOILET EXHAUST. ADJUST TERMINATION POINT OF EXHAUST DUCTS AS NECESSARY FOR EACH APARTMENT UNIT.
 4. O.A. DUCT AT MECHANICAL CLOSET WILL REQUIRE A C.R.D. AT CEILING PENETRATION.
 5. PROVIDE FSD WHERE MECHANICAL UNIT RETURNS PENETRATE CORRIDOR WALLS.
 6. REFRIGERANT LINES ARE TO BE RUN THRU MECHANICAL CLOSETS.

ZPA
POOLE & POOLE ARCHITECTURE
 3736 Winterfield Road, Suite 102
 Midlothian, Virginia 23113
 Telephone 804.225.0215
 www.zpa.net

Project: 1928
 CADD File:
 Drawn By: JC
 Checked By: CB

Permit Release:
 May 15, 2020
 Construction Release Set:
 May 15, 2020

Revisions

No.	Date	Description	Owner Comments
1	03/19/21		

ASI / RFI Revisions

No.	Date	Description
-----	------	-------------

© 2019 Poole & Poole Architects, LLC
 Drawings and specifications are not to be relied upon without the approval of Poole & Poole Architects, LLC and shall not be used for any other project without the prior written consent of Poole & Poole Architects, LLC.

PHILLIP S. GRADNICK
 ENGINEERING, P.C.
 110 S. Broad Street
 Chattanooga, TN 37402
 License No. 33864
 Mechanical

Borough 33
 an Apartment Community by
 33 Broad MF, LLC
 in Chattanooga, Tennessee

Drawing Title:
 Building 2
 Building Plan - HVAC

M2.2a

1 Building 2 - First Level
 Scale: 3/32" = 1'-0"

Plan

ISSUED FOR CONSTRUCTION