

Order Plans @ WWW.LDOnline.com

- NOTES:
1. SEE M1.X SERIES SHEETS FOR APARTMENT HVAC.
 2. ALL CORRIDOR SUPPLY AIR DUCT & AIR DISTRIBUTION IS LOCATED IN RATED ASSEMBLY. PROVIDE C.R.D. FOR EACH PENETRATION.
 3. FOR MECHANICAL SYSTEMS SERVING THE CORRIDORS, THE O.A. INTAKE LOUVER SHALL BE INSTALLED A MINIMUM OF 10'-0" FROM APARTMENT UNITS TOILET EXHAUST. ADJUST TERMINATION POINT OF EXHAUST DUCTS AS NECESSARY FOR EACH APARTMENT UNIT.
 4. O.A. DUCT AT MECHANICAL CLOSET WILL REQUIRE A C.R.D. AT CEILING PENETRATION.
 5. PROVIDE FSD WHERE MECHANICAL UNIT RETURNS PENETRATE CORRIDOR WALLS.
 6. REFRIGERANT LINES ARE TO BE RUN THRU MECHANICAL CLOSETS.



03/19/21



ZPA
POOLE & POOLE ARCHITECTURE
3736 Winterfield Road, Suite 102
Midlothian, Virginia 23113
Telephone 804.225.0215
www.zpa.net

Project: 1928
CADD File:
Drawn By: JC
Checked By: CB

Permit Release:
May 15, 2020
Construction Release Set:
May 15, 2020

Revisions

No.	Date	Description
1	03/19/21	Owner Comments


ASI / RFI Revisions

No.	Date	Description
-----	------	-------------

© 2019 Poole & Poole Architecture, LLC
Drawings and specifications are the property of Poole & Poole Architecture, LLC and shall not be used or reproduced in whole or in part without prior written consent of Poole & Poole Architecture, LLC.

PROFESSIONAL ENGINEERING F.C. POOLE & POOLE ARCHITECTURE, LLC
3736 Winterfield Road, Suite 102
Midlothian, VA 23113
804.225.0215

Borough 33
an Apartment Community by
33 Broad MF, LLC
in Chattanooga, Tennessee



Drawing Title:
Building 2
Building Plan

M2.2d

ISSUED FOR CONSTRUCTION

1 Building 2 - Fourth Level
Scale: 3/32" = 1'-0"

Plan