LIGHTING FIXTURE SCHEDULE GENERAL NOTES

1. COORDINATE WITH INTERIOR DESIGN OR LIGHTING CONSULTANTS REFLECTED CEILING PLAN FOR EXACT LOCATION OF LIGHT FIXTURES AND CEILING TYPE FOR PROPER FIXTURE TRIM.
2. ALL LINEAR FLUORESCENT LAMPS SHALL BE T8 UNLESS OTHERWISE NOTED.
3. ALL COMPACT FLUORESCENT DOWNLIGHTS AND LINEAR FLUORESCENT LIGHTING FIXTURE SHALL USE PARALLEL LAMP OPERATION TYPE ELECTRONIC BALLASTS UNLESS OTHERWISE NOTED.
4. ALL HID FIXTURES SHALL BE FUSED.
5. LIGHT FIXTURES INSTALLED IN MECHANICAL EQUIPMENT ROOMS SHALL BE COORDINATED WITH MECHANICAL CONTRACTOR TO AVOID CONFLICTS WITH DUCTWORK AND/OR PIPING.
6. PROVIDE ZERO DEGREE BALLASTS FOR ALL EXTERIOR MOUNTED FIXTURES.
7. PROVIDE SUFFICIENT QUANTITY OF BALLASTS IN FIXTURE BASED ON SWITCHING CONFIGURATION INDICATED ON PLANS.
8. INTERIOR FLUORESCENT LAMPS SHALL HAVE A MINIMUM RATED LIFE OF 15,000 HOURS. PROVIDE WARM WHITE LAMPS FOR ALL INTERIOR FINISHED SPACES. UTILITY ROOMS AND GARAGE FIXTURES TO BE COOL WHITE.
9. IF THERE IS A DISCREPANCY BETWEEN A FIXTURE DESCRIPTION, THE LIGHTING GENERAL NOTES, SPECIFICATIONS, AND THE CATALOG NUMBER LISTED THE MORE STRINGENT REQUIREMENT SHALL TAKE PRECEDENCE.
10. ALL FINAL SELECTIONS OF FIXTURES SHALL BE BY INTERIOR DESIGNER, AND/OR LANDSCAPE ARCHITECT. DESCRIPTIONS AND CATALOG NUMBERS ARE SHOWN AS BASIS OF DESIGN FOR CODE COMPLIANCE AND DESIGN INTENT.
11. VERIFY FINISHES OF UNIT FIXTURES WITH ARCHITECT.
12. VOLTAGE OF LIGHTING FIXTURE SHALL MATCH CIRCUIT TO WHICH IT IS CONNECTED.
13. ANY LIGHTING FIXTURE WITH "/EM" SHALL HAVE 1-1/2 HOUR EMERGENCY BATTERY.
14. FINAL FIXTURE SELECTION TO BE APPROVED BY PROJECT ARCHITECT / INTERIOR DESIGNER.
15. FOR RECESSED DOWNLIGHTS THAT PENETRATE BUILDING ENVELOPE, PROVIDE AIR TIGHT TYPE FIXTURE.
16. ANY FIXTURE RECESSED IN A FIRE RATED CEILING SHALL BE PROVIDED WITH A FIRE RATED ENCLOSURE AROUND PORTION OF FIXTURE ABOVE CEILING. FIRE RATED ENCLOSURE SHALL MATCH FIRE RATING OF CEILING IN WALL IT IS INSTALLED.
17. ALL EXIT/EMERGENCY LIGHTING SHALL HAVE A 90 MINUTE BACKUP CONNECTED TO THE LOCAL LIGHTING CIRCUIT AHEAD OF SWITCHING AND CONTROLS.
18. ALL FLUORESCENT LIGHT FIXTURES SHALL BE 3000 DEGREE WARM COLOR LAMP & HAVE "INSTANT START" BALLAST UNLESS NOTED OTHERWISE.
19. WHERE PRACTICAL CONTRACTORS SHALL LAMP FIXTURE WITH COMPACT FLUORESCENT LAMP.

UNIT LIGHT FIXTURE SCHEDULE ⚠

TYPE	DESCRIPTION	MANUFACTURER CATALOG NO.	VOLTAGE	LAMPS	NOTES
UA/UC/US	SURFACE OVERHEAD LED DOWN LIGHT, GENERAL LOCATIONS	LIGHTING SCIENCE #GLPG WW WH	120	15W LED	
UB	PENDANT KITCHEN ISLAND/BAR FIXTURE	INNOVATIONS LIGHTING #201S-SN-G222	120	100W INCANDESCENT	
UF	DECORATIVE CEILING FAN	CASK INDUSTRIES #CF104 BN	120	(1) 56.7W HIGH (2) E26	
UP	BALCONY WALL MOUNTED FIXTURE	PROGRESS LIGHTING #P5674-31	120	(1) 23W CFL	
UV	WALL MOUNTED VANITY FIXTURE	PROGRESS LIGHTING #P2159-09 (VANITY <54") #P2160-09 (VANITY > 54")	120	(3) 9W LED (4) 9W LED ⚠	MOUNT HORIZONTAL ON WALL CENTER FIXTURE ON BOWL AT DOUBLE VANITY LOCATIONS. CENTER ON VANITY ON SINGLE BOWL LOCATIONS
UC2	REMOVED	TBD BY OWNER/ARCH.			
UC	12" LAWS ROOM PUCK LIGHT	JUNO LIGHTING #JSF 11IN 13LM 27K 90CRI MVOLT ZT WH M6	120	15W LED	

BUILDING LIGHTING FIXTURE SCHEDULE

TYPE	DESCRIPTION	MANUFACTURER CATALOG NO.	VOLTAGE	LAMPS ⚠	NOTES
A	SURFACE OVERHEAD LED DOWN LIGHT, GENERAL LOCATIONS	LIGHTING SCIENCE #GLPG WW WH	120	15W LED	
B	UNIT ENTRY SCONCE	HINKLEY LIGHTING #51152HB	120	(2) 16W LED	ON WALL NEXT TO DOOR
C	4', 2 LAMP FLUORESCENT STRIP WITH WIRE GUARD, ELECTRONIC BALLAST.	LITHONIA LIGHTING #C217 MV	120	(2) 32W T8	
CE	4', 2-LAMP FLUORESCENT STRIP WITH WIRE GUARD, ELECTRONIC BALLAST. 90 MIN 1400 LUMEN BATTERY INVERTER UNIT	LITHONIA LIGHTING #C217 MV I-232	120	(2) 32W T8	1400 LUMEN BATTERY BACKUP
DE	4' SURFACE MOUNTED ENCLOSED FLUORESCENT FIXTURE, ELECTRONIC BALLAST	LITHONIA LIGHTING #GTL4 48L D50 LP835 EL14L	120	45.2W LED	1400 LUMEN BATTERY BACKUP
FE	4' WALL MOUNTED LINEAR LED STAIRWELL FIXTURE WITH SENSOR, STEP DIMMING AND BATTERY BACKUP	DAY-BRITE #SF4C132120-1/1-EBSD-E5	120	32W T8	1400 LUMEN BATTERY BACKUP
EM	WALL MOUNTED EMERGENCY LIGHTING FIXTURE, SELF DIAGNOSTIC, 90 MIN BATTERY BACKUP	EATON SURE-LITES #SEL503D	120	1.4W	BATTERY BACKUP
H	EXTERIOR LED WALL SCONCE FIXTURE, 90 MIN BATTERY BACKUP	HUBBELL #TRP1	120	15W LED	BATTERY BACKUP INTEGRAL PHOTOCELL
EX	EXIT SIGN LED W/90 MIN BATTERY INVERTER UNIT	LITHONIA LIGHTING #LDM	120	LED	BATTERY BACKUP
M	STAND ALONE GARAGE LIGHTING FIXTURE	LITHONIA LIGHTING #FEM L48 3500LM LPPCL MD 120 40K 80CRI	120	33W LED	SURFACE CEILING MTD, WET LOCATION
ME	STAND ALONE GARAGE LIGHTING FIXTURE W/ BATTERY BACKUP	LITHONIA LIGHTING #FEM L48 3500LM LPPCL MD 120 40K 80CRI BSS120	120	33W LED	SURFACE CEILING MTD, WET LOCATION, BATTERY BACKUP
N	6" LED RECESSED DOWNLIGHT	LITHONIA LIGHTING #6RTW6 40K	120	10.5W LED	
LA	RECESSED ROUND LED DOWNLIGHT	SLG LIGHTING #DF 4R 7 GEN'S	120	10W LED	
LB	GLIMPSE SURFACE MOUNTED LED FIXTURE	LIGHTING SCIENCE #GLGW WH	120	13W LED	
LC	SUSPENDED LINEAR LIGHT FIXTURE	TECH LIGHTING #S931-8-H-[illegible]35-W-ELVO	120	12W LED	
LD	LED TAPE LIGHT	[illegible] LED #[illegible]4V-BLBSC2-35-016	24	–	
LE	ROUND PENDANT 79" TO BOTTOM OF FIXTURE	GENERATION LIGHTING #EP1116WGV	120	75W A19	
LF	MAIL / COFFEE LOUNGE PENDANT	EGLO #201294A	120	25.4W LED	
LG	LINEAR SUSPENSION W/ REFLECTOR	ILLUMINATIONS #S 7L 20	120	(7) 6W LED	
LH	ROUND CHANDELIER	KICHLER LIGHTING #43857SN	120	(8) 60W INCANDESCENT	
LI	MINI PENDANT	KICHLER LIGHTING #44255KCC	120	75W INCANDESCENT	
LJ	MODEL UNIT VANITY SCONCE	KICHLER LIGHTING #45886NI	120	(3) 75W INCANDESCENT	
LK	CHANDELIER	CIRCA LIGHTING #T0852290	120	(8) 40W E26	
LL	MINI PENDANT	KICHLER LIGHTING #44147PN	120	75W INCANDESCENT	
LM	CEILING FAN	CIRCA LIGHTING #SMAVR60BKBK	120	–	
LM-W	CEILING FAN, WET LISTED 120" TO BOTTOM OF FIXTURE	TBD	–	–	
LN	ROUND SURFACE MOUNTED DOWNLIGHT FIXTURE, WET LISTED	TBD	–	–	
O	BUILDING ENTRY LIGHT	TBD	–	–	
I	ELEVATOR PIT AND SHAFT LIGHTING FIXTURE	LITHONIA LIGHTING #DWHL L48 3500LM MVOLT 40K 80CRI	120	33W LED	SURFACE WALL MTD
S1	SITE POLE PARKING LIGHT	LITHONIA LIGHTING #DSXO LED P5 40K T4M MVOLT SPA	120	89W LED	
S1-BLC	SITE POLE PARKING LIGHT	LITHONIA LIGHTING #DSXO LED P5 40K BLC MVOLT SPA	120	89W LED	
S1-A	SITE POLE PARKING LIGHT	LITHONIA LIGHTING #DSXO LED P5 40K T5M MVOLT SPA	120	89W LED	
S2	SITE POLE PARKING LIGHT	LITHONIA LIGHTING #DSXO LED P5 40K T4M MVOLT SPA	120	178W LED	
PT1	SITE POLE LIGHT	LITHONIA LIGHTING #RAD1 LED P2 30K ASY	120	38.0107W LED	
PT2	SITE COURTYARD POLE LIGHT	LITHONIA LIGHTING #RAD1 LED P2 30K	120	38.0107W LED	
WP	SITE GARAGE LIGHT	LITHONIA LIGHTING #DSXO LED P5 40K T4M MVOLT	120	89W LED	
CL	SITE COURTYARD LIGHT	LUMENS CANADA INC. #LO420 L4L28 LOP493	120	29.08W LED	

Order Plans @ VIEW LDILine.com

Seal

MICHAEL C. COSTA REGISTERED ENGINEER No. 001106 STATE OF TENNESSEE

03-19-2021

2PA
POOLE & POOLE ARCHITECTURE
3736 Winterfield Road, Suite 102
Midlothian, Virginia 23113
Telephone 804.225.0215
www.2pa.net

Project: 1928
CADD File:
Drawn By: SW
Checked By: WM

Permit Release:
May 19, 2020
Construction Release Set:
May 19, 2020

Revisions

No.	Date	Description
1	03/19/21	Owner Comments

ASI / RFI Revisions

No.	Date	Description

© 2019 Poole & Poole Architecture, LLC
Drawings, specifications and other documents are and shall remain the property of Poole & Poole Architecture, LLC and shall not be used or reproduced in whole or part in any form without prior written consent of Poole & Poole Architecture, LLC.

PHILLIPS-DIADICK ENGINEERING, P.C.
1320 W. Morehead Street
Suite 100
Charlotte, NC 28208
(704) 995-9006 (T)
(704) 941-9007 (F)

This drawing is an instrument of service and shall remain the property of the Phillips-Diadick Engineering, P.C. and shall not be reproduced, published or used in any way without the permission of Phillips-Diadick Engineering, P.C. This may be copyrighted and protected under section 102 of the U.S. Copyright Act 1990. The protection includes but is not limited to design of documents and techniques. Unauthorized use of these plans without the express written permission of Phillips-Diadick Engineering, P.C. is prohibited.

Borough 33
an Apartment Community by
33 Broad MF, LLC
in Chattanooga, Tennessee

Drawing Title:
Electrical Lighting
Fixture Schedule

E0.2

REVISED FOR CONSTRUCTION