


- GENERAL NOTES (THIS SHEET ONLY)
1. (F) INDICATES HVAC EQUIPMENT. SEE E6-01 FOR MECHANICAL EQUIPMENT CONNECTION SCHEDULE.
 2. DO NOT INSTALL DEVICES BACK TO BACK IN ANY FIRE RATED WALL. PROVIDE MINIMUM 24" HORIZONTAL SPACE BETWEEN SUCH OUTLETS.
 3. SEAL ALL PENETRATIONS IN EVERY FIRE RATED WALL AND FLOOR PER UL TO MAINTAIN THE WALL AND FLOOR ORIGINAL RATING.
 4. FINAL LIGHTING LOCATIONS AND SELECTIONS TO BE DETERMINED BY ARCHITECT/INTERIOR DESIGNER.
 5. PROVIDE #10 CONDUCTORS FOR ANY 120V CIRCUIT OVER 100'. PROVIDE #8 CONDUCTOR FOR ANY CIRCUIT OVER 150'.
 6. PROVIDE CONNECTION TO FIRE ALARM CONTROL PANEL FROM ALL FIRE ALARM DEVICES.
 7. TYPE N.M. WIRING FOR BRANCH CIRCUIT WIRING FOR TYPE II, IV AND V CONSTRUCTION IF ACCEPTABLE TO LOCAL AUTHORITY HAVING JURISDICTION. PROVIDE M.C. CABLE OR WIRE/EMT CONDUIT FOR BRANCH CIRCUITS IN ALL OTHER CONSTRUCTION TYPES AND IN RETURN AIR PLenum ROOMS OR SPACES.
 8. COORDINATE LOCATION AND QUANTITY OF FIRE/SMOKE AND/OR SMOKE DAMPERS WITH MECHANICAL CONTRACTOR PRIOR TO BID. COORDINATION OF LOCATIONS AND QUANTITIES WILL OVERRIDE LOCATIONS AND QUANTITIES INDICATED ON ELECTRICAL DRAWINGS. PROVIDE A 120V UNSWITCHED CIRCUIT TO EACH FIRE/SMOKE DAMPER AND/OR SMOKE DAMPER. PROVIDE A DUCT MOUNTED SMOKE DETECTOR IN FIRE/SMOKE DAMPER SHAFT. CONNECT DUCT MOUNTED SMOKE DETECTOR AND FIRE/SMOKE AND/OR SMOKE DAMPER TO FIRE ALARM SYSTEM. A CHANGE ORDER WILL NOT BE ALLOWED FOR LACK OF COORDINATION BETWEEN THE ELECTRICAL AND MECHANICAL CONTRACTOR FOR LOCATION AND QUANTITY OF FIRE/SMOKE DAMPER AND/OR SMOKE DAMPERS.
 9. ALL CEILING MOUNTED CORRIDOR LIGHTING FIXTURES ARE TYPE 'A'.
 10. ALL UNIT ENTRY WALL SCENE LIGHTING FIXTURES ARE TYPE 'B'.
 11. ALL STRIP FIXTURES ARE TYPE 'C/CE'.
 12. ALL STARWELL FIXTURES ARE TYPE 'DE'.
 13. ALL EMERGENCY LIGHTING FIXTURES ARE TYPE 'EM'.
 14. ALL EXIT SIGNS ARE TYPE 'EX'.

Seal



03-19-2021



ZPA
POOLE & POOLE ARCHITECTURE
 3736 Winterfield Road, Suite 102
 Midlothian, Virginia 23113
 Telephone 804.275.0215
 www.zpa.net

Project: 1928
 CADD File:
 Drawn By: SW
 Checked By: WM

Permit Release:
 May 19, 2020
 Construction Release Set:
 May 19, 2020

Revisions

No.	Date	Description
1	03/19/21	Owner Comments

© 2019 Poole & Poole Architecture, LLC. Design and specifications are the property of Poole & Poole Architecture, LLC and shall not be used, reproduced, or copied in any form without prior written consent of Poole & Poole Architecture, LLC.

PRISSE BRADY ENGINEERING, P.C.
 100 N. Riverside Drive
 Nashville, TN 37203
 (615) 259-1111
 www.prissebrady.com

Borough 33
 an Apartment Community by
 33 Broad MF, LLC
 in Chattanooga, Tennessee

Drawing Title:
 Clubhouse Lighting Plan

E6.1

1 Clubhouse - Lighting Plan
 Scale: 1/4" = 1'-0"

Order Plans @ www.Line.com

www.Line.com

REVISIONS: 03/19/21 (1)